




Conceptual Drinking Water Supply Plan

Long-term options for the East Metropolitan area.



1 **Authors**

- 2 Elizabeth Kaufenberg
- 3 Andri Dahlmeier
- 4 Michele Mabry
- 5 Abt Associates (Abt)
- 6 Wood Environment & Infrastructure Solutions, Inc. (Wood)

7 **Contributors/Acknowledgments**

- 8 Kirk Koudelka, MPCA Assistant Commissioner
- 9 Jess Richards, DNR Assistant Commissioner
- 10 Steve Colvin, DNR
- 11 Kathy Sather, MPCA
- 12 Gary Krueger, MPCA
- 13 Susan Johnson, MPCA
- 14 Rebecca Higgins, MPCA
- 15 Jeanne Giernet, MPCA
- 16 Jason Moeckel, DNR
- 17 John Seaberg, DNR
- 18 Karla Peterson, MDH
- 19 Lucas Martin, MDH
- 20 Corey Mathison, MDH

21 *Government and 3M Working Group Members*

- | | |
|---|--|
| 22 Bill Palmquist, Afton | 36 Christina Volkers, Oakdale |
| 23 Ron Moorsee, Afton | 37 Paul Reinke, Oakdale |
| 24 Jennifer Levitt, Cottage Grove | 38 Jessica Stolle, Prairie Island Indian Community |
| 25 Kathy Higgins, Denmark Township | 39 Kevin Walsh, St. Paul Park |
| 26 Ray Kaiser, Grey Cloud Island Township | 40 Jeff Dionisopoulos, St. Paul Park |
| 27 Kristina Handt, Lake Elmo | 41 Daniel Kylo, West Lakeland Township |
| 28 Craig Morris, Lakeland and Lakeland Shores | 42 Marian Appelt, West Lakeland Township |
| 29 Edward Shukle, Lakeland | 43 Clint Gridley, Woodbury |
| 30 Andy Erickson, Lakeland | 44 Chris Hartzell, Woodbury |
| 31 Brian Zeller, Lakeland Shores | 45 Lowell Johnson, Washington County |
| 32 Shann Finwall, Maplewood | 46 David Brummel, Washington County |
| 33 Michael Martin, Maplewood | 47 Jim Kotsmith, 3M |
| 34 Dan Lund, Newport | 48 Karie Blomquist, 3M |
| 35 Kevin Chapdelaine, Newport | |
| 49 <i>Citizen Business Group</i> | |
| 50 Julie Bunn, Lake Elmo | 51 Betsy Daub, Friends of the Mississippi |

Minnesota Pollution Control Agency

520 Lafayette Road North | Saint Paul, MN 55155-4194
651-296-6300 | 800-657-3864 | Or use your preferred relay service. | Info.pca@state.mn.us

Minnesota Department of Natural Resources

500 Lafayette Road North | Saint Paul, MN 55155-4194
651-296-6157 | 888-646-6367 | Or use your preferred relay service.

This report is available in alternative formats upon request.

Document number: xxx-xx-xxxxx

- | | | | |
|----|---|----|---|
| 1 | David Filipiak, Woodbury | 10 | Jack Lavold, Cottage Grove |
| 2 | Charlotte Flint, West Lakeland Township | 11 | Michael Madigan, Woodbury |
| 3 | Bob Fossum, Lake Elmo | 12 | Barbara Ronningen, Afton |
| 4 | Jeff Holtz, Lake Elmo | 13 | Dave Schulenberg, Cottage Grove |
| 5 | Mark Jenkins, Maplewood | 14 | Monica Stiglich, Oakdale (Government-3M) |
| 6 | Bruce Johnson, Oakdale | 15 | Working Group Liason) |
| 7 | David Johnson, Local Chamber of Commerce | 16 | Amy Schall, St. Paul Park |
| 8 | Steven Johnson, West Lakeland Township | 17 | Kevin Chapdelaine, Newport (Government-3M) |
| 9 | Katie Johnston-Goodstar, Maplewood | 18 | Working Group Liason) |
| 19 | <i>Drinking Water Supply Technical Subgroup Members</i> | | |
| 20 | Greg Johnson, Afton | 44 | Sam Paske, Met Council |
| 21 | John Christensen, Afton | 45 | Brian Davis, Met Council |
| 22 | Ryan Burfeind, Cottage Grove | 46 | Tony Runkel, Minnesota Geological Survey |
| 23 | Jennifer Levitt, Cottage Grove | 47 | Kurt Haakinson, Minnesota Rural Water |
| 24 | Kathy Higgins, Denmark Township | 48 | Association |
| 25 | Ray Kaiser, Grey Cloud Island Township | 49 | Richard Thron, Minnesota Water Well |
| 26 | Richard Adams, Grey Cloud Island Township | 50 | Association |
| 27 | Jack Griffin, Lake Elmo | 51 | Karen Kill, Browns Creek Watershed District |
| 28 | Kristina Handt, Lake Elmo | 52 | Matt Downing, Middle St. Croix Watershed |
| 29 | Dave Simons, Lakeland | 53 | Management Organization |
| 30 | Steve Love, Maplewood | 54 | Stu Grubb, Middle St. Croix Watershed |
| 31 | Molly Wellens, Maplewood | 55 | Management Organization |
| 32 | Jon Herdegen, Newport | 56 | Tina Carstens, Ramsey-Washington Metro |
| 33 | Brian Miller, Newport | 57 | Watershed District |
| 34 | Brian Bachmeier, Oakdale | 58 | Matt Moore, South Washington Watershed |
| 35 | Shawn Nelson, Oakdale | 59 | District |
| 36 | Dan DeRudder, Prairie Island Indian Community | 60 | John Hanson, Valley Branch Watershed District |
| 37 | Greg Johnson, St. Paul Park | 61 | Erik Anderson, Washington Conservation |
| 38 | Jon Christensen, St. Paul Park | 62 | District |
| 39 | Marian Appelt, West Lakeland Township | 63 | Jim Kotsmith, 3M |
| 40 | Ryan Stempski, West Lakeland Township | 64 | Chris Bryan, 3M |
| 41 | Jim Westerman, Woodbury | 65 | Gary Krueger, MPCA |
| 42 | Chris Hartzell, Woodbury | 66 | Karla Peterson, MDH |
| 43 | Stephanie Souter, Washington County | 67 | Lucas Martin, MDH |
| 68 | Editing and Graphic Design | | |
| 69 | Jeanne Giernet | | |
| 70 | Scott Andre | | |
| 71 | Abt Associates | | |

Minnesota Pollution Control Agency

520 Lafayette Road North | Saint Paul, MN 55155-4194
 651-296-6300 | 800-657-3864 | Or use your preferred relay service. | Info.pca@state.mn.us

Minnesota Department of Natural Resources

500 Lafayette Road North | Saint Paul, MN 55155-4194
 651-296-6157 | 888-646-6367 | Or use your preferred relay service.

This report is available in alternative formats upon request.

Document number: xxx-xx-xxxxx

1 Wood
2
3 Administrative staff
4
5 The Minnesota Pollution Control Agency (MPCA) is reducing printing and mailing costs by using the
6 Internet to distribute reports and information to a wider audience. Visit our website for more
7 information.
8 The MPCA reports are printed on 100% post-consumer recycled content paper manufactured without
9 chlorine or chlorine derivatives.
10

DRAFT

Minnesota Pollution Control Agency

520 Lafayette Road North | Saint Paul, MN 55155-4194
651-296-6300 | 800-657-3864 | Or use your preferred relay service. | Info.pca@state.mn.us

Minnesota Department of Natural Resources

500 Lafayette Road North | Saint Paul, MN 55155-4194
651-296-6157 | 888-646-6367 | Or use your preferred relay service.
This report is available in alternative formats upon request.

Document number: xxx-xx-xxxxx

Contents

1	Glossary	vi
2	Acronyms and abbreviations	xiii
3	Appendix A. Introduction	1
4	A.1 Afton	1
5	A.1.1 Community background	1
6	A.1.2 Current and proposed projects.....	2
7	A.2 Cottage Grove	3
8	A.2.1 Community background	3
9	A.2.2 Current and proposed projects.....	5
10	A.3 Denmark.....	7
11	A.3.1 Community background	7
12	A.3.2 Current and proposed projects.....	7
13	A.4 Grey Cloud Island	9
14	A.4.1 Community background	9
15	A.4.2 Current and proposed projects.....	9
16	A.5 Lake Elmo	11
17	A.5.1 Community background	11
18	A.5.2 Current and proposed projects.....	12
19	A.6 Lakeland and Lakeland Shores.....	14
20	A.6.1 Community background	14
21	A.6.2 Current and proposed projects.....	15
22	A.7 Maplewood	16
23	A.7.1 Community background	16
24	A.7.2 Current and proposed projects.....	16
25	A.8 Newport	18
26	A.8.1 Community background	18
27	A.8.2 Current and proposed projects.....	19
28	A.9 Oakdale	21
29	A.9.1 Community background	21
30	A.9.2 Current and proposed projects.....	22

1	A.10	Prairie Island Indian Community.....	24
2		A.10.1 Community background	24
3		A.10.2 Current and proposed projects.....	24
4	A.11	St. Paul Park	25
5		A.11.1 Community background	25
6		A.11.2 Current and proposed projects.....	26
7	A.12	West Lakeland.....	28
8		A.12.1 Community background	28
9		A.12.2 Current and proposed projects.....	28
10	A.13	Woodbury	30
11		A.13.1 Community background	30
12		A.13.2 Current and proposed projects.....	32
13		References	33
14	Appendix B.	Conceptual site model for the East Metropolitan Area.....	B-1
15	B.1	Introduction	B-1
16		B.1.1 Purpose and scope.....	B-1
17		B.1.2 Data and sources.....	B-2
18	B.1	Physical setting and climate.....	B-3
19	B.2	Geology and hydrostratigraphy	B-3
20		B.2.1 Structural setting	B-3
21		B.2.2 Bedrock geology and hydrostratigraphy	B-4
22		B.2.3 Quaternary geology and hydrostratigraphy	B-11
23	B.3	Groundwater recharge	B-14
24		B.3.1 Precipitation.....	B-14
25		B.3.2 Surface water sources.....	B-14
26	B.4	Groundwater discharge	B-16
27		B.4.1 Pumping wells.....	B-16
28		B.4.2 Baseflow.....	B-16
29		B.4.3 Lakes.....	B-17
30	B.5	Groundwater flow.....	B-17
31	B.6	PFAS source areas and groundwater sampling results.....	B-18
32	B.7	Data gaps.....	B-19

1 References 12

2 **Appendix C. Numerical model description and construction..... 1**

3 C.1 Introduction 1

4 C.1.1 Purpose and scope 1

5 C.1.2 Data and sources 1

6 C.1.3 Previous modeling efforts 2

7 C.2 Model description and discretization 3

8 C.3 Boundary conditions 5

9 C.3.1 Surface water boundaries 5

10 C.3.2 Perimeter boundaries 9

11 C.4 Hydraulic conductivity 9

12 C.4.1 Quaternary layers 9

13 C.4.2 Bedrock layers 10

14 C.5 Recharge 11

15 C.6 Pumping wells 12

16 C.7 Solver 13

17 C.8 Calibration 14

18 C.8.1 Baseflow 17

19 C.8.2 Water Balance 18

20 C.9 Effective porosity for particle tracking 19

21 C.10 Model Limitations 19

22 **Appendix D. Conceptual project list D-1**

23 D.1 Conceptual project list D-1

24 References 26

25 **Appendix E. Scenario results E-1**

26 **Appendix F. Scenarios supporting documentation F-1**

27 F.1 Unit cost estimations F-1

28 F.1.1 Introduction F-1

29 F.1.2 Water mains F-1

30 F.1.3 Storage tanks or towers F-6

31 F.1.4 Booster pump stations F-7

1	F.1.5 Buildings	F-8
2	F.1.6 Municipal and non-municipal wells	F-8
3	F.1.7 Land acquisition	F-9
4	F.2 Small community water system analysis	F-9
5	F.2.1 Introduction	F-9
6	F.2.2 Methods	F-10
7	F.2.3 Afton	F-11
8	F.2.4 Grey Cloud Island	F-15
9	F.2.5 West Lakeland	F-20
10	F.2.6 Average cost per home for community water systems	F-25
11	F.2.7 Conclusion	F-26
12	F.3 Treatment technology comparison	F-27
13	F.3.1 Introduction	F-27
14	F.3.2 Mature technologies	F-29
15	F.3.3 Waste disposal and management	F-36
16	F.3.4 Other variables	F-37
17	F.3.5 Conclusions	F-37
18	References	F-38
19	Appendix G. Scenario evaluation	G-1
20	G.1 Recommended scenarios	G-1
21	G.1.1 Scenario A.1 (HI>0.5, GAC) – Recommended Option 1	G-1
22	G.1.2 Scenario A.1 (HI>0.3, GAC) – Recommended Option 2	G-3
23	G.1.3 Scenario C.1 (SPRWS, HI>0.5, GAC) – Recommended Option 3	G-5
24	G.2 Other scenarios	G-8
25	G.2.1 Scenario A (HI>1, GAC)	G-8
26	G.2.2 Community Scenario, A HI>0, GAC	G-9
27	G.2.3 Community Scenario A, HI>1, IX	G-11
28	G.2.4 Community Scenario A, HI>0, IX	G-13
29	G.2.5 Community Scenario B, HI>1, GAC	G-15
30	G.2.6 Community Scenario B, HI>1, IX	G-18
31	G.2.7 Community Scenario B, HI>0, GAC	G-20
32	G.2.8 Community Scenario B, HI>0, IX	G-23

1 G.2.9 Community Scenario C, HI>1, GACG-25

2 G.2.10 Community Scenario C, HI>1, IXG-28

3 G.2.11 Community Scenario C, HI>0, GACG-31

4 G.2.12 Community Scenario C, HI>0, IXG-34

5 G.2.13 Community Scenario D, HI>1, GACG-36

6 G.2.14 Community Scenario D, HI>1, IXG-38

7 G.2.15 Community Scenario D, HI>0, GACG-40

8 G.2.16 Community Scenario D, HI>0, IXG-42

9 G.3 Previous Community-specific scenariosG-44

10 G.3.1 Community-Specific Scenario 1A – GACG-44

11 G.3.2 Community-Specific Scenario 1A – IXG-46

12 G.4 Previous regional scenariosG-48

13 G.4.1 Regional Scenario 2AG-48

14 G.4.2 Regional Scenario 2B.1G-51

15 G.4.3 Regional Scenario 2C – SPRWSG-54

16 G.4.4 Regional Scenario 2B.2 – Mississippi and St Croix SWTPsG-56

17 G.4.5 Regional Scenario 2E – sub-regional groundwater (GAC)G-59

18 G.4.6 Regional Scenario 2E – sub-regional groundwater (IX)G-61

19 G.5 Previous treatment scenariosG-63

20 G.5.1 Treatment Scenario 3A – HI(PFAS) > 1 (GAC)G-63

21 G.5.2 Treatment Scenario 3A – HI(PFAS) > 1 (IX)G-65

22 G.5.3 Treatment Scenario 3B – HI(PFAS) > 0.5 (GAC)G-67

23 G.5.4 Treatment Scenario 3B – HI(PFAS) > 0.5 (IX)G-69

24 G.5.6 Treatment Scenario 3C – HI(PFOS, PFOA, PFHxS) > 0 (GAC)G-71

25 G.5.7 Treatment Scenario 3C – HI(PFOS, PFOA, PFHxS) > 0 (IX)G-73

26 G.5.8 Treatment Scenario 3D – HI(PFAS) > 0 (GAC)G-75

27 G.5.9 Treatment Scenario 3D – HI(PFAS) > 0 (IX)G-77

28 G.6 Integrated scenariosG-79

29 G.6.1 Integrated Scenario 4A – GACG-79

30 G.6.2 Integrated Scenario 4A – IXG-81

31

Glossary

- 1 **Alignment** – Location of water lines relative to other infrastructure, typically roadways.
- 2 **Aquifer** – An underground layer of water-bearing permeable rock; rock fractures; or loose, unpacked
3 materials (gravel, sand, or silt). In a water-table (unconfined) aquifer, the water table (upper water
4 surface) rises and falls with the amount of water in the aquifer. In a confined aquifer, layers of
5 impermeable material both above and below cause the water to be under pressure, so that when the
6 aquifer is penetrated by a well, the water will rise above the top of the aquifer (artesian condition).
- 7 **Aquitard** – An underground layer that has low permeability and limits, but does not completely prevent
8 the flow of water to or from an adjacent aquifer.
- 9 **Booster pump station** – A pump station located within the water supply system that is designed to
10 boost the pressure of water within a long pipeline.
- 11 **Capital costs** – One-time costs to build or rebuild infrastructure, including treatment plants, wells,
12 distribution systems, and other facilities.
- 13 **Centralized system** – A centralized water treatment approach, referred to here as a centralized system,
14 for a given service treats water at a single treatment facility in a central location and then distributes
15 water via dedicated water distribution network across the service area.
- 16 **Citizen-Business Group** – One of two work groups to help the Minnesota Pollution Control Agency
17 (MPCA) and the Minnesota Department of Natural Resources (DNR) identify and recommend priorities
18 and projects to be funded from the Grant. This group is composed of the MPCA; the DNR; and about
19 15 citizen, business, and nongovernmental representatives who live or work in the East Metropolitan
20 Area. One representative from the Government and 3M Working Group serves as a liaison to this group.
- 21 **Conceptual Drinking Water Supply Plan (Conceptual Plan)** – This plan, developed from a strategic
22 planning effort as a step toward addressing the goal of Priority 1 of the 2018 Settlement, which is to
23 ensure clean drinking water in sufficient supply to residents and businesses in the East Metropolitan
24 Area to meet current and future needs. The Conceptual Plan presents a recommendation consisting of
25 sets of conceptual projects (called scenarios) that, when combined, address drinking water quality and
26 quantity issues for the 14 communities currently known to be affected by per- and polyfluoroalkyl
27 substances (PFAS) contamination in the East Metropolitan Area. This Conceptual Plan will be used to
28 guide the development and implementation of projects to be funded under the Grant.
- 29 **Conceptual projects** – Project ideas developed by the work groups, Subgroup 1, members of the public,
30 and the Co-Trustees to address PFAS-related drinking water quality and quantity issues in the East
31 Metropolitan Area. These conceptual projects are consistent with the water supply improvement
32 options, but provide more detail, such as information on project location(s), project components(s), and
33 PFAS treatment technologies.
- 34 **Conceptual site model (CSM)** – A simplified set of assumptions, data, and information that was used to
35 develop a picture of how the groundwater system functions as the basis for developing the more
36 detailed groundwater model.
- 37 **Co-Trustees** – The MPCA and DNR. Under the Minnesota Environmental Response and Liability Act
38 (MERLA), the State is the Trustee for all natural resources in the State, including air, water, and wildlife.

- 1 The Governor’s Executive Order 19-29 (inclusive of 11-09) designated the Commissioners of the MPCA
2 and DNR as Co-Trustees for natural resources under MERLA and other laws.
- 3 **Decentralized system** – A decentralized water treatment approach, referred to here as a decentralized
4 system, differs from a centralized system as it may rely on multiple treatment facilities at various
5 locations to serve communities/neighborhoods in a given service area. Typically these treatment
6 facilities are far enough apart such that it mitigates the cost and/or water quality concerns of a
7 centralized treatment facility. On a much smaller scale a decentralized system may also rely on point-of-
8 entry (POET) or point-of-use (POUT) treatments that are installed at individual homes or businesses to
9 achieve potable water.
- 10 **Distribution line** – A smaller diameter line, typically between 6 and 16 inches, which supplies water to
11 consumers.
- 12 **Distribution system** – The portion of a water supply network that conveys potable water from
13 transmission lines to water consumers and provides for residential, commercial, industrial, and fire-
14 fighting water demand requirements. A distribution system can contain distribution lines, booster pump
15 stations, pressure-reducing valves, and storage facilities such as water storage tanks or towers.
- 16 **Drinking water distribution model** – A comprehensive representation of the current and planned
17 drinking water supply infrastructure in the East Metropolitan Area used to support the evaluation of
18 scenarios in this Conceptual Plan. The model includes information on drinking water supply
19 infrastructure (e.g., connections, demand, water usage, available water supply, system pressures,
20 layouts and locations of infrastructure) as well as private and non-community public supply well data.
- 21 **Drinking Water Supply Technical Subgroup (Subgroup 1)** – A subgroup composed of technical experts
22 formed to analyze options, deliver assessments, and provide advice for long-term options for drinking
23 water supply and treatment to the Government and 3M Working Group, and the Citizen-Business
24 Group.
- 25 **East Metropolitan Area** – Communities to the East of the Minneapolis/St. Paul Metropolitan Area that
26 have been affected by PFAS releases from the 3M Company (3M) source areas. Currently comprised of
27 the cities of Afton, Cottage Grove, Lake Elmo, Lakeland, Lakeland Shores, Maplewood, Newport,
28 Oakdale, St. Paul Park, and Woodbury; the townships of Denmark, Grey Cloud Island, and West
29 Lakeland; and the Prairie Island Indian Community.
- 30 **Government and 3M Working Group** – One of two work groups to help the MPCA and DNR identify and
31 recommend priorities and projects to be funded under the Grant. The formation of a working group
32 consisting of representatives from the MPCA, the DNR, the East Metropolitan Area communities, and
33 3M to identify and recommend projects was a requirement of the 2018 Agreement and Order. One
34 representative from the Citizen-Business Group serves as a liaison to this group.
- 35 **Granular activated carbon (GAC)** – GAC is made from raw organic materials (such as coconut shells or
36 coal) that are high in carbon. Heat, in the absence of oxygen, is used to increase (activate) the surface
37 area of the carbon, which is why these filters are sometimes referred to as “charcoal” filters. The
38 activated carbon removes certain chemicals that are dissolved in water passing through a filter
39 containing GAC by trapping (adsorbing) the chemical in the GAC.
- 40 **Groundwater Management Area** – A designation created by the Minnesota legislature as a tool for the
41 DNR to address difficult groundwater-related resource challenges. Within these areas, the DNR may
42 limit total annual water appropriations and uses to ensure sustainable use of groundwater that protects

- 1 ecosystems, water quality, and the ability of future generations to meet their own needs. Washington
2 County, along with Ramsey County and portions of Anoka and Hennepin counties, fall within the North
3 and East Metro Groundwater Management Area.
- 4 **Groundwater model** – A numerical, three-dimensional representation of the groundwater aquifers in
5 the East Metropolitan Area used to support the evaluation of scenarios in this Conceptual Plan. The
6 purpose of the groundwater model is to provide insight into the current groundwater flow system, and
7 predict impacts to flow paths and groundwater resources through the year 2040 from the proposed
8 scenarios. These flow paths and quantity estimates are based on projected groundwater
9 recharge/precipitation rates, surface water elevations, and pumping volumes of the proposed scenarios.
- 10 **Health advisories** – Non-enforceable and non-regulatory technical guidance for state agencies and other
11 public health officials on health effects, analytical methodologies, and treatment technologies
12 associated with drinking water contamination. Health advisories are based on non-cancer health effects
13 for different lengths of exposure (1 day, 10 days, or a lifetime). In 2016, the U.S. Environmental
14 Protection Agency (EPA) released health advisory values for perfluorooctanoic acid (PFOA) and
15 perfluorooctane sulfonate (PFOS).
- 16 **Health-based value (HBV)** – A health-based water guidance value developed by the Minnesota
17 Department of Health (MDH) using the same scientific methods as health risk limits (HRLs), including
18 peer review. Like an HRL, it is the concentration of a water contaminant, or a mixture of contaminants
19 that, based on current knowledge, can be consumed with little or no risk to health by the most exposed
20 and sensitive individuals in a population. HBVs are developed to provide water guidance between rule-
21 making cycles for chemicals that may have been recently detected in the water or for which new health
22 information has become available.
- 23 **Health risk index (health index, HI)** – An indicator of the combined risk of exposure to multiple
24 chemicals that cause the same health effects. It is determined by calculating the concentration of each
25 chemical divided by its HRL or HBV, and adding the resulting ratios. A HI greater than one indicates
26 possible combined effects. The health risk index is referred to interchangeably throughout the
27 document as the health risk index, health index, HI, or HRI.
- 28 **Health risk limit (HRL)** – A health-based water guidance value developed by MDH that has been
29 promulgated through the Minnesota rule-making process, which includes peer review and public input.
30 It is the concentration of a groundwater contaminant, or a mixture of contaminants that, based on
31 current knowledge, can be consumed with little or no risk to health by the most exposed and sensitive
32 individuals in a population.
- 33 **High-service pump** – Pumps located at the water treatment facility that deliver large volumes of
34 treated, potable water to the water supply system.
- 35 **Horizontal directional drilling** – A minimal impact trenchless method of installing underground utilities
36 such as pipe, conduit, or cables in a relatively shallow arc or radius along a prescribed underground path
37 using a surface-launched drilling rig.
- 38 **Ion exchange (IX)** – IX processes are reversible chemical reactions for removing dissolved ions from a
39 solution and replacing them with other similarly charged ions. In water treatment, it is primarily used for
40 softening where calcium and magnesium ions are removed from water; however, it is being used more
41 frequently for the removal of other dissolved ionic species.

1 **Jack and bore** – A method of horizontal boring construction for installing casing or steel pipes under
 2 roads or railways. Construction crews drill a hole underground horizontally between two points (the
 3 sending and receiving pits) without disturbing the surface in-between. This is accomplished by using an
 4 auger boring machine that inserts a casing pipe as it moves through the earth while simultaneously
 5 removing the soil from within the casing pipe.

6 **Maximum contaminant level (MCL)** – The maximum level of a contaminant allowed in water delivered
 7 from a public water supply. MCLs are set by EPA through a scientific process that evaluates the health
 8 impacts of the contaminant; and the technology and cost required for the prevention, monitoring,
 9 and/or treatment. States are allowed to enforce lower (i.e., more strict) standards than MCLs, but are
 10 not allowed to enforce higher (i.e., less strict) standards.

11 **Metropolitan Council** – The regional policy-making body, planning agency, and provider of essential
 12 services (including transportation, wastewater, water supply planning, growth planning, parks and trails,
 13 and affordable housing) for the Twin Cities metropolitan region. The Minnesota Legislature established
 14 the Metropolitan Council in 1967, which has 17 members who are appointed by the Governor.

15 **Municipal supply well** – A drinking water well that serves as a source of water for a municipal water
 16 system.

17 **Municipal water system** – Refers to an existing municipality’s drinking or potable water treatment and
 18 distribution system.

19 **Non-community public supply well** – A well that provides water to the public in places other than their
 20 homes – where people work, gather, and play (e.g., schools, offices, factories, child care centers, or
 21 parks) – and is part of a non-community public water system (see definition below).

22 **Non-community public water system** – A drinking water system that supplies water from private water
 23 supply well(s) on a year-round basis to:

- 24 • A residential development with six or more private residences (e.g., apartment buildings, private
 25 subdivisions, condominiums, townhouse complexes, mobile home parks), or
- 26 • A mobile home park or campground with six or more sites with water service hookup.

27 **Non-municipal well** – A well considered under this Conceptual Plan that excludes municipal supply wells
 28 and includes domestic, irrigation, commercial, and non-community public water supply wells.

29 **Operations and maintenance (O&M)** – All work activities necessary to operate and maintain all water
 30 treatment and supply facilities from the source of water through the distribution systems.

31 **Per- and polyfluoroalkyl substances (PFAS)** – A family of synthetic chemicals, initially developed by 3M,
 32 used to make products that resist heat, oil, stains, grease, and water. They are extremely resistant to
 33 breakdown in the environment, accumulate in humans and animals, and are “emerging contaminants”
 34 that are the focus of active research and study. Specific chemicals within the PFAS family include PFOA,
 35 PFOS, perfluorohexane sulfonate (PFHxS), perfluorobutane sulfonate (PFBS), and perfluorobutanoic acid
 36 (PFBA).

37 **Point-of-entry Treatment (POET)** – Water treatment systems installed on the water line as it enters an
 38 individual home, business, school, or other building. These systems treat all the water entering the
 39 building.

40 **Point-of-use treatment (POUT)** – Water treatment systems installed on the water line at the point of
 41 use, such as a faucet.

- 1 **Pressure-reducing stations** – Locations within the water supply system where a pressure-reducing valve
2 has been installed.
- 3 **Pressure-reducing valves** – A valve fitted in a pipe system, which in spite of varying pressures on the
4 inlet side (inlet pressure), ensures that a certain pressure on the outlet side (outlet pressure) is not
5 exceeded, thus protecting the components and equipment on the outlet side.
- 6 **Priority 1** – The first priority of the Grant is to enhance the quality, quantity, and sustainability of
7 drinking water in the East Metropolitan Area. The goal of this highest priority work is to ensure clean
8 drinking water in sufficient supply to residents and businesses in the East Metropolitan Area to meet
9 their current and future water needs. Examples of projects in this first priority may include, but are not
10 limited to, the development of alternative drinking water sources for municipalities and individual
11 households (including but not limited to creation or relocation of municipal wells), the treatment of
12 existing water supplies, water conservation and efficiency, open space acquisition, and groundwater
13 recharge (including projects that encourage, enhance, and assist groundwater recharge). For individual
14 households, projects may include, but are not limited to, connecting those residences to municipal
15 water supplies, providing individual treatment systems, or constructing new wells.
- 16 **Priority 2** – The second priority for Grant spending is to restore and enhance aquatic resources, wildlife,
17 habitat, fishing, resource improvement, and outdoor recreational opportunities in the East Metropolitan
18 Area and in downstream areas of the Mississippi and St. Croix rivers. The MPCA and DNR have
19 immediate access to \$20 million in Grant funds for projects in this priority category. After the safe
20 drinking water goals of the first priority are reasonably achieved, all remaining Grant money is then
21 available for natural resource restoration and enhancement projects.
- 22 **Priority 3** – If there are funds remaining after the first two priority goals have been met, the Grant can
23 be used for statewide environmental improvement projects. Only projects in categories such as
24 statewide water resources, habitat restoration, open space preservation, recreation improvements, or
25 other sustainability projects would be eligible.
- 26 **Private well** – A domestic drinking water well that is not part of a public water system. The quality and
27 safety of water from private wells are not regulated by the Federal Safe Drinking Water Act and, in most
28 cases, by state laws.
- 29 **Public supply well** – A drinking water well that serves as a source of water for a public water system.
- 30 **Public water system** – A regulatory term under the federal Safe Drinking Water Act for a drinking water
31 supply system that serves at least 15 homes or 25 people for at least 60 days a year.
- 32 **Recharge** – Water added to the aquifer from the surface through the unsaturated (dry or vadose) zone
33 in the uppermost soils through processes called infiltration and percolation following any precipitation
34 (rain or snow) event.
- 35 **Regional water supply system** – A water system that supplies potable water to more than
36 one community or water system.
- 37 **Scenarios** – Sets of conceptual projects that consider water supply, distribution, and demand; and are
38 evaluated in this Conceptual Plan using drinking water distribution and groundwater models.
- 39 **Small community water system** – A private and voluntary water system that serves neighborhood-sized
40 clusters of residences.

- 1 **Special Well and Boring Construction Area (SWBCA)** – A mechanism that provides for controls on the
 2 drilling or alteration of wells in an area where groundwater contamination has, or may, result in risks to
 3 public health. The purposes of a Special Well and Boring Construction Area are to inform the public of
 4 potential health risks in areas of groundwater contamination, provide for the construction of safe water
 5 supplies, and prevent the spread of contamination due to the improper drilling of wells or borings.
- 6 **Sustainability** – Responsible interaction with the environment to avoid depletion or degradation of
 7 natural resources. Minnesota Statutes § 103G.287, subd. 5, describes ground water sustainability as the
 8 development and use of groundwater resources to meet current and future beneficial uses without
 9 causing unacceptable environmental or socioeconomic consequences.
- 10 **3M Grant for Water Quality and Sustainability Fund (Grant)** – Under terms of the Agreement, an
 11 \$850 million Grant was made by 3M to the State to be used to enhance the quality, quantity, and
 12 sustainability of the drinking water in the East Metropolitan Area; to restore and enhance natural
 13 resources and outdoor recreational opportunities; and to reimburse the State for certain other
 14 expenses.
- 15 **Transmission line** – A large-diameter pipeline designed to convey large volumes of water at higher
 16 pressures from a source (typically a water treatment facility) to a distribution system for use. Water
 17 transmission lines are typically larger in diameter (greater than 16 inches) and consumers are not
 18 typically placed on transmission lines because of their high velocities and pressures.
- 19 **2007 Consent Order** – An agreement between 3M and the MPCA requiring 3M to investigate and take
 20 remedial actions to address releases and threatened releases of PFAS from the 3M Cottage Grove Site,
 21 the 3M Oakdale Disposal Site, and the 3M Woodbury Disposal Site; and to reimburse the MPCA for its
 22 costs to oversee the remediation Remedial actions taken under the Consent Order can help provide safe
 23 drinking water to affected homes and communities (e.g., installation of temporary or permanent
 24 treatment).
- 25 **2018 Agreement and Order (Settlement)** – An agreement to settle the State’s Natural Resources
 26 Damage lawsuit against 3M for \$850 million. Minnesota’s Attorney General sued 3M in 2010, alleging
 27 that the company’s disposal of PFAS had damaged and continues to damage drinking water and natural
 28 resources in the East Metropolitan Area. After legal and other expenses were paid, about \$720 million is
 29 available to finance drinking water and natural resource projects in this region. The MPCA and DNR are
 30 Co-Trustees of these funds.
- 31 **Watershed districts** – Special government entities that monitor and regulate the use of water within
 32 certain watersheds in Minnesota, rather than political boundaries, which were first authorized by the
 33 legislature in 1955.
- 34 **Water storage tank** – A water storage facility consisting of a cylindrical tank that has a base elevation at
 35 the existing ground surface. Storage facilities provide sufficient water volume to meet peak hour water
 36 demands and provide
- 37 **Water storage tower** – An elevated water storage facility (also referred to as a water tower) that
 38 supports a water storage tank with a base elevation above the existing ground surface to provide
 39 sufficient pressure to the water distribution system and to provide emergency storage for fire
 40 protection.
- 41 **Water supply improvement options** – A reasonable range of options that could improve drinking water
 42 quality and quantity, including both centralized and decentralized systems, which are evaluated against

- 1 a set of screening criteria in this Conceptual Plan to determine their relevance to the individual
2 communities in the East Metropolitan Area.
- 3 **Water supply system** – A system for the treatment, transmission, storage, and distribution of water
4 from source to consumers (e.g., homes, commercial establishments, industry, irrigation facilities, and
5 public agencies for water).
- 6 **Well advisory** – Notice from MDH that a drinking water supply has exceeded health-based guidance
7 values developed by MDH.
- 8 **Work groups** – Three groups formed by the MPCA and DNR to help identify and recommend priorities
9 and projects to be funded under the Grant: the Government and 3M Working Group, the Citizen-
10 Business Group, and the Drinking Water Supply Technical Subgroup.
- 11

DRAFT

Acronyms and abbreviations

1	Abt	Abt Associates
2	ADD	average daily demand
3	Settlement	2018 Agreement and Order
4	CAD	computer-aided design
5	Conceptual Plan	Conceptual Drinking Water Supply Plan
6	CSM	conceptual site model
7	DNR	Department of Natural Resources
8	EPA	Environmental Protection Agency
9	GAC	granular activated carbon
10	GIS	geographic information system
11	Grant	3M Grant for Water Quality and Sustainability Fund
12	HBV	health-based value
13	HI	health risk index
14	HRL	health risk limit
15	IX	ion exchange
16	LGU	local government unit
17	MCL	maximum contaminant level
18	MDD	maximum daily demand
19	MDH	Minnesota Department of Health
20	MERLA	Minnesota Environmental Response and Liability Act
21	MGD million gallons per day	
22	MGS	Minnesota Geological Survey
23	MPCA	Minnesota Pollution Control Agency
24	NPS	National Park Service
25	O&M	operations and maintenance
26	PFAS	per- and polyfluoroalkyl substances
27	PFBA	perfluorobutanoic acid
28	PFBS	perfluorobutane sulfonate
29	PFHxS	perfluorohexane sulfonate
30	PFOA	perfluorooctanoic acid
31	PFOS	perfluorooctane sulfonate
32	POET	point-of-entry treatment
33	POUT	point-of-use treatment
34	QA/QC	quality assurance/quality control
35	SPRWS	St. Paul Regional Water Services
36	Subgroup 1	Drinking Water Supply Technical Subgroup
37	3M	3M Company
38	2007 Consent Order	2007 Settlement Agreement and Consent Order
39	2018 Settlement	2018 Agreement and Order
40	TCE	trichloroethylene
41	VOC	volatile organic compound
42	Wood	Wood Environment & Infrastructure Solutions, Inc.

Appendix A. Introduction

1 In February 2018, the State of Minnesota and the 3M Company (3M) announced an agreement to settle
2 the State’s Natural Resources Damage lawsuit for per- and polyfluoroalkyl substances (PFAS)
3 contamination in the East Metropolitan Area of the Twin Cities. As part of the settlement, the State of
4 Minnesota and 3M entered into a 2018 Agreement and Order (2018 Settlement or Settlement) that
5 established the 3M Grant for Water Quality and Sustainability Fund (Grant). Under the first and highest
6 priority (Priority 1) of this Agreement, the Minnesota Pollution Control Agency (MPCA) and the
7 Minnesota Department of Natural Resources (DNR) will use the Grant for long-term projects to enhance
8 the quality, quantity, and sustainability of drinking water for residents and businesses affected by PFAS
9 in the East Metropolitan Area. As a step toward addressing Priority 1, the MPCA and DNR have
10 developed this Conceptual Drinking Water Supply Plan (Conceptual Plan) to evaluate and recommend a
11 set of projects that provide clean, sustainable drinking water to the 14 communities currently known to
12 be affected by PFAS contamination in the East Metropolitan Area, now and into the future. The options
13 presented here are based on the totality of evaluating all appropriate and feasible alternatives, and
14 incorporate feedback from the work groups and public outreach. Any of the recommended options
15 would be reasonable and necessary in response to PFAS releases in the East Metro settlement area, and
16 not inconsistent with provisions found in Minn. Stat. 115B, the Minnesota Environmental Response and
17 Liability Act.

18 This chapter provides background information on the Agreement, the overall goals of the planning and
19 implementation effort, an overview of the Conceptual Plan, and information on communication and
20 public involvement.

21 **A.1 Afton**

22 **A.1.1 Community background**


23 Afton, located on the eastern side of the East Metropolitan Area, is a rural city designated as a
24 Diversified Rural community by the Metropolitan Council (2014). According to the city’s Comprehensive
25 Plan (City of Afton, 2015), residents value their rural lifestyle and try to maintain it by regulating low
26 residential housing densities and not implementing a municipal system that will encourage urbanization.
27 In Afton, most lots are a minimum of five acres, with many being substantially larger, and many being
28 located among large agricultural properties and wooded ravines. On many of these large lots, the homes
29 are set back 400 feet or more from the public road. Afton currently has no municipal water system, with
30 residents and businesses in the community on private wells. While a small percentage of Afton is
31 designated for industrial uses, the primary land uses are agricultural and rural residential. The
32 community is anticipated to have a population of 3,070 in the year 2020, and a population of 3,140 in
33 the year 2040 (Metropolitan Council, 2015a).

34 According the Minnesota Well Index (MWI), Afton has an estimated 708 non-municipal wells. However,
35 discussions with Afton and manual counts of parcels has indicated that there are approximately 1,1195
36 wells. Based on the available PFAS sampling data to date, the northern border of Afton, adjacent to
37 West Lakeland, is the only area of the community with PFAS levels that exceed the Minnesota
38 Department of Health (MDH) Health Index (HI) of 1 (Figure A.1). The remaining areas of the community
39 that have been sampled to date have detectable levels of PFAS but do not exceed the HI of 1.

1 **A.1.2 Current and proposed projects**

2 As shown in Figure A.1, Afton has several non-municipal wells along its northern border with West
3 Lakeland that exceed the HI of 1. To date, granular activated carbon (GAC) point-of-entry treatment
4 (POET) systems have been provided for these individual residences that have received well advisories.
5 The City has expressed their intention to continue providing such systems as residents receive well
6 advisories.

7 **Figure A-1. HI levels at sampled non-municipal wells in Afton.**



8
9

1 A.2 Cottage Grove

2 A.2.1 Community background

3 Cottage Grove, located on the southwestern side of the East Metropolitan Area, is designated as a
4 Suburban Edge community by the Metropolitan Council (2014). The community is bordered by the
5 Mississippi River to the south; Denmark Township to the east; Woodbury to the north; and Grey Cloud
6 Island, St. Paul Park, and Newport to the west. Local PFAS sources contributing to groundwater
7 contamination include the 3M Cottage Grove Disposal Site along the southern border of the community
8 and the Woodbury Disposal Site on its northern border. Table A.1 summarizes Cottage Grove’s 2020 and
9 2040 population, average daily demand, and maximum daily demand.

10 **Table A.1. Cottage Grove population and demand projections.** Source: City of Cottage Grove, 2018.

	2020	2040
Total projected population	38,400	47,000
Projected population served	38,400	47,000
Average daily demand in gpm (mgd)	2,667 (3.84)	3,264 (4.7)
Maximum daily demand in gpm (mgd)	8,000 (11.52)	9,792 (14.1)

11 gpm = gallons per minute, mgd = million gallons per day.

12
13 Cottage Grove has a municipal water system as well as residences on private wells. Cottage Grove’s
14 municipal water system has 12 municipal supply wells (Table A.2) to meet the city’s water demands. All
15 wells receive chemical treatment with fluoride and chlorine. To date, 8 out of the city’s 12 municipal
16 supply wells have PFAS levels that exceed the HI of 1 (Table A.2). Of the PFAS-impacted wells, Wells 2
17 and 4 have been taken offline, Well 7 is offline but used for blending if needed, and Wells 3 and 10
18 receive GAC treatment and are in use. However, the GAC water treatment plants (WTPs) at Wells 3 and
19 10 are interim treatment solutions and are not long-term options.

20 Cottage Grove currently faces operational challenges as the PFAS contamination levels in their
21 untreated wells continue to fluctuate. With each quarterly sampling, the city updates their standard
22 water supply operations to account for changes in the HI. High fluctuations in PFAS concentrations for
23 the city’s municipal supply wells require revisions to operations and can directly impact available supply
24 to meet peak water demands. Operational information provided by the city in February 2019 indicates
25 that Cottage Grove can meet its current demand by operating the WTPs at Wells 3 and 10; and a
26 combination of Wells 1, 5, 6, 8, 9, 11, and 12. If Well 7 is included for blending purposes, these wells can
27 provide a total flow 12,400 gpm (17.86 mgd).

28 The groundwater source firm capacity for a municipal water system, defined by the 2012 Recommended
29 Standards for Water Works, as “the total developed groundwater source capacity, unless otherwise
30 specified by the reviewing authority, that shall equal or exceed the design maximum day demand with
31 the largest producing well out of service” (Health Research, 2012, p. 18). However, the city considers
32 their firm capacity as two wells being out of service due to a seven-year well maintenance schedule.
33 Additionally, the city must review their firm supply capacity in relation to the three pressure zones and
34 raw water blending in the Intermediate Pressure Zone. Under this assumption and assuming the two
35 largest operating wells are out-of-service, the firm capacity of the system would be 8,900 gpm (12.8
36 mgd). However, according to Cottage Grove, Wells 1 and 2 are not anticipated to be long-term water

1 supply options due to their age, condition, lower capacity, and distance from the other wells; and the
 2 high HI for Well 2. Therefore, the city anticipates replacement of these municipal supply well(s) in the
 3 Low-Pressure Zone for future supply.

4 **Table A.2. Cottage Grove supply well summary.**

Well no.	Unique well no.	Design capacity (gpm)	Aquifer	HI value	Status
1	208808	600	Prairie du Chien-Jordan	0.545	In use
2	208809	600	Prairie du Chien-Jordan	2.342	Offline
3	208807	800	Prairie du Chien-Jordan	2.49	In use ^a
4	208805	1,000	Prairie du Chien-Jordan	3.047	Offline
5	208806	1,000	Prairie du Chien-Jordan	1.204	In use
6	201238	1,000	Prairie du Chien-Jordan	1.97	In use
7	201227	1,000	Prairie du Chien-Jordan	1.064	Offline ^b
8	110464	1,500	Prairie du Chien-Jordan	1.404	In use
9	165602	1,500	Prairie du Chien-Jordan	0.905	In use
10	191904	2,000	Prairie du Chien-Jordan	2.913	In use ^a
11	655944	1,500	Prairie du Chien-Jordan	0.249	In use
12	830682	1,500	Prairie du Chien-Jordan	0.01	In use
Total capacity		14,000 gpm (20.2 mgd)			
Total available capacity ^c		12,400 gpm (17.86 mgd)			
Firm capacity ^d		8,900 gpm (12.82 mgd)			

5 Notes:

6 Green indicates wells that have a HI greater than 1.

7 a. Well is receiving GAC treatment and is in operation.

8 b. Used for blending if needed.

9 c. Excludes wells that are offline and/or have a HI greater than 1 and are not used for blending.

10 d. As defined by the community’s Standard Operating Procedures (SOPs) and this appendix.

11
 12 Under these assumptions, Cottage Grove has sufficient water supply to meet the anticipated 2020
 13 maximum daily demands of 11.5 mgd, if the active municipal supply wells maintain an HI value less than
 14 1. However, the city would need an additional well to meet their 2040 maximum daily demands of
 15 14.1 mgd.

16 The City of Cottage Grove owns and operates their municipal water system, which consists of six water
 17 storage tanks and two booster pump stations, and operates across three pressure zones. Wells are
 18 operated to maintain set water levels in the water storage towers/tanks. The city has one interconnect
 19 with St. Paul Park, which is not active under normal operating conditions. As such, this interconnect
 20 needs to undergo a condition assessment to determine its capacity and operational condition. It is
 21 estimated that the existing interconnect has a capacity of 400–500 gpm, but this needs to be verified.

22 According to the city, the majority of Cottage Grove is served by the city’s municipal water system. The
 23 city is still experiencing growth and is expanding their municipal water system to both new and existing
 24 developments. Cottage Grove has an estimated 820 non-municipal wells, mostly in the southern,

1 eastern, and western extents of the city. According to available data from PFAS sampling to date, many
2 of the non-municipal wells in Cottage Grove exceed the HI of 1 (Figure A.2). Treatment has been
3 provided for the individual residences that have received well advisories.

4 **A.2.2 Current and proposed projects**


5 Cottage Grove implemented GAC WTPs at Wells 3 and 10 in 2017. However, the WTP at Well 10 was
6 intended to be an interim solution for five years as it is partially located on adjacent lands, which
7 required easements for construction. There is no room for expansion and the GAC vessels are being
8 rented from Carbonair, which is a not a viable long-term solution.

9 Cottage Grove is currently working with their consulting engineers and the Minnesota Pollution Control
10 Agency (MPCA) on a pilot study to establish ion exchange (IX) as an approved alternative for PFAS
11 treatment. Cottage Grove also submitted two expedited projects (Applications 100013 and 100014) that
12 proposed to connect two subdivisions currently on private wells to the city's municipal water system.
13 The City has expressed their intention to continue expanding upon the existing centralized treatment
14 system. The city is also currently in the process of implementing a temporary treatment system at an
15 existing well which was accepted by the Co-Trustees as an interim measure to address additional well
16 exceedances as well as the demand challenges the city is facing due to PFAS contamination.

17

DRAFT

1 Figure A-2. HI levels at sampled non-municipal wells in Cottage Grove. The 3M source areas are
2 outlined in red.



3
4

1 **A.3 Denmark**

2 **A.3.1 Community background**

3 Denmark, located on the southeastern side of the East Metropolitan Area, is a rural township designated
4 as a Diversified Rural community by the Metropolitan Council (2014). According to the community's
5 Comprehensive Plan (Denmark Township, 2019), residents value their rural lifestyle and try to maintain
6 it by regulating low residential housing densities and not implementing public facilities that will
7 encourage urbanization, though the community is growing. Denmark has no municipal water system,
8 with residents and businesses in the community on private wells. The largest land use in Denmark is
9 agricultural, accounting for 54% of the total existing land use in 2016, with only 6% for residential,
10 single-family use (Denmark Township, 2019). The community is anticipated to have a population of
11 1,920 in the year 2020, and a population of 2,410 in the year 2040 (Metropolitan Council, 2015c).


12 According to the MWI, Denmark has an estimated 487 non-municipal wells; however, conversations with
13 Denmark and manual counts have indicated there is approximately 761 wells. According to available
14 PFAS sampling data to date, one well in the community had PFAS levels that exceeded the HI of 1 (Figure
15 A.3). However, according to MDH, this well was located on a farm that was sampled just before being
16 sealed; therefore, no well advisory was issued for the well. The remaining areas of the community that
17 have been sampled to date have detectable levels of PFAS but do not exceed the HI of 1.

18 **A.3.2 Current and proposed projects**

19 As shown in Figure A.3, Denmark has little PFAS contamination based on data available to date. As a
20 result, the community has not implemented any projects to address the PFAS contamination. Denmark
21 has expressed that it is their intention to provide GAC POET systems to residents that receive well
22 advisories.

23

1 Figure A-3. HI levels at sampled non-municipal wells in Denmark.



2

1 **A.4 Grey Cloud Island**

2 **A.4.1 Community background**


3 Grey Cloud Island, located on the southwestern side of the East Metropolitan Area, is a small,
4 rural township designated as a Diversified Rural community by the Metropolitan Council (2014).
5 The community is bordered by the Mississippi River, with St. Paul Park to the north and Cottage
6 Grove to the east. According to the community's Comprehensive Plan (Grey Cloud Island
7 Township, 2018), residents value their rural lifestyle, which they try to maintain by regulating
8 low residential housing densities and not implementing public facilities that will encourage
9 urbanization. Grey Cloud Island has no municipal water system, with residents and businesses
10 in the community on private wells. Most homes in the community were built in the 1940s and
11 1950s. The community is anticipated to have a population of 300 in the year 2020, and a
12 population of 270 in the year 2040 (Metropolitan Council, 2015d).

13 According to available data from PFAS sampling to date, Grey Cloud Island has detectable levels of PFAS
14 in the majority of their estimated 121 non-municipal wells, and PFAS exceeding the HI of 1 in many of
15 them (Figure A.4). Depending on the date of installations, private wells in Grey Cloud Island range from
16 shallow to deep wells, and the data suggest that PFAS-contaminated wells are in the shallower aquifers.

17 **A.4.2 Current and proposed projects**

18 As shown in Figure A.4, Grey Cloud Island has several non-municipal wells that exceed the HI of 1.
19 Bottled water and/or GAC POET systems have been provided for these individual residences that have
20 received well advisories. The community has expressed an interest in exploring various options to
21 address PFAS contamination including GAC POET systems and implementing a distribution system to
22 receive water from neighboring municipal water systems.

1 Figure A-4. HI levels at sampled non-municipal wells in Grey Cloud Island. The 3M source area is
2 outlined in red.



3
4

1 A.5 Lake Elmo

2 A.5.1 Community background

3 Lake Elmo, located on the northern side of the East Metropolitan Area, is designated as both an
 4 Emerging Suburban Edge and Rural Residential community by the Metropolitan Council (2014). Lake
 5 Elmo is bordered by Woodbury to the south, Oakdale to the west, and West Lakeland to the east. The
 6 community, traditionally rural with large residential lots, originally did not intend to have a municipal
 7 water system, with the exception of the Old Village area and the Eagle Point Business Park. This
 8 changed, however, after 2006 when sampling indicated that PFAS contamination was impacting the
 9 southern two-thirds of the city, areas generally south of the Washington County Landfill. The
 10 Washington County Landfill and the Oakdale Disposal Site were previous disposal sites for 3M and a
 11 source of PFAS contamination to Lake Elmo. Sampling efforts have been ongoing and have focused on
 12 the southern two-thirds of the city where perfluorooctanoic acid (PFOA) and perfluorooctane sulfonate
 13 (PFOS) levels have exceeded health standards. The northern part of Lake Elmo is believed to be
 14 upgradient of the contamination, where only slight levels of perfluorobutanoic acid (PFBA) have been
 15 found, similar to levels found throughout much of the Twin City’s Metropolitan Area. Table A.3
 16 summarizes Lake Elmo’s 2020 and 2040 population, average daily demand, and maximum daily demand.

17 **Table A.3. Lake Elmo population and demand projections.** Source: City of Lake Elmo, 2019.

	2020	2040
Total projected population	11,020	22,304
Projected population served	7,302	21,165
Average daily demand gpm (mgd)	532 (0.77)	1,597 (2.3)
Maximum daily demand gpm (mgd)	1,597 (2.3)	4,325 (6.1)

18
 19 Lake Elmo has a municipal water system as well as residences on private wells. Currently, the Lake Elmo
 20 municipal water system has two municipal supply wells in use and a third being installed (Well 5; Table
 21 A.4) to meet the city’s water demands. At this time, Well 1 has exceeded the HI of 1 and has been
 22 removed from operation. In addition, Well 1 is a multi-aquifer well that the Department of Natural
 23 Resources (DNR) and MDH have requested to be sealed. Lake Elmo’s Well 4 falls within a 5-mile radius
 24 of White Bear Lake, which has legally impacted the city’s appropriation permits. Well 3 was drilled but
 25 never equipped or used due to contamination issues.

26 **Table A.4. Lake Elmo supply well summary.**

Well no.	Unique well no.	Capacity (gpm)	Aquifer	HI value	Status
1	208448	500	Jordan and Mt. Simons	1.3736	Offline – sealed
2	603085	1,000	Prairie du Chien-Jordan	0.012	In use
4	767874	1,250	Jordan	0.011	In use
5		1,250	Jordan		Being installed
Total capacity ^a		2,250 gpm (3.24 mgd)			
Firm capacity ^{a, b}		1,000 gpm (1.44 mgd)			

Well no.	Unique well no.	Capacity (gpm)	Aquifer	HI value	Status
Total capacity ^c		3,500 gpm (5.0 mgd)			
Firm capacity ^{b, c}		2,250 gpm (3.24 mgd)			

1 Notes:

2 a. Excluding Well 5.

3 b. With the largest pump out of service.

4 c. Including Well 5.

5

6 Based on the capacities in Table A.4, Lake Elmo does not have sufficient firm capacity to supply the
7 maximum daily demands for 2020 or 2040. However, once Well 5 is in operation, there will be sufficient
8 firm capacity to meet current 2020 maximum daily demands, but the city will need to drill additional
9 wells to provide firm capacity that will meet 2040 maximum daily demands. The third additional well is
10 anticipated to be installed before 2040; however, the location of any new wells will be a challenge due
11 to PFAS contamination in the southern two-thirds of the community, as well as the designation of, and
12 requirements for, a Special Well and Boring Construction Area. In addition, new wells located in the
13 northern one-third of the city could have potential impacts on White Bear Lake, which would need to be
14 considered.

15 For Lake Elmo’s municipal water system, it was not until recently that the northern and southern
16 portions of the community were interconnected by a series of water mains. Now, Lake Elmo has three
17 water storage tanks (Water Tower 1 will likely be replaced in the future when a third well is placed into
18 operation), and operates across four pressure zones with an installed booster pump on Inwood Avenue
19 to serve the southern region. The city previously had two interconnects of 600 gpm (Hudson Boulevard)
20 and 1,400 gpm (Ideal Avenue and Lake Jane Trail North) with Oakdale, but they are no longer active
21 under normal operating conditions. The Hudson Boulevard interconnect is near the southwest corner of
22 the city and the Ideal Avenue interconnect is near the central part of the city on the western border.

23 As of 2016, about 49% of Lake Elmo was being served by the city’s municipal water system. Currently,
24 the city is still experiencing growth and is expanding their municipal water system to both new and
25 existing developments. According to available data from PFAS sampling to date, a considerable number
26 of non-municipal wells exceed the HI of 1 (Figure A.5). GAC treatment has been provided for the
27 individual residences that have received well advisories.

28 **A.5.2 Current and proposed projects**


29 In January 2019, Lake Elmo hired Bolton & Menk to perform the “Lake Elmo Well No. 1 Advisory Study
30 Related to PFC Contaminated Jordan Aquifer,” in which six alternatives were evaluated to address the
31 contamination from Well 1. The study found that drilling a new well (Well 5) and abandoning/sealing
32 Well 1 was the best solution.

33 Lake Elmo also submitted four expedited projects (Applications 100007, 100008, 100009, and 100011)
34 to connect residences currently on private wells to the city’s municipal water system. Three of the
35 projects were approved by the Co-Trustees, and include extending water mains to:

- 36 • Stonegate
- 37 • Hamlet on Sunfish Lake
- 38 • 31st Street and Stillwater Boulevard Extension.

1 The city also plans on installing a 1 million gallon water storage tank (Tank 3) to help them meet
2 increasing water demands and meet storage requirements. The city has expressed their
3 intention to continue operating and expanding upon their existing system by installing wells in
4 the northeast where treatment would not be required. However, various options will need to
5 be considered to protect water levels in White Bear Lake.

6 **Figure A-5. HI levels at sampled non-municipal wells in Lake Elmo. The 3M source area is outlined in**
7 **red.**



8
9

1 **A.6 Lakeland and Lakeland Shores**

2 **A.6.1 Community background**

3 Lakeland and Lakeland Shores, located on the eastern side of the East Metropolitan Area, are designated
 4 as Rural Residential communities by the Metropolitan Council (2014). The community is bordered by the
 5 St. Croix River, with West Lakeland and Afton to the west. Table A.5 summarizes Lakeland’s 2020 and
 6 2040 population, average daily demand, and maximum daily demand. The population and demand
 7 numbers include Lakeland Shores and Lake St. Croix Beach that are served by Lakeland’s municipal
 8 water system.

9 **Table A.5. Lakeland, Lakeland Shores, and Lake St. Croix Beach population and demand projections.**

10 Source: City of Lakeland, 2017.

	2020	2040
Total projected population	3,110	3,710
Projected population served	2,587	3,710
Average daily demand gpm (mgd)	174 (0.25)	250 (0.36)
Maximum daily demand gpm (mgd)	521 (0.75)	750 (1.08)

11
 12 Lakeland has a municipal water system that serves a large fraction of the community, and also serves
 13 Lakeland Shores and Lake St. Croix Beach. Lakeland’s municipal water system has two municipal supply
 14 wells in the Mt. Simon aquifer to meet the city’s water demands (Table A.6). With existing firm capacity,
 15 Lakeland is able to meet current and future 2040 demands with one well out of service. At this time,
 16 neither well has exceeded the HI of 1. However, each well has a pressure filtration system consisting of
 17 GAC that is coated with permanganate to remove the high levels of iron and manganese found in these
 18 communities’ groundwater.

19 **Table A.6. Lakeland supply well summary.**

Well no.	Unique well no.	Design capacity (gpm)	Aquifer	HI value	Status
1	420985	750	Mt. Simon	0.0009	In use
2	533517	750	Mt. Simon	0.0008	In use
Total capacity		1,500 gpm (2.16 mgd)			
Firm capacity		750 gpm (1.08 mgd)			

20
 21 For Lakeland’s municipal water system, two water storage tanks operate across one pressure zone, and
 22 an installed fire booster pump serves the northern region. The city does not currently have any
 23 interconnects. Lakeland is also bordered by a bluff on the western edge of the city that is approximately
 24 120-foot tall, which should be considered when analyzing supplying water options to neighboring
 25 communities.


26 Lakeland’s service area is essentially built-out, with the majority (80%) of the population being served by
 27 the city’s municipal water system. Based on a MDH estimate for 2015, an estimated 296 homes in
 28 Lakeland proper are on non-municipal wells. However, in discussions with the city, this is likely a

1 discrepancy with the MWI data or some of the residences may have kept their wells for irrigation
2 purposes. This would need to be field verified. According to the city, an estimated 30 residences with
3 non-municipal wells were connected to the city’s municipal water system in 2018, and additional
4 residences are expected to connect to Lakeland’s system each year. The city previously received a grant
5 for TCE contamination impacting residential wells, and residents were allowed to keep their wells if they
6 connected to city water. According to the city, residents are using their wells only for irrigation, but an
7 inventory of the wells currently used for irrigation purposes has not been completed.

8 **A.6.2 Current and proposed projects**

9 Since Lakeland’s municipal supply wells do not exceed the HI of 1, they do not have any current projects
10 in place to address PFAS contamination. However, according to available data from PFAS sampling to
11 date, some residences on non-municipal wells have exceeded the HI of 1 (Figure A.6). Treatment has
12 been provided for individual residences that have received well advisories, however, the City has
13 expressed their intent to continue to connect residents on private wells to the municipal system.

14 **Figure A-6. HI levels at sampled non-municipal wells in Lakeland and Lakeland Shores.**



15
16

1 **A.7 Maplewood**

2 **A.7.1 Community background**


3 Maplewood, located on the northwestern side of the East Metropolitan Area, is designated as an Urban
4 community by the Metropolitan Council (2014). The community, primarily supplied by the private utility
5 provider St. Paul Regional Water Services (SPRWS), utilizes a series of surface water bodies (primarily
6 the Mississippi River and a series of lakes) as their source water. Maplewood has an anticipated 2020
7 population of 42,200 people and a 2040 population of 48,600 people (Metropolitan Council, 2015b).
8 According to the city, approximately 98% of residents are served by SPRWS. However, some residences
9 are on private wells throughout the community, particularly in the southern portion. According to
10 available data from PFAS sampling to date, some of these private wells have exceeded the HI of 1
11 (Figure A.7).

12 **A.7.2 Current and proposed projects**

13 As shown in Figure A.7, Maplewood has some non-municipal wells that exceed the HI of 1. GAC
14 treatment has been provided for these individual residences that have received well advisories.
15 Additional options include extending SPRWS lines or extending other nearby municipal service lines to
16 the impacted residences.

DRAFT

1 Figure A-7. HI levels at sampled non-municipal wells in Maplewood.



2
3

1 A.8 Newport

2 A.8.1 Community background

3 Newport, located on the southwestern side of the East Metropolitan Area, is designated as an Urban
4 community by the Metropolitan Council (2014). The community is bordered by the Mississippi River
5 with Cottage Grove and Woodbury to the east, Maplewood and St. Paul to the north, and St. Paul Park
6 to the south. Table A.7 summarizes Newport’s 2020 and 2040 population, average daily demand, and
7 maximum daily demand.

8 **Table A.7. Newport population and demand projections.** Source: City of Newport, 2016.

	2020	2040
Total projected population	4,400	4,939
Projected population served	4,087	4,587
Average daily demand gpm (mgd)	233 (0.34)	261 (0.38)
Maximum daily demand gpm (mgd)	362 (0.52)	406 (0.58)

9
10 The majority of the community is currently served by the city’s municipal water system, with the
11 exception of a few private residences and neighborhoods. Newport’s municipal water system has two
12 municipals wells in the Jordan aquifer to meet the city’s water demands (Table A.8). Wells 1 and 2 have
13 a capacity of 1,000 gpm and 800 gpm, respectively, for a combined capacity of approximately 2.6 mgd
14 and a firm capacity of 1.15 mgd, with the largest pump out of service. The anticipated maximum daily
15 demand is 0.52 mgd for 2020 and 0.585 mgd for 2040, indicating the current wells have sufficient
16 capacity to meet current and future demands. At this time, neither municipal supply well has exceeded
17 the HI of 1.

18 **Table A.8. Newport supply well summary.**

Well no.	Unique well no.	Design capacity (gpm)	Aquifer	HI value	Status
1	208353	1,000	Jordan	0.0396	In use
2	225904	800	Jordan	0.0671	In use
Total capacity		1,800 gpm (2.6 mgd)			
Firm capacity		800 gpm (1.15 mgd)			

19
20 Newport’s municipal water system has two water storage reservoirs and one recently installed
21 standpipe, and operates across three pressure zones. The city has a large topography range of
22 approximately 300 feet, which generally slopes down toward the Mississippi River. In addition, Newport
23 is currently constructing two duplex booster pump stations. While the city does not have any
24 interconnects to neighboring communities’ municipal water systems, Newport has agreements with
25 Woodbury and Cottage Grove to provide municipal utilities, and with SPRWS for water system
26 emergency repair. Currently, Newport is providing water to a few private residences in Woodbury and
27 has a packaging plant in the southeast corner that is receiving water from Cottage Grove. In addition,
28 the Xcel Energy and the Recycling and Energy facilities are currently being supplied water by SPRWS
29 through southeastern St. Paul’s distribution system located just north of Newport.

1 The majority of the population (90%) is currently served by the city’s municipal water system with the
2 exception of a few remote private residences and neighborhoods. The city estimates there are about 50
3 to 60 homes remaining on non-municipal wells and MWI shows 113. Based on PFAS sampling to date, no
4 non-municipal wells have exceeded the HI of 1 (Figure A.8).


5

6 **A.8.2 Current and proposed projects**

7 Since Newport’s municipal supply wells and non-municipal wells do not exceed the HI of 1, the city does
8 not have any current projects in place to address PFAS contamination. However, the city has concerns
9 about future contamination if the PFAS migrates from upgradient and/or higher stratigraphy aquifers, as
10 there are non-municipal wells with HI values above 1 to the south, southeast, and north of Newport
11 (Figure A.9). There is also the concern that new, high-capacity, municipal supply wells installed in
12 neighboring communities will impact the flow path of PFAS, possibly resulting in PFAS contamination of
13 Newport’s municipal supply wells. The City has expressed interest in various options to address PFAS
14 contamination including provided GAC POET systems, connecting homes to the municipal system, and
15 establishing and interconnect with a neighboring community.

DRAFT

1 Figure A-8. HI levels at sampled non-municipal wells in Newport.



2
3

1 A.9 Oakdale

2 A.9.1 Community background

3 Oakdale, located on the northern side of the East Metropolitan Area, is designated as a Suburban
 4 community by the Metropolitan Council (2014). The Oakdale Disposal Site is located near the
 5 intersection of 34th Street and Hadley Avenue, a known source of PFAS contamination to the
 6 community. Table A.9 summarizes Oakdale’s 2020 and 2040 population, average daily demand, and
 7 maximum daily demand.

8 **Table A.9. Oakdale population and demand projections.** Source: City of Oakdale, 2019.

	2020	2040
Total projected population	28,500	36,000
Projected population served	30,360 ^a	36,740 ^a
Average daily demand gpm (mgd)	1,743 (2.51)	2,125 (3.06)
Maximum daily demand gpm (mgd)	3,986 (5.74)	4,861 (7)

9 Note:

10 a. Includes landfall population served.

11
 12 The majority of the community is currently served by the city’s municipal water system, with the
 13 exception of some private residences and neighborhoods. Oakdale’s municipal water system has nine
 14 municipal supply wells to meet the city’s water demands. Currently Wells 5 and 9 are receiving GAC
 15 treatment for PFAS; and Wells 1, 2, 7, and 8 were found to exceed the HI of 1. Currently, the city relies
 16 primarily on Wells 5 and 9, with water also being supplied from Wells 3 and 10. Water from the four
 17 affected wells were previously blended with water from the other four wells in operation in the
 18 distribution system. Well 6, Oakdale’s largest-producing well, has been taken out of service due to high
 19 iron and manganese levels. In addition to the municipal supply wells, an estimated 124 homes are on
 20 non-municipal wells. According to available data from PFAS sampling to date, XX of the non-municipal
 21 wells also exceed the HI of 1 (Figure A.10). Treatment or a municipal supply connection has been
 22 provided for the individual residences that have received well advisories.

23

24 **Table A.10. Oakdale supply well summary.**

Well no.	Unique well no.	Capacity (gpm)	Aquifer	HI value	Status	Treatment
1	208462	925	Jordan	9.0946	Offline	
2	208463	950	Jordan	6.0969	Offline	
3	208454	1,000	Jordan	0.0142	In use	
5	127287	925	Jordan	56.8379	In use	GAC
6	151575	1,650	Jordan	0	Offline	
7	463534	1,000	Jordan	42.1890	Offline	
8	572608	1,000	Jordan	21.1920	Offline	
9	611059	1,500	Jordan	45.9535	In use	GAC

10	773389	1,000	Jordan	0.0055	In use
Total capacity ^a		4,425 gpm (6.37 mgd)			
Firm capacity ^b		2,925 gpm (4.21 mgd)			

1 Notes:

2 Green indicates wells that have a HI value greater than 1.

3 a. Total capacity of wells with HI < 1.

4 b. With largest pump out of service.


5 Based on the capacities in Table A.10, Oakdale has sufficient water supply to meet the anticipated 2020
6 maximum daily demands of 5.74 mgd as long as the active municipal supply wells maintain a HI value
7 less than 1. However, the city would need an additional well that doesn't require treatment, provide
8 treatment to their existing wells that are currently out of use, or develop a centralized well field and
9 expand their existing WTP to meet their 2040 maximum daily demands of 7 mgd.

10 For Oakdale's municipal water system, the city has four water storage towers and operates across
11 three pressure zones with elevations ranging up to 175 feet. Oakdale supplies water to the city of
12 Landfall. While Oakdale has two interconnects with Lake Elmo and one with Woodbury, the
13 interconnects are not active under normal operations. According to the city, almost all residences are
14 connected to the municipal water system with the exception of neighborhoods in the northeastern and
15 central regions. According to available data from PFAS sampling to date, a number of the non-municipal
16 wells exceed the HI of 1. Treatment has been provided for individual residences that have received well
17 advisories (Figure A.10).

18 **A.9.2 Current and proposed projects**

19 Oakdale submitted one expedited project (Application 100010) to evaluate two options that address the
20 impacted municipal supply wells. The first option is to add treatment at each of the municipal supply
21 well sites, and the second option is to develop a centralized well field and expand the existing WTP at
22 the Public Works Facility. The City's intention is to further develop and expand their current municipal
23 treatment and distribution system to address PFAS contamination.

1 Figure A-9. HI levels at sampled non-municipal wells in Oakdale. The 3M source areas are outlined in
2 red.



3
4

1 **A.10 Prairie Island Indian Community**

2 **A.10.1 Community background**

3 The Prairie Island Indian Community (PIIC), which is located in Goodhue County, Minnesota, owns
4 111 acres of undeveloped land in West Lakeland Township on the northeast corner of Manning Avenue
5 and I-94. The property in West Lakeland Township is intended to be a housing development. PIIC has
6 submitted an initial site plan indicating a proposed 71 residential lots and 11.67 acres for commercial
7 development. One existing irrigation well on the property has a 12-inch casing pipe and a capacity of
8 1,000 gpm (1.44 mgd).

9 According to available data from PFAS sampling to date, the irrigation well on PIIC exceeds the HI of 1
10 (Figure A.11); this well is not currently in use.


11 **A.10.2 Current and proposed projects**

12 As the irrigation well is not currently in use and the property has not been developed, PIIC does not have
13 any current projects in place to address the PFAS contamination.

14 PIIC submitted an expedited project (Application 100019) to investigate the feasibility of converting the
15 private irrigation well in PIIC to a municipal supply well.

16 PIIC has also expressed interest in provided water to West Lakeland, should a distribution system for
17 West Lakeland by further evaluated.

18 **Figure A-10. HI levels at sampled non-municipal wells in PIIC. The border of the PIIC is outlined in black**
19 **in the lower left-hand corner.**



20

21

1 **A.11 St. Paul Park**

2 **A.11.1 Community background**

3 St. Paul Park, located on the southwestern side of the East Metropolitan Area, is designated as an
 4 Emerging Suburban Edge community by the Metropolitan Council (2014). The community is bordered by
 5 the Mississippi River with Cottage Grove to the east, Newport to the north, and Grey Cloud Island to the
 6 south. The city is home to the Marathon Petroleum Corporation refinery in the north-western region,
 7 and is split by the Burlington Northern Santa Fe Railroad that owns approximately 100 acres in the
 8 southern region. Table A.11 summarizes St. Paul Park’s 2020 and 2040 population, average daily
 9 demand, and maximum daily.

10 **Table A.11. St. Paul Park population and demand projections. Source: City of St. Paul Park, 2018.**

	2020	2040
Total projected population	6,000	7,900
Projected population served	6,000	7,900
Average daily demand gpm (mgd)	438 (0.63)	576 (0.83)
Maximum daily demand gpm (mgd)	897 (1.29)	1,181 (1.70)

11
 12 The majority of the community is currently served by the city’s municipal water system, with the
 13 exception of some private residences in the central and western portions of St. Paul Park. St. Paul Park’s
 14 municipal water system consists of three municipal supply wells (Table A.12) to meet the city’s water
 15 demands. To date, Wells 3 and 4 have had PFAS concentrations exceeding the HI of 1 (Table A.12). As a
 16 result, the city relies primarily on Well 2, with minimal water being supplied from Wells 3 and 4.
 17 Currently all three wells are needed to meet maximum daily demands in 2020; water from the two
 18 affected wells were previously blended with water from Well 2 in the distribution system. However, the
 19 city is currently constructing a temporary WTP to treat groundwater supplied by Wells 3 and 4. In
 20 addition to the municipal supply wells, an estimated 49 homes are on non-municipal wells. According to
 21 available data from PFAS sampling to date, 16 of the non-municipal wells also exceed the HI of 1 (Figure
 22 A.12). Treatment has been provided for the individual residences that have received well advisories.

23 For St. Paul Park’s municipal water system, the city has two water storage towers that operate across
 24 one pressure zone. The city has an interconnect with Cottage Grove but it is not active under normal
 25 operating conditions. As such, this interconnect needs to undergo a condition assessment to determine
 26 its capacity and operational condition. It is estimated that the existing interconnect has a capacity of
 27 350 gpm, but this should be verified.

28 **Table A.12. St. Paul Park supply well summary.**


Well no.	Unique well no.	Design capacity (gpm)	Aquifer	HI value	Status
2	208418	600	Prairie du Chien-Jordan	0.7	In use
3	208804	600	Jordan	1.2745	In use ^a
4	431603	900	Jordan	1.1634	In use ^a
Total capacity		2,100 gpm (3.0 mgd)			

Well no.	Unique well no.	Design capacity (gpm)	Aquifer	HI value	Status
Total available capacity ^b		2,100 gpm (3.0 mgd)			
Firm capacity ^c		1,200 gpm (1.73 mgd)			


- 1 Notes:
- 2 Green indicates wells that have a HI greater than 1.
- 3 a. Used for blending if needed.
- 4 b. Excludes wells that are offline and/or have a HI greater than 1 and not used for blending.
- 5 c. As defined by the community’s SOPs and this appendix.

6 **A.11.2 Current and proposed projects**

7 Recently St. Paul Park conducted a “Water Supply and Treatment Options for PFAS Feasibility Study” to
8 determine a short-term solution to the PFAS contamination. The feasibility study looked at several
9 options, including purchasing water from SPRWS; drilling new, deeper wells; and installing a new
10 groundwater WTP. The study results indicated that the groundwater WTP was the best option. Since
11 then, the city has requested funding for and started a project to install a temporary GAC WTP near Well
12 3 that is covered by the 2007 Consent Order. The GAC WTP will be similar to the Oakdale facility and
13 have eight, 10-foot-diameter vessels to treat water from Wells 3 and 4, with the intent to serve Well 2 at
14 a future date.



1 Figure A-11. HI levels at sampled non-municipal wells in St. Paul Park. The 3M source area is outlined
2 in red.



3
4

1 **A.12 West Lakeland**

2 **A.12.1 Community background**

3 West Lakeland, located on the northeastern side of the East Metropolitan Area, is a township
4 designated as a Rural Residential community by the Metropolitan Council (2014). The community is
5 bordered by Lake Elmo to the west and Lakeland to the east. According to the community's
6 Comprehensive Plan (West Lakeland Township, 2019), residents value their rural lifestyle and try to
7 maintain it by regulating low residential housing densities and not implementing public facilities that will
8 encourage urbanization, though the community is growing. West Lakeland has no municipal water
9 system, with residents and businesses in the community on private wells. A few large-volume water
10 users within the community have DNR-regulated wells; however, the community is primarily residential.
11 Approximately 1,340 non-municipal wells are in the township. In 2020, the community is anticipated to
12 be "built-out" at a population of 4,500 (West Lakeland Township, 2019).

13 West Lakeland has been faced with contamination issues from PFAS as well as trichloroethylene (TCE).
14 The northern portion of the community has TCE groundwater contamination from the Baytown
15 Township National Priorities List Site. As a result of the TCE contamination, the city passed an ordinance
16 that requires new homes built after April 9, 2002 to have a GAC treatment system provided by the
17 homeowner if the measured groundwater concentration for TCE is above the MDH Health Based Value.
18 Lots platted before that time with measured concentrations of TCE above the Health Based Value were
19 given GAC treatment. MDH has designated the northern part of West Lakeland a Special Well and Boring
20 Construction Area, which places restrictions on new well construction.


21 Recent sampling efforts have indicated that groundwater in the southern portion of the community is
22 contaminated with PFAS (Figure A.13). This area of West Lakeland was most likely impacted from the
23 transport of PFAS from western portions of the East Metropolitan Area via a surface water/stormwater
24 management system known as Project 1007. The MPCA is currently conducting a source assessment and
25 feasibility study of Project 1007, as prescribed in the 2018 Settlement Agreement between 3M and the
26 State.

27 **A.12.2 Current and proposed projects**

28 Within West Lakeland, many homes already have GAC treatment systems installed because of actions
29 taken following the earlier TCE contamination issue. Currently, residences in the southern portion are
30 being provided bottled water until individual GAC treatment systems are installed.

31 Proposed projects include a new distribution system with treatment. This has been proposed as an
32 autonomous option as well as with water treated and supplied by nearby Prairie Island Indian
33 Community.

1 Figure A-12. HI levels at sampled non-municipal wells in West Lakeland.



2
3

DRAFT

1 A.13 Woodbury

2 A.13.1 Community background

3 Woodbury, located on the western side of the East Metropolitan Area, is designated as a Suburban Edge
 4 community by the Metropolitan Council (2014). The city is bordered by Cottage Grove to the south, Lake
 5 Elmo to the north, Afton to the east, and Maplewood and Newport to the west. Local PFAS sources
 6 include the Woodbury Disposal Site on the southeastern border of Woodbury, and the Oakdale Disposal
 7 Site and the Washington County Landfill located north of Woodbury. Table A.13 summarizes
 8 Woodbury's 2020 and 2040 population, average daily demand, and maximum daily demand

9 **Table A.13. Woodbury population and demand projections.** Source: City of Woodbury, 2019.

	2020	2040
Total projected population	72,500	89,630
Projected population served	67,839	88,139
Average daily demand gpm (mgd)	6,111 (8.8)	7,528 (10.84)
Maximum daily demand gpm (mgd)	15,903 (22.9)	19,576 (28.19)

10
 11 The majority of the community is currently served by Woodbury's municipal water system, with the
 12 exception of some residences on private wells, which are primarily in the southern third of the city.
 13 Woodbury's municipal water system has 19 municipals wells (Table A.14) to meet the city's water
 14 demands, which are distributed in 3 well fields. The Tamarack Well Field is the largest well field with 15
 15 wells, the East Well Field has 3 wells, and the South Well Field has 1 well. All future programed wells will
 16 be located in the South Well Field. Woodbury's consultants have done extensive hydraulic modeling of
 17 the city's municipal water system, and provided design and current pumping rates for each well. To
 18 date, five wells have been identified as consistently exceeding the HI of 1, all of which are located in the
 19 Tamarack Well Field. As of June 2019, a sixth well (Well 4) that is directly adjacent to PFAS-impacted
 20 Wells 6 and 7, exceeded the HI of 1. Because of the close proximity of Wells 12 and 14 to the other
 21 contaminated wells in the Tamarack Well Field, there is concern that the increased pumping of wells not
 22 currently exceeding the HI will influence the migration of contaminants to these wells.

23 **Table A.14. Woodbury supply well summary.**

Well no.	Unique well no.	Design capacity (gpm)	Actual capacity ^a (gpm)	Well field	Aquifer	HI value	Status
1	208420	800	725	Tamarack	Jordan	1.4967	Off
2	208422	750	760	Tamarack	Jordan	0.0325	In use
3	208423	1,000	860	Tamarack	Jordan	0.4425	In use ^b
4	208005	1,000	990	Tamarack	Prairie du Chien-Jordan	0.9092	In use ^b
5	150353	1,000	940	Tamarack	Jordan	0.2475	In use ^b
6	151569	1,200	1,150	Tamarack	Jordan	2.5209	Blend
7	433281	1,200	1,350	Tamarack	Jordan	2.3545	Blend
8	509051	1,200	900	Tamarack	Jordan	0.0393	In use
9	463539	1,200	1,050	Tamarack	Jordan	1.5332	Blend
10	541763	1,500	1,305	Tamarack	Jordan	0.0411	In use

Well no.	Unique well no.	Design capacity (gpm)	Actual capacity ^a (gpm)	Well field	Aquifer	HI value	Status
11	563000	1,500	1,150	Tamarack	Jordan	0.1032	In use
12	596646	1,400	1,220	Tamarack	Jordan	0.035	In use
13	593657	1,400	1,530	Tamarack	Jordan	3.3134	Off
14	611094	1,500	1,400	Tamarack	Jordan	0.0364	In use
15	676415	2,000	1,850	East	Jordan	0.0276	In use
16	706811	2,000	1,980	East	Jordan	0.0467	In use
17	759572	1,500	1,500	Tamarack	Jordan	0.2743	In use ^b
18	786210	2,000	2,000	East	Jordan	0.0158	In use
19	805361	2,000	2,000	South	Jordan	0.0286	In use
Total capacity ^c		17,865 gpm (25.7 mgd)					
Firm capacity ^d		15,865 gpm (22.8 mgd)					

1 Notes:

2 Green indicates wells that have a HI value greater than 1.

3 a. From Bolton & Menk's Water Supply, Storage, and Distribution Plan for the City of Woodbury (2019).

4 b. Well runs to blend water with wells that have a HI greater than 1.

5 c. The total capacity only considers the capacity of wells with a HI less than 1.

6 d. With the largest well (2,000 gpm) out of service

7

8 Woodbury faces operational challenges due to PFAS impacts and the proximity of wells within the
9 Tamarack Well Field. Currently, wells exceeding the HI of 1 are Wells 1, 4, 6, 7, 9, and 13. The city has
10 made operational adjustments that limit the use of wells exceeding the HI of 1. These adjustments
11 include removing Wells 1 and 13 from normal operation, and reducing the pumping rates of the
12 remaining PFAS-impacted wells in order of use, which limits their overall time of operation and places a
13 higher burden on the remaining wells.

14 The municipal supply wells in Woodbury are not currently treated for PFAS but receive chlorine and
15 fluoride treatment at the well head. Currently, the city relies on blending water from various wells
16 within the distribution system to keep PFAS levels in the system below an HI of 1. The total capacity
17 available based on actual pumping rates for those wells with an HI less than 1 is 17,865 gpm (25.7 mgd).
18 The firm capacity with the largest well out of service is 15,865 gpm (22.8 mgd). Based on the firm
19 capacity, Woodbury does not have sufficient capacity to meet their revised maximum daily demands of
20 22.9 mgd for year 2020 and 28.19 mgd for year 2040. Additionally, the Tamarack Wells are located very
21 close to each other and, when running simultaneously, can reduce the pumping rates of one another by
22 increasing the effective draw down. Unfortunately, data are not available to provide the pumping rates
23 of these wells when they are all running simultaneously. Therefore, it is a safe assumption to say that
24 Woodbury will need an additional, high-capacity wells in the South Well Field to reliably meet maximum
25 daily demands.

26 For Woodbury's municipal water system, the city has six water storage tanks with booster pumps, which
27 operate across one pressure zone. Wells are operated to maintain the set levels in the storage tanks.
28 The city has two interconnects – one 10-inch interconnect with Oakdale and one 6-inch interconnect

1 with Maplewood. Both interconnects are not active under normal operating conditions and
2 Maplewood’s water is noted to be incompatible with Woodbury’s municipal water system.
3 As of 2016, about 97% of Woodbury’s population is being served by the city’s municipal water system.
4 The city continues to experience growth along with a corresponding need to expand the municipal
5 water system infrastructure to meet 2040 population projections. An estimated 632 non-municipal wells
6 are currently in Woodbury, with the majority located in the southern third of the city. According to
7 available data from PFAS sampling to date, a few non-municipal wells exceed the HI of 1 (Figure A.14).


8 **A.13.2 Current and proposed projects**

9 Woodbury, with the State of Minnesota’s concurrence, is implementing short-term operational changes
10 and a blending strategy for the municipal water system, and storage tanks as a stop-gap measure to
11 meet drinking water standards. A temporary WTP is also being installed during summer 2020.

12 The city submitted three expedited projects (Application Nos. 100015, 100016, and 100017) for
13 consideration of funding under the settlement. The expedited project, “Distribution System PFAS
14 Mitigation Feasibility Study” (Application 100016), will help examine the effectiveness of mixing and
15 dilution of PFAS in the city’s existing municipal water system. The expedited project, “Salem Meadows
16 Development & Erin Court Water Service Connections” (Application 100015), proposed to connect the
17 Salem Meadows and Erin Court neighborhoods to Woodbury’s municipal water system. The expedited
18 project, “In-Home GAC Treatment Grant Program” (Application 1000017), proposed to make in-home
19 GAC treatment systems available to residences with private wells in Woodbury that are not likely to be
20 serviceable by the municipal water system.

21 The city is currently in the process of implementing a temporary treatment system in the Tamarack well
22 field, which was accepted by the Co-Trustees as an interim measure to address additional well
23 exceedances as well as the demand challenges the city is facing due to PFAS contamination.

1 **Figure A-13. HI levels at sampled non-municipal wells in Woodbury. The 3M source area is outlined in**
2 **red.**



3

4

5 **References**

6 City of Afton. 2015. City of Afton 2008 Comprehensive Plan. Revised May 19, 2015. Available:
7 [https://www.ci.afton.mn.us/vertical/sites/%7B255148F5-88B9-45F6-9726-](https://www.ci.afton.mn.us/vertical/sites/%7B255148F5-88B9-45F6-9726-DD95D24AA11D%7D/uploads/2008_AMENDED_Comp_Plan-Septic_APPROVED_5.19.2015.pdf)
8 [DD95D24AA11D%7D/uploads/2008_AMENDED_Comp_Plan-Septic APPROVED 5.19.2015.pdf](https://www.ci.afton.mn.us/vertical/sites/%7B255148F5-88B9-45F6-9726-DD95D24AA11D%7D/uploads/2008_AMENDED_Comp_Plan-Septic_APPROVED_5.19.2015.pdf).

9 City of Cottage Grove. 2018. City of Cottage Grove Local Water Supply Plan. Updated per DNR
10 Comments June 2018.

- 1 City of Lake Elmo. 2019. Local Water Supply Plan – City of Lake Elmo. Revised June 30, 2019.
2 Appendix to the City of Lake Elmo 2040 Comprehensive Plan. Available:
3 <http://www.lakeelmo.org/2040%20Comprehensive%20Plan.pdf>.
- 4 City of Lakeland. 2017. Local Water Supply Plan – City of Lakeland. August.
- 5 City of Newport. 2016. Local Water Supply Plan – City of Newport. December 31.
- 6 City of Oakdale. 2019. Local Water Supply Plan – City of Oakdale. January.
- 7 City of St. Paul Park. 2018. Local Water Supply Plan – St. Paul Park. August.
- 8 City of Woodbury. 2019. Woodbury 2040 Comprehensive Plan. April 24.
- 9 Denmark Township. 2019. Denmark Township 2040 Comprehensive Plan. Prepared by wsb and
10 Focus Engineering, Inc. Available:
11 https://www.denmarktownship.org/vertical/sites/%7B5B1C76D5-2975-4BD2-B0BA-7327C34C7928%7D/uploads/Denmark_Township_2040_Comp_Plan_Adopted_12-02-2019.pdf.
- 13 Grey Cloud Island Township. 2018. Grey Cloud Island Township, Minnesota – 2040
14 Comprehensive Plan. Draft for Review. June. Available:
15 http://docs.neighborhoodlink.com/resources/529242028/2018-06-12_2040GreyCloudIslandDraftCompPlan--200.pdf?AWSAccessKeyId=AKIAJODKKJAWTTFD34BQ&Expires=1580070120&Signature=P004bbPEsOmWxnRQluszK2NsHH0%3D.
- 19 Health Research. 2012. Recommended Standards for Water Works. Policies for the Review and
20 Approval of Plans and Specifications for Public Water Supplies. A Report of the Water Supply
21 Committee of the Great Lakes – Upper Mississippi River Board of State and Provincial Public
22 Health and Environmental Managers. Prepared by Health Research Inc. Available:
23 <https://www.health.state.mn.us/communities/environment/water/docs/tenstates/waterrev2012.pdf>.
- 25 Metropolitan Council. 2014. 2040 Thrive MSP 2040 Plan. Available:
26 <https://metro council.org/Planning/Projects/Thrive-2040/Thrive-MSP-2040-Plan.aspx?source=child>.
- 28 Metropolitan Council. 2015a. 2015 System Statement – City of Afton. September. Available:
29 <https://metro council.org/Communities/Planning/Local-Planning-Assistance/System-Statements.aspx>.
- 31 Metropolitan Council. 2015b. 2015 System Statement – City of Maplewood. September.
32 Available: <https://metro council.org/Communities/Planning/Local-Planning-Assistance/System-Statements.aspx>.
- 34 Metropolitan Council. 2015c. 2015 System Statement – Denmark Township. September.
35 Available: <https://metro council.org/Communities/Planning/Local-Planning-Assistance/System-Statements.aspx>.
- 36

- 1 Metropolitan Council. 2015d. 2015 System Statement – Grey Cloud Island Township.
- 2 September. Available: [https://metrocouncil.org/Communities/Planning/Local-Planning-](https://metrocouncil.org/Communities/Planning/Local-Planning-Assistance/System-Statements.aspx)
- 3 [Assistance/System-Statements.aspx](https://metrocouncil.org/Communities/Planning/Local-Planning-Assistance/System-Statements.aspx).
- 4 West Lakeland Township. 2019. West Lakeland Township, Minnesota – Comprehensive Plan.
- 5 Prepared by West Lakeland Township Board and Planning Commission. Approved Final Draft.
- 6 January. Available: [https://westlakeland.govoffice2.com/vertical/sites/%7B4302F8BA-2E20-](https://westlakeland.govoffice2.com/vertical/sites/%7B4302F8BA-2E20-46AE-A97A-E6644431668F%7D/uploads/Comprehensive_Plan_-_draft_-_submitted_to_MetCouncil_on_02-04-2019.pdf)
- 7 [46AE-A97A-E6644431668F%7D/uploads/Comprehensive Plan - draft -](https://westlakeland.govoffice2.com/vertical/sites/%7B4302F8BA-2E20-46AE-A97A-E6644431668F%7D/uploads/Comprehensive_Plan_-_draft_-_submitted_to_MetCouncil_on_02-04-2019.pdf)
- 8 [submitted to MetCouncil on 02-04-2019.pdf](https://westlakeland.govoffice2.com/vertical/sites/%7B4302F8BA-2E20-46AE-A97A-E6644431668F%7D/uploads/Comprehensive_Plan_-_draft_-_submitted_to_MetCouncil_on_02-04-2019.pdf).
- 9

DRAFT

Appendix B. Conceptual site model for the East Metropolitan Area

1
2 Groundwater modeling was conducted to support the evaluation of scenarios in this Conceptual
3 Drinking Water Supply Plan (Conceptual Plan). The first step in building a groundwater model is to
4 develop a conceptual site model (CSM), which integrates existing technical data and information from
5 various sources. A CSM provides a way to better understand a very complex natural system by reducing
6 it to a simplified set of relevant assumptions, data, and information to develop a picture of how the
7 system functions. The CSM identifies and describes the relevant and important processes that influence
8 groundwater flow in the East Metropolitan Area of the Twin Cities. These are the processes that will be
9 simulated and represented by the numerical, three-dimensional groundwater flow model, which was
10 constructed following the development of this CSM. The numerical model was developed to support the
11 evaluation of scenarios that address drinking water quantity and quality for the 14 communities
12 currently known to be affected by per- and polyfluoroalkyl substances (PFAS) contamination in the East
13 Metropolitan Area, now and through 2040. The numerical model will be used as a basis to create visual
14 representations of the groundwater regime, flow path, and well/pumping scenarios.

15 This appendix provides an overview of the CSM that was developed for the East Metropolitan Area.
16 Appendix C provides an overview of the numerical model.

17 **B.1 Introduction**

18 **B.1.1 Purpose and scope**

19 The CSM presented here is the basis for construction of a numerical, three-dimensional groundwater
20 flow model. The purpose of the groundwater model is to provide insight into the current groundwater
21 flow system, and predict impacts to flow paths and groundwater resources through the year 2040 from
22 the proposed scenarios. These flow paths and quantity estimates are based on projected groundwater
23 recharge/precipitation rates, surface water elevations, and pumping volumes of the proposed scenarios.
24 The year 2040 was selected because it was the time period for which there are population projections in
25 the comprehensive plans and/or water supply plans of each community, which determine drinking
26 water demand.

27 The objectives of the groundwater model are to:

- 28 1. Assess aquifer sustainability and viability of production rates for the proposed scenarios that may
29 involve changes in pumping rates or new water supply wells
- 30 2. Analyze contaminant flow paths under the different proposed scenarios and climate conditions to
31 determine the potential risk of PFAS contamination at existing and future wellfields
- 32 3. Evaluate potential impacts to groundwater resources in response to projected future groundwater
33 use under the different proposed scenarios and climate conditions
- 34 4. Communicate model results and technical issues (e.g., flow direction, impacts to current
35 remediation) internally and to stakeholders through visual representations of simulated flow
36 systems.

1 This groundwater model may also be used in the future to further evaluate projects as they are refined
2 following the development of this Conceptual Plan.

3 **B.1.2 Data and sources**

4 The data and content within this CSM were selected in collaboration with several agencies, local
5 government units, and consultants. The entities listed below made major contributions to the
6 construction of this CSM:

- 7 • Wood Environment & Infrastructure Solutions, Inc. (Wood)
- 8 • Minnesota Pollution Control Agency (MPCA)
- 9 • Minnesota Geological Survey (MGS)
- 10 • Minnesota Department of Natural Resources (DNR)
- 11 • Minnesota Department of Health (MDH).

12 Additional contributors included the local watershed districts and Washington County.

13 The data compiled and evaluated for the CSM are summarized in Table B.1. The focus of the CSM is the
14 East Metropolitan Area (henceforth regarded as the “Study Area”) and presentation of the compiled
15 data is restricted to the following Minnesota counties: Washington, Ramsey, Dakota, Hennepin, Chisago,
16 Anoka, Scott, and Isanti. An approximate boundary for the groundwater flow model domain in
17 Minnesota was generated for the data collection and the data presented in this appendix are restricted
18 to this boundary, which does not include the Wisconsin side of the St. Croix River (Figure B.1).

19 **Table B.1. Data compiled for the CSM.**

Data	Source
3-meter digital elevation model (DEM)	DNR (2019h)
Land use map	MNIT (2019)
Surface water boundaries	USGS (2019a)
Geologic maps	Balaban and Hobbs (1990), Meyer and Swanson (1992), Setterholm (2010, 2013), Bauer et al. (2016), Chandler et al. (2017), Steenberg et al. (2018)
Precipitation data	DNR (2019a)
Lake bathymetry data	DNR (2019d)
Hydraulic conductivity	Runkel et al. (2003), Tipping et al. (2010)
Surface water elevations	DNR (2019f)
Historical and current pumping volumes	DNR (2019b)
Groundwater elevations	DNR (2019e), MDH (2019)
Well construction details	MDH (2019)
Baseflow measurements	DNR (2019c)
Recharge and runoff estimates from 1990s through 2018	DNR (2019i)
Metro Model 3	Metropolitan Council (2019)
U.S. Geological Survey (USGS) Northeast Metro Lakes Groundwater-Flow model files	USGS (2019b)
DNR Northeast Metro Lakes Groundwater-Flow model files	DNR (2019g)
Groundwater sample data	MDH (2019), MPCA (2019a)

Data	Source
PFAS source areas	MDH (2019), MPCA (2019b)

1 **B.1 Physical setting and climate**

2 The Study Area is in east-central Minnesota in the northern continental United States (Figure B.1). The
3 land surface in the Study Area was shaped by multiple glacial advances and retreats, resulting in a gently
4 rolling to flat topography, with occasional outcroppings and erosional surface exposures near major
5 surface water features. The developed metropolitan area is surrounded by suburbs, rural towns,
6 pastures, and cultivated crops. The landscape is also defined by abundant surface water features,
7 including the St. Croix, Minnesota, and Mississippi rivers; in addition to many smaller streams, lakes, and
8 wetlands (Figure B.2).

9 The climate is sub-humid. Average summer (June through August) monthly temperature and
10 precipitation for the Study Area is approximately 70°F and 4 to 5 inches, respectively, based on a 50-year
11 period of record (1968–2018; Table B.2). In the winter months (December through February), average
12 temperatures are below freezing and average monthly precipitation (typically in the form of snowfall) is
13 approximately 1 to 2 inches.

14 **Table B.2. Average monthly temperature and precipitation based on 50-year period of record**
15 **(1968–2018).**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Temperature (°F)	14	20	32	47	59	69	74	71	62	49	34	20
Precipitation (inches)	0.94	0.83	1.78	2.92	3.75	4.76	4.26	4.18	3.17	2.64	1.76	1.19

16 Data source: DNR (2019a).

17 A plot of average annual precipitation by decade for the entire period of record (1890s to present
18 decade) is shown in Figure B.3. Overall, the plot shows a decreasing trend followed by an increasing
19 trend in precipitation. During the early 1900s, precipitation was on a decreasing trend until it reaches a
20 minimum in the 1930s. Since then, precipitation has been on an increasing trend, with the exception of
21 a slight dip during the 2000–2010 decade. Average annual precipitation for the current decade
22 (34.94 inches) is above the 75th percentile for annual precipitation during the period of record
23 (32.66 inches).

24 Much of the precipitation received in the Study Area is removed via evapotranspiration, which is a
25 combination of moisture being removed from the soil to the atmosphere (evaporation) and from plants
26 through transpiration. Mean evapotranspiration was estimated by Baker et al. (1979) using
27 two methods: (1) calculating the difference between precipitation and run-off, assuming zero recharge
28 to groundwater; and (2) calculating evapotranspiration using the Thornthwaite method, which takes
29 into account a number of assumptions. The first method provided a mean evapotranspiration in the
30 Twin Cities Metropolitan Area of approximately 20 inches per year. The second method provided a
31 mean potential evapotranspiration of approximately 25 inches per year.

32 **B.2 Geology and hydrostratigraphy**

33 **B.2.1 Structural setting**

34 The structural setting for the Twin Cities Metropolitan Area is the Midcontinent Rift System
35 (Figure B.4a). Formation of the rift occurred during the Mesoproterozoic Era (1,600–1,000 million years

ago) and resulted in a complex suite of volcanic rock bounded by major northeast-southwest trending faults. The faults were initially extensional during graben development; however, later compressional forces caused the faults to reverse and, consequently, the central graben was uplifted, resulting in a central horst (St. Croix Horst). In the Study Area, the western side of the St. Croix Horst is bounded by the Douglas and Pine faults in Hennepin County (Steenberg et al., 2018). Rocks associated with the Midcontinent Rift System are part of the Keweenaw Supergroup, which is comprised primarily of volcanic rock but also includes sedimentary rock that was deposited within the rift zone after volcanic activity ceased. A long period of erosion occurred after the uplift of the horst and prior to the deposition of the oldest Paleozoic rock mapped in the Study Area (Mt. Simon Sandstone).

The deposition of Paleozoic rock was influenced by another structural feature present in southeast Minnesota: the Hollandale Embayment (Figure B.4b). The Hollandale Embayment was a shallow depositional basin bordered by the Transcontinental Arch to the west-northwest, the Wisconsin Dome to the northeast, and the Wisconsin Arch to the east. Shallow epeiric seas inundating southeast Minnesota and adjacent states during the Paleozoic era occupied the Hollandale Embayment, and resulted in a sequence of Paleozoic sedimentary strata. Reactivation of pre-Cambrian basement faults during the Ordovician Period off-set Paleozoic strata, resulting in the formation of the Twin Cities Basin. The Twin Cities Basin is bounded on the west by the Douglas and Pine faults in Hennepin County, and by the Hudson-Afton Horst (an inverted graben) in southeast Washington County.

B.2.2 Bedrock geology and hydrostratigraphy

Bedrock in the Study Area consists of Paleozoic sedimentary rocks that span in age correlating to the Cambrian through Devonian Periods (Figure B.5). Deposition occurred during transgression and regression of shallow epeiric seas that inundated southeast Minnesota and adjacent states. The Paleozoic bedrock units (sedimentary sequences of sandstone, siltstone, shale, limestone, and dolomite) are discussed below. A stratigraphic column showing lithology and a representative natural gamma log are provided in Figure B.6. A summary of hydraulic conductivity values from Runkel et al. (2003) is provided in Table B.3 and discussed in more detail for individual hydrostratigraphic units in the sections below.

Table B.3. Horizontal hydraulic conductivity (K) ranges for bedrock aquifer and confining units (based on Runkel et al., 2003).

Formation	K-min (feet/day) shallow ^a bedrock		K-max (feet/day) shallow bedrock		K-min (feet/day) deep bedrock		K-max (feet/day) deep bedrock	
	Decorah Shale	6.01E+01		NA		NA		1.00E-06
Platteville Formation	1.00E-01	1.00E+03 (estimate)	1.00E-03		1.00E-01			
Glenwood Formation	NA		1.00E-06 (vertical only)					
St. Peter Sandstone – upper	2.00E+01	3.87E+01	1.30E+00		1.59E+01			
St. Peter Sandstone – lower	NA		NA					
Prairie du Chien Group – Shakopee Formation	1.00E-01	1.02E+03	9.00E+00		3.35E+01			
Prairie du Chien Group – Oneota Dolomite	7.50E-03		NA					
Jordan Sandstone – upper	3.00E+01	5.00E+02	1.00E-01		1.00E+02			
Jordan Sandstone – lower			1.00E-02					
St. Lawrence Formation ^b	4.60E+01		1.00E-02		2.00E+01			

Tunnel City Group – upper	1.00E-02	2.20E+02	1.40E+00	2.78E+01
Tunnel City Group – lower			< 1.00E-02	
Wonewoc Sandstone – upper	1.00E+01	1.00E+02	5.00E+00	
Wonewoc Sandstone – lower			1.60E+00	3.10E+01
Eau Claire Formation	3.67E+01		1.00E-03	1.00E-02
Mt. Simon Sandstone – upper	2.93E+01		1.00E-02	1.30E+00
Mt. Simon Sandstone – lower			1.50E+00	3.95E+01
Blue indicates aquifer properties				
Orange indicates aquitard properties				

- 1 a. Shallow bedrock is generally the upper portion of for each individual formation and deep bedrock is the lower
2 portion.
3 b. The St. Lawrence Formation can function as a semi-confining unit in portions of the study area. Based on Runkel
4 et al., 2003.
5 NA = not available.
6

7 **B.2.2.1 Mt. Simon Sandstone (oldest Paleozoic bedrock formation)**

8 The Mt. Simon Sandstone is a medium- to coarse-grained, well-sorted quartz-rich sandstone with
9 interbedded fine-grained sediment (siltstone and very fine-grained feldspathic sandstone). The thin beds
10 of finer-grained sediment are more abundant in the upper portion of the Mt. Simon Sandstone than in
11 the lower portion.

12 The Mt. Simon Sandstone unconformably overlies Mesoproterozoic rock (i.e., an erosional surface is at
13 the base of the formation). A quartz conglomerate is present at several stratigraphic positions within the
14 formation and is particularly more prominent at the base. The thickness of the Mt. Simon Sandstone is
15 variable, and in part due to the topography of the erosional surface the formation was deposited onto.
16 Based on borehole data, the thickness of this unit varies between approximately 100 and 400 feet within the
17 Study Area. In Washington County, it has a reported maximum thickness of approximately 280 feet
18 (Bauer et al., 2016).

19 Horizontal hydraulic conductivity values estimated from specific capacity, discrete interval packer, and
20 standard aquifer tests range between 0.38 and 39.5 feet/day. In shallow bedrock (areas of enhanced
21 fracture porosity in Paleozoic strata within 60 feet of the bedrock surface), where the hydraulic
22 conductivity is enhanced due to secondary porosity (i.e., fractures), the average horizontal hydraulic
23 conductivity is 29.3 feet/day. Based on discrete interval packer tests of similar strata in other parts of
24 the Paleozoic section, the fine clastic vertical hydraulic conductivity could be on the order of
25 10^{-4} feet/day (Runkel et al., 2003).

26 The Mt. Simon Sandstone is typically depicted as a single aquifer; however, due to the greater relative
27 abundance of fine-grained beds in the upper Mt. Simon Sandstone compared to the lower portion, it is
28 likely the formation internally consists of at least two hydrogeologic units (Runkel et al., 2003).

29 **B.2.2.2 Eau Claire Formation**

30 The Eau Claire Formation is composed of shale, siltstone, and very fine- to fine-grained feldspar-rich
31 sandstone. The contact between the Eau Claire and underlying Mt. Simon Sandstone is conformable
32 (Bauer et al., 2016). Based on borehole data, where available, the thickness of the Eau Claire Formation
33 ranges from approximately 60 to 100 feet.

1 The Eau Claire Formation is present in the subsurface throughout the Study Area with the exception of a
2 few localized areas, particularly in northern Isanti and Chisago counties. In parts of Chisago, Isanti, and
3 Anoka counties, the Eau Claire is the uppermost bedrock along the rim of the Twin Cities Basin and along
4 deep buried valleys. In Ramsey and Dakota counties, the Eau Claire Formation is completely covered by
5 younger Paleozoic rock (Balaban and Hobbs, 1990; Meyer and Swanson, 1992).

6 Horizontal hydraulic conductivity values estimated from discrete interval packer and slug tests range
7 between 10^{-3} and 10^{-2} feet/day. A discrete interval packer test of similar strata in Ramsey County yielded
8 a vertical hydraulic conductivity estimate of 10^{-4} feet/day. The average hydraulic conductivity from
9 specific capacity tests in fractured shallow bedrock is 36.7 feet/day (Runkel et al., 2003).

10 Due to the fine-grained nature of the formation, the Eau Claire is generally considered a confining unit.
11 However, where well-connected fractures exist, such as in shallow bedrock conditions, the permeability
12 is enhanced and the formation is used as a source of groundwater supply.

13 **B.2.2.3 Wonewoc Sandstone**

14 The Wonewoc Sandstone is a fine- to coarse-grained sandstone with two members. Due to the coarser
15 nature of the lower member compared to the upper member, the Wonewoc Sandstone is divided into
16 an upper and lower aquifer (oldest to youngest): (1) the Galesville Sandstone (lower member) and
17 (2) the Ironton Sandstone (upper member). Previously, the members were identified as separate
18 formations. However, due to the difficulty in distinguishing the two sandstones, they are currently
19 combined and classified as the Wonewoc Sandstone (Mossler, 2008).

20 The lower Wonewoc is a fine- to coarse-grained sandstone that becomes finer-grained and more well-
21 sorted toward the base. The upper Wonewoc is a very coarse-grained sandstone with thin interbeds of
22 siltstone and shale. The clay and silt components are also observed in the matrix (Mossler, 2008).

23 The Wonewoc Sandstone conformably overlies the Eau Claire Formation in Minnesota and the contact
24 between the two is transitional. A subtle unconformity is present at the contact between the upper and
25 lower Wonewoc (Runkel et al., 1998). Based on borehole data, the thickness of Wonewoc is
26 approximately 60 feet. In Washington County, the thickness ranges between 45 and 75 feet (Bauer
27 et al., 2016). The Wonewoc is present in the subsurface throughout the Study Area (Meyer and
28 Swanson, 1992), with the exception of areas where Mt. Simon or Eau Claire are directly underlying
29 Quaternary sediment.

30 Horizontal hydraulic conductivity values estimated from specific capacity, pumping, and packer tests
31 range between 1.6 and 31 feet/day in deep bedrock (Runkel et al., 2003). The horizontal hydraulic
32 conductivity of the lower member, based on a discrete interval packer test in Ramsey County, ranges
33 between 1.6 and 7.9 feet/day. The vertical hydraulic conductivity ranges between 0.16 and
34 0.79 feet/day. This same test yielded a horizontal hydraulic conductivity estimate of 5 feet/day and a
35 vertical hydraulic conductivity estimate of 0.5 feet/day for the upper member of the Wonewoc. The
36 range of horizontal hydraulic conductivity values is higher for fractured shallow bedrock. Slug and
37 specific capacity tests provide a horizontal hydraulic conductivity range of 10 to 100 feet/day (Runkel
38 et al., 2003).

39 **B.2.2.4 Tunnel City Group**

40 The Tunnel City Group (formerly classified as the Franconia Formation) is composed of three formations:
41 (1) the Davis Formation (not present in the Study Area), (2) the Lone Rock Formation, and (3) the
42 Mazomanie Formation. The Lone Rock and Mazomanie formations intertongue with each other in east-

1 central Minnesota (Mossler, 2008). The Mazomanie Formation is present in the northern part of the
 2 Study Area. In Washington County, the Mazomanie overlies and intertongues with the Lone Rock
 3 member. It thins toward the south, where it is progressively replaced by the Lone Rock Formation
 4 (Bauer et al., 2016). The Lone Rock Formation contains three members (from oldest to youngest): (1) the
 5 Birkmose Member, (2) the Tomah Member, and (3) the Reno Member. The Birkmose Member is a
 6 massive, very fine- to fine-grained, glauconitic sandstone cemented with dolomite (Mossler, 2013).
 7 Burrows are present throughout and are commonly lined or filled with silt. Intraclastic dolostone is
 8 present at the top of the member. The Tomah Member is a siltstone to very fine-grained, feldspar-rich
 9 sandstone with very thin interbeds of shale (Mossler, 2013). The Reno Member is a very fine-grained,
 10 well-sorted, glauconitic, feldspar-rich sandstone with minor siltstone and shale beds (Mossler, 2008). It
 11 also has thin beds with dolomitic intraclasts. A siltstone conglomerate in a matrix of sandy dolostone is
 12 typically present at the top of the Reno Member and may indicate a period of non-deposition between
 13 the Reno and overlying St. Lawrence Formation (Mossler, 2008). The contact between the Lone Rock
 14 Formation and underlying Wonewoc Sandstone is conformable.

15 The Mazomanie Formation is a very fine- to medium-grained dolomitic sandstone (Mossler, 2008).
 16 Burrows are common along discrete horizons. The Mazomanie Formation is present in Washington,
 17 Ramsey, Anoka, Chisago, and Hennepin counties.

18 The Tunnel City Group is present in the subsurface throughout the Study Area and its thickness is fairly
 19 consistent. Based on available data, the formation ranges between 135 and 180 feet. Where present,
 20 the Mazomanie Formation is up to 100-feet thick and individual tongues can be up to 50-feet thick in
 21 Washington County (Bauer et al., 2016). Outcrops occur along the St. Croix River from central
 22 Washington County to southern Chisago County (Mossler, 2008).

23 The average horizontal hydraulic conductivity of the Tunnel City Group based on specific capacity tests is
 24 5.9 feet/day where the Mazomanie Formation is thin to absent and 27.8 feet/day where it is thick
 25 (Runkel et al., 2003). Discrete interval packer tests in Ramsey County yielded horizontal and vertical
 26 hydraulic conductivity estimates of 1.4 to 7.5 and 0.14 to 0.75 feet/day, respectively, for the Mazomanie
 27 Formation. The same tests provided a horizontal and vertical hydraulic conductivity estimate of 10^{-2} (or
 28 less) and 10^{-4} (or less) feet/day, respectively, for the middle to lower Lone Rock Formation. Where the
 29 permeability is enhanced due to well-connected fractures, the average horizontal hydraulic conductivity
 30 for the Tunnel City Group is 32 feet/day (Runkel et al., 2003).

31 Due to the low permeability of the middle-to-lower Lone Rock Formation, this portion of the Tunnel City
 32 Group is considered a confining unit. The upper half of the Tunnel City Group contains discrete bedding
 33 plane fractures (even in deep bedrock) and a coarser clastic component, and, therefore, is considered an
 34 aquifer.

35 **B.2.2.5 St. Lawrence Formation**

36 The St. Lawrence Formation is composed of two distinct lithofacies: sandy/silty dolostone in the lower
 37 portion and siltstone in the upper portion. The lower St. Lawrence is the first Paleozoic rock consisting
 38 primarily of chemically precipitated carbonate. The lower dolomitic portion of the St. Lawrence includes
 39 thin glauconitic sandstone beds and is argillaceous (Mossler, 2008). Thin beds of siltstone and shale are
 40 common. The contact between the St. Lawrence and the underlying Tunnel City Group is conformable
 41 and distinct. In the northern part of the Study Area, the base of the St. Lawrence is composed of a
 42 siltstone and sandy/silty dolostone that overlies the fine- to medium-grained sandstone of the
 43 Mazomanie Formation (Runkel et al., 2006). However, in the southern part of the Study Area (Scott,

1 Ramsey, and Dakota counties), the base of the St. Lawrence overlies the very fine-grained, feldspathic
2 sandstone of the Lone Rock Formation and the contact between the two can be harder to distinguish.

3 The siltstone of the upper St. Lawrence Formation is a dolomitic siltstone and can be slightly glauconitic
4 or sandy within the Study Area (Mossler, 2008). In Washington County, the St. Lawrence is primarily a
5 dolomitic, feldspathic siltstone with interbedded shale and very fine-grained sandstone. The
6 St. Lawrence generally ranges in thickness between 30 and 50 feet in the northern part of the Study
7 Area. In Scott County, the formation is up to 90-feet thick.

8 The St. Lawrence Formation underlies younger Paleozoic rock in most of Washington, Hennepin,
9 Ramsey, Dakota, eastern Scott, and southern Anoka counties. The formation directly underlies
10 Quaternary deposits in deeply incised buried bedrock valleys. In Ramsey County, the St. Lawrence is the
11 oldest Paleozoic rock to directly underlie Quaternary sediment. The St. Lawrence is not present in most
12 of Chisago and Isanti counties. It is the youngest Paleozoic rock mapped in Isanti County. The
13 St. Lawrence is exposed in thin outcrops along the Minnesota River valley and the St. Croix River in
14 eastern Washington and Chisago counties (Runkel et al., 2006).

15 Horizontal hydraulic conductivity estimates for the St. Lawrence Formation (deep bedrock) vary
16 considerably and range between 10^{-2} and 20 feet/day based on specific capacity and packer tests. The
17 low end of the range represents intergranular or matrix porosity. The higher end represents secondary
18 porosity, mainly in the form of dissolution cavities formed in carbonate rock. A discrete interval packer
19 test performed in Ramsey County provided a vertical hydraulic conductivity estimate of 10^{-4} feet/day.
20 The average horizontal hydraulic conductivity estimated from specific capacity tests in shallow fractured
21 bedrock is 46 feet/day (Runkel et al., 2003).

22 Dissolution cavities within the St. Lawrence enhances the permeability of the formation and, as a result,
23 can provide moderate-to-large quantities of water where the dissolution cavities occur. However, the
24 vertical hydraulic conductivity of the formation is sufficiently low for the St. Lawrence to be considered a
25 confining unit. Under shallow bedrock conditions where fractures and large dissolution cavities exist, the
26 formation is considered an aquifer.

27 **B.2.2.6 Jordan Sandstone**

28 The Jordan Sandstone consists of a very fine- to coarse-grained, well-rounded, well-sorted sand. The
29 formation conformably overlies the St. Lawrence Formation and the contact is gradational (Steenberg
30 and Retzler, 2016). The sandstone coarsens upward from a very fine-grained, massive, feldspar-rich sand
31 with thin beds of siltstone and shale to a medium- to coarse-grained, quartz-rich sand (Mossler, 2008).
32 Very fine-grained feldspathic intervals are intercalated within the quartz-rich lithofacies (Mossler, 2008).

33 The Jordan Sandstone underlies younger Paleozoic rock in much of Washington, Hennepin, Scott,
34 Ramsey, and Dakota counties. The formation is exposed along the Mississippi River and the St. Croix
35 River bluffs in Washington County (Steenberg and Retzler, 2016). In areas where the Jordan Sandstone is
36 present, it ranges in thickness between approximately 80 and 100 feet. In northern Washington County,
37 the formation thins to approximately 65 to 70 feet (Bauer et al., 2016).

38 Horizontal hydraulic conductivity estimates from specific capacity, pumping, and packer tests in deep
39 bedrock range between 0.1 and 100 feet/day. These estimates may include the overlying Coon Valley
40 Member of the Ordovician Prairie du Chien Formation, since many open borehole intervals of water
41 wells for the Jordan Sandstone also include the Coon Valley Member. Horizontal hydraulic conductivity
42 estimates from discrete interval packer tests of similar strata as the lower lithofacies yield an estimated
43 value on the order of 10^{-2} feet/day. Based on these same tests, the vertical hydraulic conductivity for the

1 fine-grained interval is inferred to be on the order of 10^{-4} feet/day. Specific capacity and pumping tests
 2 in shallow fractured bedrock provide a horizontal hydraulic conductivity range of 30 to over 500
 3 feet/day (Runkel et al., 2003).

4 Given the higher-permeability estimates of the upper quartz-rich portion of the Jordan Sandstone, the
 5 upper Jordan Sandstone is considered to be an aquifer. Due to the fine-grained nature of the lower
 6 Jordan Sandstone and inferred low permeability, the lower Jordan Sandstone is considered to be a
 7 confining unit, together with the underling St. Lawrence Formation.

8 **B.2.2.7 Prairie du Chien Group**

9 The Prairie du Chien Group is the oldest Ordovician rock in the Study Area and is made up of
 10 two formations (from oldest to youngest): (1) the Oneota Dolomite and (2) the Shakopee Formation.
 11 The group as a whole is largely composed of carbonate rock. As the name implies, the Oneota Dolomite
 12 is primarily a massive dolostone. The lower Oneota Dolomite includes the Coon Valley Member, which
 13 formerly was identified as part of the Jordan Sandstone. The Coon Valley Member is composed of
 14 dolostone, feldspathic sandstone, quartzose sandstone, and shale. It is absent in parts of Washington
 15 County. Where present, the Coon Valley is up to 30-feet thick (Bauer et al., 2016). The contact between
 16 the Coon Valley Member and the underlying Jordan Sandstone is unconformable, marked by a poorly
 17 sorted, pebbly sandstone (Mossler, 2008). The upper member of the Oneota Dolomite is the Hager City
 18 Member, a crystalline dolomite. The upper portion has coarse-grained, calcite-filled vugs and is
 19 brecciated within the top few feet (Mossler, 2008). In Washington County, the Hager City Member is up
 20 to 70-feet thick (Steenberg and Retzler, 2016).

21 The Shakopee Formation includes two members (from oldest to youngest): (1) the New Richmond
 22 Member and (2) the Willow River Member. The New Richmond Member is primarily a fine-grained
 23 sandstone but also includes sandy dolostone. The Willow River Member is a dolostone with thin,
 24 medium-grained sandstone beds and dolostone beds (Mossler, 2008). The thickness of the Shakopee is
 25 variable due to faulting and a period of erosion prior to deposition of the overlying St. Peter Sandstone.
 26 In Washington County, the Shakopee is thickest in the southeast (up to 200-feet thick east of the
 27 Hudson-Afton Horst). West of the Hudson-Afton Horst, the Shakopee is up to 115-feet thick and thins to
 28 the northwest (Bauer et al., 2016). Based on a limited amount of data, the Shakopee is thinner (and may
 29 be absent) in areas overlying the Hudson-Afton Horst. Based on thickness changes of the Prairie du
 30 Chien across the Hudson-Afton Horst, Paleozoic faulting is interpreted to have occurred during the early-
 31 to-middle Ordovician Period (Bauer et al., 2016).

32 The Prairie du Chien Group is present in Washington, Ramsey, Dakota, Hennepin, and Anoka counties. In
 33 Anoka County, the Prairie du Chien is only present in the very southeastern corner. It is the uppermost
 34 bedrock across a wide expanse of the Study Area, particularly in Washington, Dakota, Ramsey,
 35 Hennepin, and Scott counties. The Prairie du Chien outcrops along the tops of bluffs of the Mississippi
 36 and St. Croix River valleys in Washington County, and in places where Quaternary sediment is thin
 37 (Bauer et al., 2016).

38 The Shakopee and upper Oneota have a well-developed network of dissolution cavities and vertical
 39 fractures, as well as oomoldic porosity, a form of secondary porosity that can form through the
 40 preferential dissolution of oolitic limestone (limestone composed of spherical grains of concentric
 41 layers). Specific capacity discrete interval, and pumping tests; dye studies; and flow meter logging
 42 provide a horizontal hydraulic conductivity range of 1.6 to greater than 1,023 feet/day. Secondary
 43 porosity in the lower-to-middle Oneota is primarily restricted to discrete horizons along bedding planes.

1 Pumping tests in the middle-to-lower Oneota yielded horizontal and vertical hydraulic conductivity
2 estimates on the order of 10^{-3} and 10^{-4} feet/day, respectively (Runkel et al., 2003).

3 Given the enhanced permeability from secondary porosity, the combined Shakopee and upper Oneota
4 are considered to be an aquifer. The middle and lower Oneota is considered a confining unit. Under
5 shallow bedrock conditions, the Prairie du Chien exhibits the typical attributes characteristic of a karst
6 system (Runkel et al., 2003). Preferential flow paths occur through fractures and solution features in
7 both shallow and deep conditions.

8 **B.2.2.8 St. Peter Sandstone**

9 The St. Peter Sandstone is divided into a lower Pigs Eye Member and an Upper Tonti Member. The
10 Lower Pigs Eye Member is composed of interbedded sandstone, siltstone, and shale. The sandstone is
11 fine- to medium-grained and quartz-rich. The Tonti Member is a well-sorted, well-rounded, poorly
12 cemented, fine- to medium-grained, quartz-rich sandstone. Bedding and structures are generally absent
13 (Steenberg et al., 2018). In Washington County, the lower Pigs Eye Member is 10- to 40-feet thick and
14 the Tonti Member is 100- to 140-feet thick (Bauer et al., 2016).

15 A long period of erosion occurred prior to the deposition of the St. Peter Sandstone, and a major
16 unconformity exists at the contact between the Middle to Upper Ordovician St. Peter Sandstone and the
17 underlying Lower Ordovician Prairie du Chien Group. In areas of western Hennepin County, along the
18 edge of the Twin Cities Basin, the Prairie du Chien is absent and the St. Peter Sandstone directly overlies
19 the Jordan Sandstone.

20 The St. Peter Sandstone is present in Washington, Anoka, Dakota, Hennepin, and Ramsey counties; and
21 is either buried beneath younger Paleozoic rocks or directly underlies Quaternary sediment. Outcrops of
22 St. Peter Sandstone are located along bluffs of the Mississippi River (Steenberg et al., 2018) or where
23 Quaternary deposits are thin. The Lower Pigs Eye member is not exposed in Washington County (Bauer
24 et al., 2016).

25 Horizontal hydraulic conductivity estimates from specific capacity, packer, and pumping tests range
26 between 1.3 and 15.9 feet/day for deep bedrock. The vertical hydraulic conductivity of the lower Pigs
27 Eye Member was estimated from pumping tests and groundwater modeling, and is on the order of 10^{-3}
28 feet/day (Schoenberg, 1990). In shallow bedrock, horizontal hydraulic conductivity estimates vary but
29 are as high as 38.7 feet/day (Runkel et al., 2003).

30 The St. Peter Sandstone serves as an aquifer as a result of its high permeability and intergranular
31 porosity. Due to the low vertical hydraulic conductivity of the lower Pigs Eye Member, the lower
32 St. Peter Sandstone is considered a confining unit, where present.

33 **B.2.2.9 Glenwood Formation**

34 The Glenwood Formation is primarily a calcareous and phosphatic, sandy shale (Mossler, 2008). The
35 contact between the Glenwood and the underlying St. Peter Sandstone is marked by a clayey sandstone.
36 The occurrence of pebbles and sandstone fragments along the contact suggest a break in deposition;
37 however, the contact is not designated as a regional unconformity due to the lack of large-scale erosion
38 (Mossler, 2008).

39 The Glenwood Formation and the overlying Platteville Formation are mapped together in the Study
40 Area. The mapped unit is present in Washington, Hennepin, and Ramsey counties. Where present, the
41 Glenwood thickness is typically 3 to 7 feet (Steenberg et al., 2018).

1 Based on a laboratory analysis of slug and pumping tests of similar strata, the vertical hydraulic
 2 conductivity is estimated to be on the order of 10^{-6} feet/day. Due to the low estimated vertical hydraulic
 3 conductivity, the Glenwood Formation is considered a confining unit. In shallow bedrock conditions,
 4 open vertical fractures may penetrate through the relatively thin formation and provide a conduit for
 5 groundwater recharge to the underlying St. Peter Sandstone (Runkel et al., 2003).

6 **B.2.2.10 Platteville Formation**

7 The Platteville Formation is composed of limestone and dolomite. In the East Metropolitan Area, the
 8 Platteville consists of four members representing different lithologies and depositional environments
 9 (Mossler, 2008). The basal member is a sandy dolostone that typically contains phosphate nodules. The
 10 contact between the Platteville and Glenwood formations is considered conformable because of the
 11 lack of evidence suggesting a break in deposition in Minnesota (Mossler, 2008).

12 The Platteville Formation is present in parts of Washington and Ramsey counties. Where present, the
 13 formation thickness ranges between approximately 25 and 30 feet (Steenberg et al., 2018). The
 14 Platteville crops out at bluffs of the Mississippi River in Ramsey County.

15 The horizontal hydraulic conductivity estimates, based on discrete interval packer tests, range between
 16 10^{-3} and 10^{-1} feet/day in deep bedrock. Pumping tests in shallow bedrock span from 10^{-1} to hundreds of
 17 feet/day. Specific capacity tests in this same interval yield an average estimate of 72 feet/day (Runkel
 18 et al., 2003).

19 Due to the low hydraulic conductivity estimates of the Platteville Formation, the lowest portion of the
 20 unit is considered a confining unit. However, the formation is a karstic aquifer where bedrock is shallow
 21 and serves as a source of water where secondary porosity is well-developed. The Platteville Formation is
 22 a significant karst feature within southern Washington County, where present.

23 **B.2.2.11 Decorah Shale**

24 The Decorah Shale is predominantly a shaley unit; however, it also contains thin beds of fossiliferous
 25 limestone that are more prominent at the base (Bauer et al., 2016). It is the youngest Paleozoic rock
 26 mapped in the Study Area and is only present in Washington, Dakota, Hennepin, and Ramsey counties.
 27 In Washington County, it has a maximum thickness of 40 feet. The Decorah Shale is exposed along bluffs
 28 of the Mississippi River in Ramsey County.

29 Where present in Washington County, the Decorah Shale would be under shallow bedrock conditions.
 30 Specific capacity tests in shallow bedrock yield an average horizontal hydraulic conductivity of
 31 60.1 feet/day. Under deep bedrock conditions, the Decorah Shale would be on the order of 10^{-6} feet/day
 32 based on measured values in similar strata (Freeze and Cherry, 1979) and is considered a confining unit.

33 **B.2.3 Quaternary geology and hydrostratigraphy**

34 The advance and retreat of glaciers emanating from the Laurentide Ice Sheet resulted in a complex
 35 assemblage of surficial deposits across Minnesota. The distribution and thickness of glacial deposits
 36 were controlled to some extent by the paleo landscape at the time of deposition. Glacial deposits that
 37 have distinct characteristics indicate the source area and timing of the glacial advance. Multiple glacial
 38 advances occurred during the Pleistocene Epoch and the sediments left behind (gravel, sand, silt, and
 39 clay) make up the vast majority of Quaternary deposits. Glacial lobes that advanced into Minnesota have
 40 four source areas (shown in Figure B.7): (1) Riding Mountain Provenance, (2) Winnipeg Provenance,
 41 (3) Rainy Provenance, and (4) Superior Provenance. Most of the glacial sediments deposited in the Study
 42 Area are associated with the Wisconsin Superior lobe and the Wisconsin Grantsburg sublobe.

1 The Pleistocene units mapped in the Study Area make up a complex suite of sand and gravel aquifers,
 2 and fine-grained confining units (Figure B.8a). The fine-grained sediment consists of till or diamicton
 3 (poorly sorted deposits consisting of gravel-to-boulder size clasts in a fine-grained matrix deposited
 4 directly by glaciers); lacustrine clay, silt, and sand; loess (wind-blown silt); and slack water deposits that
 5 overly terrace sand. Sand and gravel deposits are primarily the result of meltwater from advancing and
 6 retreating glacial lobes.

7 Holocene deposits are present throughout the Study Area and primarily occur along surface water
 8 bodies. These deposits include:

- 9 • Alluvium (deposits resulting from flowing water)
- 10 • Peat
- 11 • Silt and clay lacustrine (lake) deposits
- 12 • Wetland sediment
- 13 • Colluvium (deposits resulting from gravity or fallen material)
- 14 • Wind-blown sand.

15 Quaternary deposit thickness varies throughout the Study Area (Figure B.8b) and greater thicknesses
 16 occur in bedrock valleys. Bedrock valleys are generally areas of sand and gravel outwash deposits. In
 17 Washington County, surficial deposits are less than 300 feet. Thickness less than 50 feet occurs in areas
 18 where bedrock is at or near the land surface in southern Washington County.

19 Hydraulic conductivity data for unconsolidated Quaternary deposits was collected by Tipping et al.
 20 (2010) and includes laboratory permeameter, slug, specific capacity, and higher-capacity aquifer tests
 21 (Table B.4). The scale of the test is generally related to sediment size. Slug tests are the upper limit for
 22 field measurement of fine-grained sediment, while large-scale aquifer tests are typically conducted in
 23 sand and gravel aquifers. Vertical hydraulic conductivity in fine-grained sediment is typically measured in
 24 a laboratory.

25 **Table B.4. Horizontal hydraulic conductivity (Kh) and vertical hydraulic conductivity (Kv) ranges for**
 26 **Quaternary textures.**

Texture	Method	Number of samples	Mean	Minimum	Maximum	Geomean
Horizontal hydraulic conductivity (feet/day)						
Loam, silt rich, silt and clay	Grain size	79	3.45E-01	8.57E-03	3.35E+00	1.39E-01
	Slug test	7	1.43E-02	7.65E-05	9.35E-02	7.74E-04
Loam to clay loam	Grain size	1,155	2.37E-01	2.83E-05	5.45E+00	9.64E-02
	Slug test	17	3.87E-01	5.67E-04	3.83E+00	2.80E-02
Loam to sandy loam	Grain size	325	1.26E+00	2.78E-03	1.42E+01	5.70E-01
	Slug test	34	2.27E+00	2.83E-03	4.30E+01	2.00E-01
Sandy silt	Grain size	38	5.65E-01	1.42E-04	1.13E+01	2.42E-02
	Slug test	18	2.49E+01	1.40E-01	1.50E+02	5.54E+00
Fine sand	Grain size	32	4.81E+00	5.84E-05	3.69E+01	1.61E-01
	Slug test	14	3.91E+00	1.42E-03	2.61E+01	5.11E-01
	Grain size	168	5.47E+01	2.83E-02	3.09E+02	1.92E+01

Texture	Method	Number of samples	Mean	Minimum	Maximum	Geomean
Sand and gravel	Laboratory permeameter	3	2.34E+00	4.30E-01	4.50E+00	1.60E+00
	Aquifer test	118	1.17E+02	4.82E-01	4.15E+02	6.53E+01
	Slug test	215	3.98E+01	5.00E-03	5.40E+02	8.07E+00
	Specific capacity	17	4.07E+01	1.50+00	1.52E+02	2.66E+01
Vertical hydraulic conductivity (feet/day)						
Loam, silt rich, silt and clay	Laboratory permeameter (falling head)	4	1.94E-04	6.80E-05	3.97E-04	1.55E-04
Loam to clay loam	Laboratory permeameter (constant head)	17	1.68E-01	6.24E-05	2.83E+00	7.26E-04
	Laboratory permeameter (falling head)	37	7.14E-02	2.83E-06	1.98E+00	2.19E-04
Loam to sandy loam	Laboratory permeameter (falling head)	14	2.45E-01	1.98E-05	3.40E+00	9.81E-04
Sandy silt	Laboratory permeameter (constant head)	9	8.55E-01	8.50E-04	5.67E+00	8.88E-02
	Laboratory permeameter (falling head)	31	1.07E-01	9.35E-06	1.64E+00	1.73E-03
Fine sand	Laboratory permeameter (constant head)	2	1.70E+00	1.50E+00	1.90E+00	1.69E+00
	Laboratory permeameter (falling head)	1	2.35E-01	2.35E-01	2.35E-01	2.35E-01
Sand and gravel	Laboratory permeameter (falling head)	4	4.27E-01	6.80E-03	1.13E+00	1.22E-01
	Aquifer test	3	6.76E+01	7.00E-01	1.01E+02	1.93E+01

1 Source: Tipping et al., 2010.

2
3 Tipping et al. (2010) noted a potential relationship between hydraulic conductivity and burial depth in
4 fine-grained sediment. Local, site-specific slug tests conducted in till showed decreasing hydraulic
5 conductivity values with increasing burial depth. Visual observation of the till showed an upper,
6 fractured, oxidized zone; and a lower, less-fractured, unoxidized zone. However, when evaluating all the
7 data together, Tipping et al. (2010) did not observe a strong correlation between depth and hydraulic
8 conductivity. Instead, the poor correlation was attributed to several factors that would obscure a

1 correlation between depth and hydraulic conductivity such as a uniform fracture network regardless of
 2 depth, relatively thinner till deposits with depth, and a wide variety of till textures in the Twin Cities
 3 Metropolitan Area.

4 **B.3 Groundwater recharge**

5 Groundwater recharge primarily occurs from precipitation. However, surface water features can provide
 6 a source of water to Quaternary and bedrock aquifers as well.

7 **B.3.1 Precipitation**

8 Precipitation that infiltrates the ground surface and reaches the water table is the primary source of
 9 recharge to the groundwater flow system. Groundwater recharge from precipitation varies spatially
 10 across the Study Area depending on land cover, evapotranspiration, and hydraulic properties of the soil
 11 or bedrock. The amount and distribution of recharge is difficult to quantify on a regional scale, and
 12 recharge rates used in groundwater flow models are often assumed as a percentage of precipitation and
 13 adjusted during model calibration. Previous groundwater modeling efforts for the Twin Cities
 14 Metropolitan Area have used the USGS soil water balance (SWB) code to establish a spatial distribution
 15 of recharge from precipitation and temperature. The SWB uses geographic information system (GIS)
 16 compatible rectangular grids with user-defined data, including (1) climate data, (2) land-use
 17 classification, (3) hydrologic soil group, (4) flow direction, and (5) soil-water capacity to calculate spatial
 18 and temporal variations in groundwater recharge (Westenbroek et al., 2010). As the name implies, the
 19 SWB uses a soil-water balance approach that consists of the following components:

20 **Sources**

- 21 • Daily precipitation
- 22 • Daily snowmelt (based on temperature)
- 23 • Inflow (surface runoff that is routed to downslope grid cells using a digital elevation model).

24 **Sinks**

- 25 • Interception (precipitation that is trapped at the land surface and evaporated or used by plants)
- 26 • Outflow (surface runoff)
- 27 • Evapotranspiration (requiring climate data such as daily minimum and maximum air
 28 temperatures)
- 29 • Change in soil moisture (change in the amount of water stored in the soil for a given grid cell).

30 Detailed documentation for the SWB model including all required input parameters, equations, and
 31 methods used to calculate each component are found in Westenbroek et al. (2010).

32 The DNR (2019i) provided Wood with SWB input and output files for simulations run between 1999 and
 33 2018. The SWB domain is a rectangular area that covers the Northeast Metro Lakes Groundwater-Flow
 34 (NMLG) model domain. With the exception of surface water features, annual recharge rates range
 35 between less than 1 to greater than 20 inches in 2018 (Figure B.9). Surface water features that were
 36 assigned an open-water land cover type in the SWB model have a recharge value of zero (i.e., does not
 37 allow recharge to groundwater).

38 **B.3.2 Surface water sources**

39 Rivers, lakes, streams, and wetlands are also potential sources of recharge depending on surface water
 40 elevation relative to the position of the water table. Water chemistry data for Washington County

1 suggest that many of the lakes throughout the county are sources of recharge with the exception of
2 lakes in the northwest, which tend to be more isolated because of an underlying low-permeability layer
3 (Berg, 2019). Surface water bodies that have a water elevation higher than the adjacent water table
4 elevation will be a source of recharge to the aquifer. The amount of recharge is affected by the lakebed
5 conductance and hydraulic conductivity of the receiving formation. During periods of high river stage,
6 water may percolate laterally from a river into the adjacent aquifer (bank storage), which may in turn
7 percolate back into the river as it returns to normal or low-flow conditions. Unlike bank storage that
8 occurs during periods of high stage, recharge from lakes may be sustained over long periods of time.
9 Lake gages are located throughout the Study Area and provide current and/or historical water-level
10 measurements (Figure B.10). Based on lake bathymetry data, most of the lakes overlie glacial deposits.
11 However, deeper lakes in the Study Area extend closer to bedrock, such as White Bear Lake, which may
12 be less than 50 feet above bedrock in the deepest portion of the lake (Berg, 2019).

13 Surface water elevations at White Bear Lake and adjacent groundwater elevations are shown in
14 Figure B.11 for a 15-year period (2003–2018). In this example, groundwater in Quaternary glacial
15 deposits mimic lake surface water elevations. Lake water levels and groundwater elevations are
16 decreasing between 2003 and 2012, and increasing between 2013 and 2018. This same general trend is
17 seen in the Prairie du Chien; however, water-level fluctuations are more pronounced, perhaps as a
18 response to pumping from nearby wells. Based on data provided by the DNR, annual precipitation was
19 below normal between 2003 and 2012 (with the exception of annual precipitation for 2005, 2007, and
20 2010), as shown in Figure B.11. The DNR used a gridding procedure to harmonize observations from a
21 dense portion of their high-density precipitation gage network and the data presented in Figure B.11 are
22 representative of the Study Area. However, local variations, such as in White Bear Lake, have occurred
23 (DNR, 2018a, 2018b). In general, precipitation at White Bear Lake was exceptionally high in 2002 (45
24 inches) and below normal from 2006 to 2012 (with the exception of annual precipitation for 2010 and
25 2011). The decline in White Bear Lake water levels between 2003 and 2012 is attributed to long-term
26 well pumping in the vicinity of the lake and a period of below-normal precipitation (Jones et al., 2013;
27 S.S. Papadopulos and Associates, 2017; DNR, 2018a, 2018b; Berg, 2019). Annual precipitation between
28 2013 and 2018 was at or above normal annual precipitation and, as a result, lake levels increased during
29 this period (Berg, 2019).

30 The impact on lake levels and volume from groundwater withdrawal in the vicinity of White Bear Lake
31 (within five miles) has been evaluated using the transient NMLG model (S.S. Papadopulos and
32 Associates, 2017; DNR, 2018a, 2018b). The results of these efforts have demonstrated some influence
33 on lake levels from nearby pumping; however, the magnitude of response depends on several factors
34 such as the pumping rate, the distance to the lake, and the aquifer being utilized. Additionally, the
35 adverse effects noted are largely a result of pumping from a small number of permitted wells that
36 appear to have a dominant influence on the lake (S.S. Papadopulos and Associates, 2017). Recent
37 modeling efforts have also shown that while current groundwater use complies with Minnesota’s
38 sustainability standard, current pumping continues to contribute to water levels falling below the
39 protective elevation for White Bear Lake (DNR, 2018a).

40 During the same 15-year period, White Bear Lake surface water elevations were generally observed to
41 be higher-than-measured adjacent groundwater elevations, indicating that the groundwater system is
42 receiving net recharge from the lake. Additional studies conducted at White Bear Lake also suggest that
43 the lake is a source of net recharge to groundwater and indicate that the lake is hydraulically connected
44 to the Prairie du Chien aquifer (uppermost bedrock aquifer). It was also shown, however, that
45 groundwater is discharging to the lake along parts of the lake shore (Jones et al., 2013, 2016).

1 **B.4 Groundwater discharge**

2 Water is removed from the groundwater flow system by pumping wells, lakes, major rivers, and smaller
3 streams. Groundwater discharge can also occur from evapotranspiration at springs along bedrock
4 outcrops; and at wetlands along lakes, rivers, and streams. A discussion of discharge from wells, lakes,
5 and rivers is provided below.

6 **B.4.1 Pumping wells**

7 Groundwater is the primary source of potable water for about three-quarters of the population in the
8 Twin Cities Metropolitan Area. In addition to being the primary potable water supply, pumping wells are
9 used to extract groundwater for a variety of purposes, including industrial/commercial, agricultural,
10 construction, and hydraulic control at landfills/waste sites.

11 Annual withdrawal from all pumping wells (commercial, municipal, industrial, agricultural, and
12 construction) within the Study Area were obtained from the DNR (2019b). The pumping wells were
13 filtered so that only wells pumping greater than 10 million gallons per year were evaluated. Locations of
14 high capacity wells in the Easter Metropolitan Area are shown in Figure B.12. A plot of combined
15 Washington County withdrawal from all high-capacity wells and combined withdrawal from seven East
16 Metropolitan Area municipalities (i.e., Cottage Grove, Lake Elmo, Lakeland, Newport, Oakdale, St. Paul
17 Park, and Woodbury) for a 30-year period is shown in Figure B.13a. The overall trend in withdrawal over
18 time is primarily driven by municipal wells, with most of the withdrawal coming from Woodbury,
19 Cottage Grove, and Oakdale. A significant increase in pumping occurs in the 1990s and early 2000s,
20 which corresponds to a population growth in Washington County during that time (Figure B.13b).
21 Pumping from high-capacity wells peaks in 2007 and then appears to level off or decrease in the past
22 decade (with the exception of 2012). Bedrock aquifers (particularly the Jordan) are heavily utilized in
23 Washington County. Quaternary aquifers are also used but to a lesser extent. The Jordan Sandstone and
24 Quaternary aquifers saw an increase in total gallons extracted between 1988 and 2018, while pumping
25 in the Mt. Simon and Prairie du Chien aquifers has steadily decreased during the same time period.

26 **B.4.2 Baseflow**

27 Natural sustained flow of a stream (i.e., baseflow) in the absence of run-off is largely due to
28 groundwater discharge. Net baseflow at Valley and Browns creeks in Washington County was estimated
29 by the DNR (2019c). Baseflow estimates from data recorded in 2016, 2017, and 2018 at three gaging
30 stations are summarized in Table B.5.

Table B.5. Stream baseflow in Valley Creek and Browns Creek.

Year	2016	2017	2018
Station 37067001 (Valley Creek at Afton)			
Average flow (cfs)	4.8	5.1	NA
Estimated average baseflow (cfs)	4.8	5.0	NA
Station VA0010 (Valley Creek at Putman Boulevard)			
Average flow (cfs)	20	22	19
Estimated average baseflow (cfs)	20	22	18 to 19
Station BR0003 (Browns Creek and Dellwood Road)			
Average flow (cfs)	8.8	8.8	8.5
Estimated average baseflow (cfs)	6.1 to 7.2	6.7 to 7.7	6.2 to 7.2

31 cfs = cubic feet per second.

32

1 Additionally, the Washington County Conservation District gaged streamflow at Trout Brook (near the
2 mouth) between April and October in years 2004 through 2006. During this period, baseflow varied from
3 less than 1 cubic feet per second (estimated from August 2004 streamflow) and 4.5 cubic feet per
4 second (estimated from May and June 2004). Baseflow typically ranged between 1 and 2.5 cubic feet
5 per second during this period (Emmons & Oliver Resources, 2009).

6 **B.4.3 Lakes**

7 Lakes can be points of discharge, which is particularly the case with lower-elevation lakes. When
8 groundwater elevations are higher than lake elevations, the lake receives discharge from the adjacent
9 aquifer. For example, water levels measured at Lake Isabelle, near Hastings, are generally lower than
10 water table elevations measured at an adjacent observation well between 2003 and 2018 (Figure B.14).
11 Periodically, this relationship is reversed (i.e., during periods of high lake levels). The water table
12 fluctuates with lake elevations and there appears to be an increase in both between 2015 and 2018. It is
13 important to note that surface water features determined to be points of discharge can also serve as
14 points of recharge and provide water to the groundwater flow system when the elevation of
15 groundwater drops below that of the water body, and surface water features determined to be a source
16 of recharge can also be points of discharge when water body elevations drop below groundwater
17 elevations. The amount of flow or surface water-groundwater exchange is controlled by the hydraulic
18 conductivity and thickness of lakebed sediment.

19 **B.5 Groundwater flow**

20 Groundwater levels measured at DNR observation wells that are constructed in glacial or bedrock
21 aquifers were plotted and compared to precipitation and pumping data. Many of the wells showed an
22 increasing trend in groundwater levels within the past decade until approximately 2016. This may be in
23 part due to an increase in precipitation; however, this may also be related to pumping.

24 Bedrock potentiometric surfaces generated by Sanocki et al. (2009) are shown in Figures B.15a–c. The
25 aquifers were grouped as follows:

- 26 1. Mt. Simon-Hinckley
- 27 2. Wonewoc Sandstone and Tunnel City Group
- 28 3. Jordan Sandstone and Prairie du Chien Group.

29 Elevations shown on Figures B.15a–c represent elevations where groundwater would rise in a tightly
30 cased well. Groundwater flow occurs from higher-to-lower elevations perpendicular to potentiometric
31 surface contours. The potentiometric maps of all aquifers in Washington County show that groundwater
32 in bedrock aquifers (with exception of Mt. Simon) generally flows south-southwest toward the
33 Mississippi River or east toward the St. Croix River from the elongated north-south groundwater high
34 area in northern Washington County, as shown in Figure B.16.

35 The potentiometric surface for the Mt. Simon Sandstone aquifer is affected by a regional cone of
36 depression in the Metropolitan Area (Figure B.15a). The cone of depression is presumably an effect of
37 long-term, high-capacity pumping from the aquifer (Berg and Pearson, 2013).

38 Groundwater elevations in the Prairie du Chien are in many areas above the top of bedrock, indicating
39 that groundwater is confined. However, unconfined conditions in the Prairie du Chien were also
40 observed (Figure B.17). Groundwater elevations measured in a Prairie du Chien observation well at
41 Cottage Grove [Minnesota Well Index (MWI) number 817790] between 2017 and 2019 are below the

1 top of bedrock. The well is located along the Mississippi River, where regional groundwater discharge
 2 occurs. Areas of shallow depths to bedrock and bedrock aquifers overlain by large bodies of sand and
 3 gravel (such as in deep bedrock valleys) tend to be under unconfined conditions, as supported by
 4 calculated short travel times and water chemistry data (Tipping, 2011). Groundwater flow is enhanced
 5 by secondary porosity (fracture flow and/or dissolution) in shallow bedrock. Although groundwater flow
 6 is primarily horizontal, vertical gradients occur at high-capacity wells, areas of regional discharge, and in
 7 bedrock confining units.

8 Due to the complex nature of glacial deposits, groundwater flow in buried sands and gravels are not
 9 depicted on a potentiometric map. Shallow unconfined groundwater flow generally follows surface
 10 topography and is toward major rivers. In Washington County, the water table ranges between 0 and
 11 20 feet below ground surface (bgs) in the northwest, 0 to 40 ft bgs in the central part of the county, and
 12 greater than 50 feet bgs in proximity to the Mississippi and St. Croix rivers (Berg, 2019). According to
 13 Berg (2019), groundwater flow through unconsolidated deposits in Washington County generally occurs
 14 as follows:

- 15 1. Laterally through unconsolidated deposits from areas of recharge to areas of discharge areas (at
- 16 surface water bodies)
- 17 2. Vertically from unconsolidated surficial aquifers to buried unconsolidated aquifers
- 18 3. Vertically from surficial or buried aquifers to an underlying bedrock aquifer.

19 **B.6 PFAS source areas and groundwater sampling results**

20 Four source areas for PFAS contamination in the East Metropolitan Area groundwater were identified by
 21 the MPCA and MDH: 3M Cottage Grove Disposal Sites, the 3M Woodbury Disposal Site, the Oakdale
 22 Disposal Site, and the Washington County Landfill (Figures B.18a–c). There is also evidence suggesting
 23 the large flood control project conducted by the Valley Branch Watershed District, known as Project
 24 1007, may have contributed to the distribution of PFAS. Raleigh Creek is one of the surface water bodies
 25 that conveys water from the Tri-Lakes area to the St. Croix River as a part of this project. Raleigh Creek
 26 flows through the former Oakdale disposal site, potentially conveying PFAS-impacted water to locations
 27 downstream where it may have mixed with groundwater.

28 Groundwater samples were collected from drinking water wells throughout the East Metropolitan Area,
 29 as well as greater Minnesota, and analyzed for PFAS. Results of the groundwater samples were
 30 compared to the health index (HI) values. Drinking water wells with HI values greater than 1.0 are
 31 considered an exceedance and the well is subject to a well advisory. MDH provided a dataset containing
 32 the most recent PFAS results for each private drinking water well sampled. Not all the wells were
 33 assigned a HI value in the MDH-provided dataset; therefore, a column titled “Wood HI” (Wood Health
 34 Index) was created to fill in the missing HIs where possible. The Wood HI was calculated using the same
 35 HI calculation used by MDH: the sum of the PFAS constituent concentrations (in parts per billion) divided
 36 by their respective (most conservative) health-based value (HBV) or health risk limit (HRL), as shown
 37 below.

$$38 \quad \text{Wood HI} = ((\text{PFOA}/0.035) + (\text{PFOS}/0.015) + (\text{PFBA}/7) + (\text{PFBS}/2) + (\text{PFHxS}/0.047)).$$

39 A subset of MDH wells within and slightly beyond the 14 affected East Metropolitan Area communities
 40 were selected for review during the preparation of this Conceptual Plan. In total, 3,320 wells in the
 41 selected extent were sampled for PFAS by MDH and 1,304 samples exceeded the HI value. The Wood HI

1 values were plotted for the East Metropolitan Area wells and are presented in Figures B.17a–c with
 2 applicable cross-sections. The wells were divided into five categories (Table B.6) based on the
 3 percentage of the HI or Wood HI:

4 **Table B.6. HI values.**

Value	Percent of HI value
0.0000–0.25000	Non-detect to 25%
0.25001–0.50000	> 25 to 50%
0.50001–0.75000	> 50 to 75%
0.75001–1.00000	> 75 to 100%
> 1.00000	> 100%

5
 6 Most of the samples exceeding the HI or Wood HI were in the Jordan, Prairie du Chien, and St. Peter
 7 aquifer grouping. A complete list of exceedances by aquifer is presented in Table B.7. Residential wells
 8 exceeding the HI were generally located downgradient of the four PFAS source areas. Remediation wells
 9 now largely provide hydraulic control of the groundwater migration around the four source areas. A
 10 remedial investigation to determine the nature and extent of these source areas has not been
 11 conducted.

12 **Table B.7. HI exceedances by aquifer.**

Aquifer grouping	Total number of wells exceeding the HI
Eau Claire	2
Jordan, Prairie du Chien, St. Peter	791
Mt. Simon	0
Platteville	3
Quaternary	100
St. Lawrence	0
Unknown ^a	396
Tunnel City-Wonewoc	9

13 a. The Unknown aquifer group represents wells with either no well log or no information in MWI.

14 **B.7 Data gaps**

15 A great deal of work has been accomplished by others in characterizing the geology and hydrogeology of
 16 the East Metropolitan Area. This work includes (but is not limited to):


- 17 • Detailed mapping of lithostratigraphic units
- 18 • Defining and characterizing hydrostratigraphic units
- 19 • Generating potentiometric surfaces
- 20 • Estimating groundwater recharge and residence times
- 21 • Evaluating groundwater and surface water exchanges
- 22 • Conducting steady-state and transient groundwater flow modeling
- 23 • Evaluating groundwater and surface water chemistry data.

24 Much of this work has been done on a regional scale where localized heterogeneities are difficult to
 25 capture.

- 1 Although site-specific data are available, some amount of simplification is necessary when building a
2 groundwater flow model as data gaps are inherent on both regional and local scales. Data gaps include:
- 3 • Heterogeneities within hydrostratigraphic units (particularly in glacial deposits and areas of
4 fractured bedrock or karst development)
 - 5 • Limitations related to the SWB model, and aerial recharge and runoff estimates
 - 6 • Surface water elevations where not gaged
 - 7 • Bottom elevations of rivers, lakes, and streams where bathymetry data are not available
 - 8 • River and lakebed conductance
 - 9 • Amount of leakage from surface water bodies
 - 10 • Limited baseflow calculations
 - 11 • Limited vertical and spatial distribution of calibration targets
 - 12 • Limited PFAS plume nature and extent of understanding
 - 13


DRAFT

1 **Figure B.1. Location of the Study Area.**




2
3 Background imagery service layer credits: Esri, Garmin, GEBCO, National Oceanic and Atmospheric
4 Administration (NOAA) National Geophysical Data Center (NGDC), and other contributors.
5

1 **Figure B.2. Land use.**




2
 3 Background imagery service layer credits: Esri, Garmin, GEBCO, NOAA NGDC, and other
 4 contributors.

1 **Figure B.3. Annual precipitation by decade.**




2

1 **Figure B.4. Structural setting.**




- 2
- 3 Background imagery service layer credits: Esri, Garmin, GEBCO, NOAA NGDC, and other
- 4 contributors.

1 **Figure B.5. Paleozoic bedrock geology in the Twin Cities Metropolitan Area.**




- 2
- 3 Background imagery service layer credits: Esri, Garmin, GEBCO, NOAA NGDC, and other
- 4 contributors.

1 Figure B.6. Representative stratigraphic column for Paleozoic bedrock.




2

1 **Figure B.7. Global lobe source areas.**




2

1 Figure B.8a. Generalized surficial geology map.




2

1 **Figure B.8b. Quaternary thickness.**



2


1 **Figure B.9. Recharge in 2018 for Washington County (inches/year).**



2


3 Background imagery service layer credits: Esri, GEBCO, NOAA, National Geographic, Garmin,
4 HERE, Geonames.org, and other contributors.

1 **Figure B.10. Location of surface water gages.**




2
3 Background imagery service layer credits: Esri, Garmin, GEBCO, NOAA NGDC, and other
4 contributors.

1 **Figure B.11. Surface water elevations at White Bear Lake, and Quaternary and Prairie du Chien**
 2 **groundwater elevations measured at adjacent observation wells.**




3

1 Figure B.12. Map showing locations of high capacity wells (greater than 10 million gallons per year) in
2 the East Metropolitan Area.




3

1 **Figure B.13. A) Total groundwater pumped from municipal water supply wells for seven municipalities**
 2 **(Cottage Grove, Lake Elmo, Lakeland, Newport, Oakdale, St. Paul Park, and Woodbury), and**
 3 **B) Washington County population data.**




4

1 **Figure B.14. Lake Isabelle water levels and water table elevation measured in an adjacent observation well.**
2 **well.**




3

1 Figure B.15a. Average 2017 potentiometric surfaces for Mt. Simon Sandstone.




2
3

1 Figure B.15b. Average 2017 potentiometric surfaces for Wonewoc Sandstone and Tunnel City Group.




2
3

1 Figure B.15c. Average 2017 potentiometric surfaces for Jordan and Prairie Du Chien aquifers.




2

1 **Figure B.16. Washington County potentiometric elevation in Prairie du Chien and Jordan bedrock aquifers (Berg, 2019).**
2




3
4
5

1 **Figure B.17. Groundwater elevation measured in Prairie du Chien and Mt. Simon observation wells at**
 2 **Cottage Grove (MWI unique well numbers 817790 and 789735).**



3
4


1 Figure B.18a. Cross-section locations with PFAS source areas and HI values from wells.



2


3 Background imagery service layer credits: Esri, GEBCO, NOAA, National Geographic, Garmin,
4 HERE, Geonames.org, and other contributors.

1 **Figure B.18b. Cross-section locations with PFAS source areas and HI values from wells (cont.).**



2

1 **Figure B.18c. Cross-section locations with PFAS source areas and HI values from wells (cont.).**



2
3



1 **References**

- 2 Baker, D.G., E.L. Kuehnast, and W.W. Nelson. 1979. Climate of Minnesota Part XII – The Hydrologic Cycle
3 and Soil Water: Climate of Minnesota Series. Technical Bulletin 322, Minnesota Department of Natural
4 Resources. Available: <https://files.dnr.state.mn.us/>. Accessed August 2019.
- 5 Balaban, N.H. and H.C. Hobbs. 1990. C-06 Geologic Atlas of Dakota County, Minnesota: Minnesota
6 Geological Survey, University of Minnesota Digital Conservancy. Available:
7 <http://hdl.handle.net/11299/58494>. Accessed April 2019.
- 8 Bauer, E.J., R.S. Lively, G.N. Meyer, A.J. Retzler, and J.R. Steenberg. 2016. C-39, Geologic Atlas of
9 Washington County, Minnesota, Minnesota Geological Survey, University of Minnesota Digital
10 Conservancy. Available: <http://hdl.handle.net/11299/178852>. Accessed April 2019.
- 11 Berg, J.A. 2019. Groundwater Atlas of Washington County, Minnesota, Minnesota Department of Natural
12 Resources (MNDNR), County Atlas Series C-39, Part B, Report and Plates 7–9. Available:
13 https://www.dnr.state.mn.us/waters/programs/gw_section/mapping/platesum/washcga.html.
14 Accessed April 2019.
- 15 Berg, J.A. and S.R. Pearson. 2013. South-Central Minnesota Groundwater Monitoring of the Mt. Simon
16 Aquifer – Phase 2, MDNR, Ecological and Water Resources Division, St. Paul, Minnesota. Available:
17 https://files.dnr.state.mn.us/publications/waters/south_central_mn_gw_monitoring_phase2.pdf.
18 Accessed April 2019.
- 19 Chandler, V.W., B.A. Bloomgren, M.C. Pettus, A.C. Runkel, D.D. Hougardy, G.N. Meyer, and
20 J.D. Hamilton. 2017. C-44, Geologic Atlas of Isanti County, Minnesota. Minnesota Geological Survey,
21 University of Minnesota Digital Conservancy. Available: <http://hdl.handle.net/11299/192515>. Accessed
22 April 2019.
- 23 DNR. 2019a. Annual and Monthly Precipitation Data (1891–2018). Minnesota Department of Natural
24 Resources. Written communication.
- 25 DNR. 2019b. Annual Pumping Volumes for East Metropolitan Area. Minnesota Department of Natural
26 Resources. Written communication.
- 27 DNR. 2019c. Baseflow estimates. Minnesota Department of Natural Resources. Written communication.
- 28 DNR. 2019d. Lake Bathymetric Outlines, Contours, Vegetation, and EMD: MNDNR. Minnesota
29 Department of Natural Resources. Available: <https://gisdata.mn.gov/dataset/water-lake-bathymetry>.
30 Accessed June 2019.
- 31 DNR. 2019e. Minnesota Cooperative Groundwater Monitoring. Minnesota Department of Natural
32 Resources. Available: <https://www.dnr.state.mn.us/waters/cgm/index.html>. Accessed April 2019.
- 33 DNR. 2019f. MNDNR Lake Finder. Minnesota Department of Natural Resources. Available:
34 <https://www.dnr.state.mn.us/lakefind/index.html>. Accessed June 2019.
- 35 DNR. 2019g. MNDNR Transient NMLG Model. Minnesota Department of Natural Resources. Written
36 communication.
- 37 DNR. 2019h. MNTopo: MNDNR, 3-Meter Digital Elevation Model. Minnesota Department of Natural
38 Resources. Available: <http://arcgis.dnr.state.mn.us/maps/mntopo/>. Accessed June 2019.

- 1 DNR. 2019i. SWB Model Input and Output Files. Minnesota Department of Natural Resources. Written
2 communication.
- 3 DNR. 2018a. Modeling Analysis Required by Ramsey County District Court Order 62-CV-13-2414, Parts
4 3.A and 3.C). Minnesota Department of Natural Resources. Available: <https://www.dnr.state.mn.us/>.
5 Accessed February 2020.
- 6 DNR. 2018b. Transient NMLG Model Analysis and Revisions. Minnesota Department of Natural
7 Resources. Available: <https://www.dnr.state.mn.us/gwmp/area-ne-model.html>. Accessed April 2019.
- 8 Emmons & Olivier Resources. 2009. Trout Brook Management Plan: report prepared for the
9 Lower St. Croix Watershed Management Organization by Emmons & Olivier Resources, Inc.
- 10 Freeze. R.A. and J.A. Cherry. 1979. *Groundwater*. Prentice Hall, Upper Saddle River, NJ.
- 11 Jones, P.M., J.J. Trost, D.O. Rosenberry, P.R. Jackson, J.A. Bode, and R.M. O’Grady. 2013. Groundwater
12 and Surface-Water Interactions near White Bear Lake, Minnesota, through 2011. U.S. Geological Survey,
13 Scientific Investigations Report 2013-5044.
- 14 Jones, P.M., J.J. Trost, A.L. Diekoff, D.O. Rosenberry, E.A. White, M.L. Erickson, D.L. Morel, and J.M. Heck.
15 2016. Statistical Analysis of Lake Levels and Field Study of Groundwater and Surface-Water Exchanges in
16 the Northeast Twin Cities Metropolitan Area, Minnesota, 2002 through 2015. U.S. Geological Survey
17 Scientific Investigations Report 2016–5139– A. Available: <http://dx.doi.org/10.3133/sir20165139A>.
18 Accessed April 2019.
- 19 MDH. 2019. Minnesota Well Index (MWI). Minnesota Department of Health. Available:
20 <https://www.health.state.mn.us/communities/environment/water/mwi/index.html>. Accessed May
21 2019.
- 22 Metropolitan Council. 2019. Metro Model 3, Metropolitan Council. Available:
23 <https://metrocouncil.org/Wastewater-Water/Planning/Water-Supply-Planning/Metro-Model-3.aspx>.
24 Accessed April 2019.
- 25 Meyer, G.N. and L. Swanson. 1992. C-07 Geologic Atlas of Ramsey County, Minnesota, Minnesota
26 Geological Survey. University of Minnesota Digital Conservancy. Available:
27 <http://hdl.handle.net/11299/58233>. Accessed April 2019.
- 28 MNIT. 2019. Minnesota Land Use/Cover. Minnesota IT Service. Available:
29 https://www.mngeo.state.mn.us/chouse/land_use_recent.html. Accessed July 2019.
- 30 Mossler, J.H. 2008. RI-65 Paleozoic Stratigraphic Nomenclature for Minnesota: Minnesota Geological
31 Survey, University of Minnesota Digital Conservancy. Available: <http://hdl.handle.net/11299/58940>.
32 Accessed April 2019.
- 33 Mossler, J.H. 2013. Bedrock Geology of the Twin Cities Ten-County Metropolitan Area, Minnesota,
34 University of Minnesota Digital Conservancy. Available: <http://hdl.handle.net/11299/154925>. Accessed
35 April 2019.
- 36 MPCA. 2019a. Groundwater Sample Data. Minnesota Pollution Control Agency. Written communication.
- 37 MPCA. 2019b. PFAS Source Areas. Minnesota Pollution Control Agency. Written communication.

- 1 Runkel, A.C., J.H. Mossler, R.G. Tipping, and E.J. Bauer. 2006. A Hydrogeologic and Mapping Investigation
2 of the St. Lawrence Formation in the Twin Cities Metropolitan Area: University of Minnesota, University
3 of Minnesota Digital Conservancy. Available: <http://hdl.handle.net/11299/108892>. Accessed April 2019.
- 4 Runkel, A.C., R.M. McKay, T.H. Shaw, and E.J. Bassett. 1998. Origin of a classic Cratonic Sheet Sandstone:
5 Stratigraphy across the Sauk II-Sauk III Boundary in the Upper Mississippi Valley. *Geologic Society of*
6 *America Bulletin* 110:188–210.
- 7 Runkel, A.C., R.G. Tipping, E.C. Alexander Jr., J.A. Green, J.H. Mossler, and S.C. Alexander. 2003.
8 Hydrogeology of the Paleozoic Bedrock in Southeastern Minnesota, Minnesota Geological Survey Report
9 of Investigations 61.
- 10 Sanocki, C.A., S.K. Langer, and J.C. Menard. 2009. Potentiometric Surfaces and Changes in Groundwater
11 Levels in Selected Bedrock Aquifers in the Twin Cities Metropolitan Area, March–August 2008 and 1988–
12 2008. U.S. Geological Survey Scientific Investigations Report 2009-5226.
- 13 Schoenberg, M. 1990. Effects of Present and Projected Ground-Water Withdrawals on the Twin Cities
14 Aquifer System, Minnesota. Water-Resources Investigations Report 90-4001. United States Geological
15 Survey.
- 16 Setterholm, D.R. 2010. C-22 Geologic Atlas of Chisago County, Minnesota [Part A]. Minnesota Geological
17 Survey, University of Minnesota Digital Conservancy. Available: <http://hdl.handle.net/11299/93861>
18 Accessed April 2019.
- 19 Setterholm, D.R. 2013. C-27 Geologic Atlas of Anoka County, Minnesota [Part A]. Minnesota Geological
20 Survey, University of Minnesota Digital Conservancy. Available: <http://hdl.handle.net/11299/116119>.
21 Accessed April 2019.
- 22 S.S. Papadopoulos and Associates. 2017. Development of a Transient Version of the Northeast Metro
23 Lakes Groundwater-Flow (NMLG) Model – with Simulation and Calibration from 1980 through 2016.
24 Prepared for Minnesota Department of Natural Resources. October.
- 25 Steenberg, J.R. and A.J. Retzler. 2016. Depositional Trends of the Prairie du Chien Group (Lower
26 Ordovician) along the Western Edge of the Twin Cities Basin, Minnesota. Poster Abstract No. 275216.
- 27 Steenberg, J.R., E.J. Bauer, V.W. Chandler, A.J. Retzler, A.J. Berthold, and R.S. Lively. 2018. C-45, Geologic
28 Atlas of Hennepin County, Minnesota, Minnesota Geological Survey, University of Minnesota Digital
29 Conservancy. Available: <http://hdl.handle.net/11299/200919>. Accessed April 2019.
- 30 Tipping, R.G. 2011. Distribution of Vertical Recharge to Upper Bedrock Aquifers, Twin Cities
31 Metropolitan Area: Minnesota Geological Survey Report submitted to Metropolitan Council. November.
- 32 Tipping, R.G., A.C. Runkel, and C.M. Gonzalez. 2010. Geologic Investigation for Portions of the Twin
33 Cities Metropolitan Area: I. Quaternary/Bedrock Hydraulic Conductivity, II. Groundwater Chemistry:
34 Informal Report Delivered to the Metropolitan Council for Metropolitan Council Water Supply Master
35 Plan Development.
- 36 USGS. 2019a. National Hydrology dataset (NHD). U.S. Geological Survey. Available:
37 <https://www.usgs.gov/core-science-systems/ngp/national-hydrography>. Accessed June 2019.
- 38 USGS. 2019b. NMLG Model. U.S. Geological Survey. Available:
39 <https://pubs.er.usgs.gov/publication/sir20165139B>. Accessed May 2019.

- 1 Westenbroek, S.M., V.A. Kelson, W.R. Dripps, R.J. Hunt, and K.R. Bradbury. 2010. SWB – a modified
- 2 Thornthwaite-Mather Soil-Water-Balance Code for estimating groundwater recharge. Chapter 31 of
- 3 Section A, *Groundwater*, of Book 6, *Modeling Techniques*. July.

DRAFT

Appendix C. Numerical model description and construction

1
2 Groundwater modeling was conducted to support the evaluation of scenarios in this Conceptual
3 Drinking Water Supply Plan (Conceptual Plan). The numerical groundwater flow model was developed to
4 support the evaluation of scenarios that address drinking water quantity and quality for the 14
5 communities currently known to be affected by per- and polyfluoroalkyl substances (PFAS)
6 contamination in the East Metropolitan Area, now and through 2040.

7 This appendix provides a summary of the groundwater model setup, calibration, and simulations
8 developed for the East Metropolitan Area. The conceptual site model provided in Appendix B was used
9 as the basis of the numerical groundwater model.

10 C.1 Introduction

11 C.1.1 Purpose and scope

12 The purpose of the groundwater model is to provide insight into the current groundwater flow system,
13 and predict impacts to flow paths and groundwater resources through the year 2040 from the proposed
14 scenarios. These flow paths and quantity estimates are based on projected groundwater
15 recharge/precipitation rates, surface water elevations, and pumping volumes of the proposed scenarios.
16 The year 2040 was selected because it was the time period for which there are population projections in
17 the comprehensive plans and/or water supply plans for each community, which determine drinking
18 water demand.

19 The objectives of the groundwater model are to:

- 20 5. Assess aquifer sustainability and viability of production rates for the proposed scenarios that may
21 involve changes in pumping rates and/or new water supply wells
- 22 6. Analyze contaminant flow paths under the different proposed scenarios and climate conditions to
23 determine the potential risk of PFAS contamination at existing and future wellfields
- 24 7. Evaluate potential impacts to groundwater resources in response to projected future groundwater
25 use under the different proposed scenarios and climate conditions
- 26 8. Communicate model results and technical issues (e.g., flow direction, impacts to current
27 remediation) internally and to stakeholders through visual representations of simulated flow
28 systems.

29 This groundwater model may also be used in the future to further evaluate projects as they are refined
30 following the development of this Conceptual Plan.

31 Results of the model predictions, as related to the objectives stated above, are provided in Appendix E
32 of this Conceptual Plan.

33 C.1.2 Data and sources

34 The data compiled for the groundwater model were selected in collaboration with several agencies,
35 local government units, and consultants, including the:

- 36 • Minnesota Pollution Control Agency
- 37 • Minnesota Geological Survey (MGS)

- 1 • Minnesota Department of Natural Resources (DNR)
- 2 • Minnesota Department of Health
- 3 • Metropolitan Council
- 4 • United States Geological Survey (USGS).

5 The data compiled and evaluated for the groundwater model are summarized in Table C.1.

6 **Table C.1. Data compiled for the groundwater model.**

Data	Source
3-meter digital elevation model (DEM)	DNR (2019f)
10-meter DEM	USGS (2019c, 2019d)
Lake bathymetry contours	DNR (2019d)
Bedrock elevation digital rasters	MGS (2019)
Surface water elevations at USGS gaging stations	USGS (2019b)
Surface water elevations at lake gaging stations	DNR (2019e)
Stream networks	USGS (2019a)
Potentiometric surfaces	Sanocki et al. (2009), Berg (2016)
Geologic maps for K zonation	Balaban and Hobbs (1990), Meyer and Swanson (1992), Setterholm (2010, 2013), Bauer et al. (2016), Tipping (2019)
Initial hydraulic conductivity estimates/ranges	Runkel et al. (2003), Tipping (2011), DNR (2020), MDH (2020)
Soil water balance (SWB) recharge	DNR (2019g)
Historical and current pumping volumes	DNR (2019a)
Groundwater elevations	DNR (2019c)
Baseflow estimates	DNR (2019b)
Effective porosity	Metropolitan Council (2019)

7 **C.1.3 Previous modeling efforts**

8 Previous groundwater modeling efforts near the current study area serve as a source for input
 9 parameters in this groundwater model in some instances (provided in Table C.2). These instances are
 10 discussed throughout this appendix.

1 **Table C.2. Summary of previous groundwater modeling efforts.**

Model	Additional information
Metro Model 3	<ul style="list-style-type: none"> • Developed to assist with regional water supply planning • Model domain includes an 11-county area in and around the Twin Cities Metropolitan Area • Grid has a uniform 500-meter x 500-meter cell size • Quasi-3D layers were used to represent confining units not explicitly included in the model (lower St. Peter Sandstone, lower Prairie Du Chien Group, and lower Tunnel City Group) • MODFLOW-NWT code was used for the simulation of groundwater flow • Accounts for temporal variations in aquifer stresses and changes in aquifer storage • SWB model was used to estimate recharge • Unsaturated Zone Flow package was used to simulate recharge in MODFLOW (i.e., a time lag between infiltration and recharge to the water table was accounted for during transient simulations)
Northeast Metro Lakes Groundwater-Flow Model	<ul style="list-style-type: none"> • Initially developed as a steady-state model by Jones et al. (2017) to assess groundwater and surface water exchanges, and the effects of groundwater withdrawals and precipitation on water levels of lakes in the northeast Twin Cities Metropolitan Area • Transient version of the model was developed by S.S Papadopoulos & Associates (2017) to help understand and meet the challenges of sustainable groundwater use, with a focus on White Bear Lake • Additional refinement was performed by the DNR (2018) to incorporate new and updated data • Borrows much from Metro Model 3 but with a finer grid (125 meters x 125 meters), additional layers, and updated model parameters • Includes water budget/levels for several lakes (Lake package)
South Washington County	<ul style="list-style-type: none"> • Last version was a local refinement of Metro Model 2, with transient pumping capability • Built to evaluate potential impact of Woodbury’s East Well Field on baseflow in Valley Creek • Parameter estimation to match a long-term pumping test
Minnesota Department of Health Wellhead Protection Areas	<ul style="list-style-type: none"> • Delineation of 10-year capture zones within pumped aquifer systems; some include surface drainage areas to vulnerable capture zones • Extent of some Wellhead Protection Areas defined by simple volume mapping technique for fractured aquifers • Local refinements of Metro Model 3 or other models

2 **C.2 Model description and discretization**

3 The groundwater model was developed and calibrated based on average 2016–2018 steady-
 4 state conditions using the three-dimensional control volume finite-difference groundwater flow
 5 code MODFLOW-USG Transport (Panday et al., 2013). The code was chosen because of the
 6 flexibility in the grid design around hydrologic boundaries and the ability to represent
 7 discontinuous layers. Additionally, faulted systems can be represented explicitly with
 8 MODFLOW-USG because of the model’s ability to assign cell connections between different

1 layers along faults. This allows for the continuity of flow between aquifers represented by
2 different layers that are juxtaposed along a fault.

3 The model was constructed using Groundwater Vistas version 7 (ESI, 2017), a graphical user
4 interface for the construction, simulation, and analysis of numerical groundwater flow models.
5 The software was used as a pre-and post-processor for the three-dimensional MODFLOW-USG
6 numerical model.

7 The model area contains the entire region shown in Figure C.1. Unlike previous finite-difference
8 MODFLOW codes that use a rectangular grid, the MODFLOW-USG (simplified to MODFLOW
9 elsewhere in this appendix) code uses an unstructured grid that can be fitted to an irregular
10 model boundary without having to inactivate cells outside the model domain. The model
11 domain was discretized (subdivided into smaller areas or cells) into a Voronoi polygon grid
12 using AlgoMesh (HydroAlgorithmics, 2016) and imported into Groundwater Vistas. Since the
13 grid is limited to 2 million nodes for particle tracking simulations, grid refinement was largely
14 constrained to the area of interest. This is evident in Figure C.2a, where the polygon cell sizes
15 vary from the smallest (most discrete) in southern Washington County and near features of
16 interest such as high-capacity wells and rivers, to the largest cell sizes in areas of less interest in
17 the model domain. In southern Washington County, the average polygon cell size is
18 approximately 100 meters (328 feet). In northern Washington County, the average polygon cell
19 size was increased to 500 meters (1,640 feet). In other areas, cell sizes are up to 1,200 meters
20 (3,937 feet), but refinement outside Washington County was applied around high-capacity
21 wells (greater than 10 million gallons per year) and along major rivers.

22 The top elevation of the model is land surface. The land surface in Minnesota was defined using
23 a 3-meter (10-feet) resolution DEM (DNR, 2019c). The land surface in Wisconsin was defined
24 using a USGS 10-meter (33-feet) resolution DEM (USGS, 2019c, 2019d). Bathymetry data for
25 several lakes in the model domain were provided by the DNR (2019d) and incorporated into the
26 DEM for accurate lake bottom elevations.

27 The grid was vertically discretized into 18 layers that represent the primary geologic units for
28 the area (Table C.3). Each of the layers, with exception of Layer 6, has a variable thickness.

Table C.3. Model layers.

Layer	Hydrostratigraphic unit
1 through 5	Quaternary sediments
6	Shallow bedrock
7	Platteville-Glenwood Confining Unit
8	St. Peter Sandstone Aquifer
9	Lower St. Peter Confining Unit
10	Prairie Du Chien (Shakopee) Aquifer
11	Prairie Du Chien (Oneota) Confining Unit
12	Jordan Sandstone Aquifer
13	St. Lawrence Confining Unit
14	Upper Tunnel City Aquifer

15	Lower Tunnel City Confining Unit
16	Wonewoc Sandstone Aquifer
17	Eau Claire Confining Unit
18	Mt. Simon Sandstone Aquifer

1

2 Quaternary deposits are represented in Layers 1 through 5 (Table C.3). Vertical discretization of
 3 the Quaternary sediments was achieved by equally dividing the total quaternary thickness
 4 (ground surface through the top of bedrock) into five layers, so that in Washington County the
 5 average layer thickness is approximately 6 meters (20 feet).

6 The top of bedrock is equivalent to the base of Layer 5. Bedrock aquifers and confining units are
 7 represented in Layers 6 through 18 (Table C.3). MODFLOW-ready surfaces for bedrock units
 8 were created using rasters (i.e., grids) provided by MGS (2019). The bedrock rasters have
 9 assigned elevation values only where the bedrock unit is present. Since each model cell needs
 10 an assigned elevation to create MODFLOW inputs, areas with no coverage were assigned the
 11 elevation of the underlying surface present in those areas. The bedrock layers were constructed
 12 from the bottom up. The base elevation of the Mt. Simon Sandstone Aquifer (Layer 18) is
 13 equivalent to the top of pre-Cambrian basement rock (present everywhere). The top of the Mt.
 14 Simon is the base of the Eau Claire Confining Unit. Where the Mt. Simon is not present, the top
 15 elevation of the pre-Cambrian basement rock is equivalent to the base elevation of the Eau
 16 Claire. Each overlying bedrock layer (with the exception of Layer 6) was assigned elevations in
 17 the manner described above. Cells with thickness less than 0.1 meter (3 feet; where a bedrock
 18 unit is not present) were removed from the simulations using MODFLOW settings. The upper 18
 19 meters (59 feet) of bedrock was made into a separate model layer (Layer 6) that represents
 20 shallow bedrock that is typically more weathered and fractured, with greater secondary
 21 porosity values. Layer 6 replaced the upper 18 meters (59 feet) of bedrock throughout the
 22 entire model domain and represents the areas where deeper units subcrop. The remaining
 23 layers, Layers 7 through 18, represent individual, competent deeper bedrock units.

24 **C.3 Boundary conditions**

25 Boundary conditions were placed along the edge of the model domain where groundwater was
 26 determined to enter or leave the model (perimeter boundaries) and at major rivers, lakes, and perennial
 27 streams (surface water boundaries).

28 An overview of surface water boundaries is presented in Section C.3.1 and an overview of perimeter
 29 boundaries is presented in Section C.3.2.

30 **C.3.1 Surface water boundaries**

31 Rivers, lakes, and perennial streams represented in the model were simulated using
 32 MODFLOW's RIV package (Figure C.3). This package is a head-dependent boundary in which
 33 flow across the boundary is dependent on the difference between a user-supplied head (i.e.,
 34 stage or elevation) at the boundary and the model's calculated head adjacent to the boundary.
 35 Where the model's calculated head is higher than the user-supplied stage, groundwater flows
 36 into the river or lake and is removed from the model. If the stage is higher than the adjacent

1 model's calculated head, water flows from the river or lake into the model. The rate of flow into
2 and out of the river or lake (or flux) is also dependent on the hydraulic conductivity of the river
3 or lakebed material, its presumed thickness, and the cross-sectional area of flow between the
4 river or lakebed and the aquifer (referred to as river or lakebed conductance). Stage, bottom
5 elevation, and conductance values assigned to RIV boundary cells are discussed below.

6 **C.3.1.1 Surface water stage**

7 River stages in the St. Croix, Mississippi, and Minnesota rivers were recorded at the USGS
8 gaging stations (USGS, 2019b) and are summarized in Table C.4.

9

DRAFT

Table C.4. USGS gaging stations at St. Croix, Mississippi, and Minnesota rivers

River	USGS station	Location	2016–2018 average stage (meters)	2016–2018 average stage (feet)
St. Croix	5341550	Stillwater, MN	206.62	677.89
St. Croix	5344490	Prescott, WI	206.51	677.53
Mississippi	5344500	Prescott, WI	206.50	677.49
Mississippi	5331580	Hastings, MN (below Lock and Dam #2)	206.60	677.82
Mississippi	5331000	St. Paul, MN	210.13	689.40
Mississippi	5288500	Brooklyn Park, MN	245.01	803.84
Minnesota	5330920	Fort Snelling Park, MN	210.67	691.17

1

2 The average stage at each gaging station was calculated for the 2016–2018 timeframe (Table
 3 C.4). The St. Croix River stage was estimated by linear interpolation between gaging stations
 4 along the mid-line of the river. The river stage north of the Stillwater station was interpolated
 5 using the 3-meter (10-foot) DEM surface elevation along the mid-line of the river. The
 6 Mississippi River consists of a series of locks and dams that form navigation pools along the
 7 river; therefore, the river stage could not be estimated by interpolating between USGS gaging
 8 stations. Since pool elevation does not vary considerably annually, the 3-meter (10-foot) DEM
 9 was used to assign the river stage at dam locations (with the exception of Lock and Dam #2 at
 10 Hastings). The river stage between dams and USGS gaging stations was estimated by linear
 11 interpolation. The average 2016–2018 river stage calculated from data recorded at Fort Snelling
 12 Park, Minnesota, was assigned to each reach designated for the Minnesota River. Since only a
 13 small portion of the river is located within the model domain (approximately 4 miles) and the
 14 DEM surface elevation does not change along the centerline of the simulated stretch of the
 15 river, the average river stage at Fort Snelling Park was used for each of the boundary cells
 16 representing the Minnesota River (i.e., linear interpolation was not applied to these reaches).

17 Lake data, which include surface water elevations and lake surveys, are available on the DNR
 18 LakeFinder website (DNR, 2019e). Monitored lakes that have recorded stage for the 2016–2018
 19 timeframe were assigned an average stage value for that period. Lake stages for unmonitored
 20 lakes were determined from the 3-meter (10-foot) DEM.

21 Perennial streams were identified using the USGS National Hydrography Dataset (USGS, 2019a).
 22 Stage data for perennial streams within the model domain are limited. Of the streams
 23 represented in the model, only the Vermillion River, the Kinnickinnic River, and Rice Creek have
 24 gaging stations with current water level data. With the exception of the Vermillion River,
 25 perennial streams represented in the model typically connect to a major river or lake. Stages
 26 along perennial streams were estimated by linear interpolation; recorded surface water levels
 27 were used where available. For stream segments that start and end at a lake, the stream stage
 28 was estimated using the assigned lake stage at the start and end of the stream segment. For
 29 streams that did not have a lake at the start of the stream but discharge into a lake or major
 30 river, stage along the stream was estimated using linear interpolation between an estimated
 31 stage at the head of the stream [based on the 3-meter (10-foot) DEM in Minnesota or the

1 10-meter (33-feet) DEM in Wisconsin] and the assigned river stage at the mouth of the stream.
 2 If a gaging station was located along the stream, the average 2016–2018 calculated stage was
 3 also used in the interpolation. The Vermillion River does not connect to a lake or major river
 4 and was divided into two segments for assigning stage: an upper segment that stretches
 5 between the model boundary near Vermillion and the USGS gaging station at Hastings, and a
 6 lower segment that stretches between the USGS gaging station and where it intersects the
 7 model boundary southeast of Hastings. Stage along the upper segment was estimated using
 8 linear interpolation between an estimated stage at the start of the stream [based on the 3-
 9 meter (10-foot) DEM] and the average 2016–2018 calculated stage at Hastings. Stage along the
 10 lower segment was estimated using linear interpolation between calculated stage at Hastings
 11 and estimated stage at the end of the stream [based on the 3-meter (10-foot) DEM].

12 **C.3.1.2 Surface water bottom elevation**

13 The bottom elevation of the St. Croix River was assigned based on depth contours provided in
 14 an ArcGIS base map (National Geographic Society, 2013). Bathymetry data are not available for
 15 the Mississippi and Minnesota rivers; therefore, the river bottom was arbitrarily assigned an
 16 elevation 3 meters (10 feet) below stage. The bottom elevation for lakes with bathymetry data
 17 incorporated into the 3-meters (10-foot) DEM were assigned a bottom elevation equivalent to
 18 the top elevation of the model. Lakes lacking bathymetry data and perennial streams were
 19 estimated by using lake depths reported in the DNR LakeFinder (DNR, 2019e), or by subtracting
 20 a minimum of 1 meter (3 feet) from the stage where lake and stream depths were not
 21 available.

22 **C.3.1.2 Conductance value**

23 The conductance value assigned to the boundary cell restricts the amount of flow between the
 24 aquifer and the boundary. Conductance is the product of the hydraulic conductivity of the river
 25 or lakebed and the cross-sectional area of the surface water body within the model cell, divided
 26 by the river or lakebed thickness. Initial conductance values assigned to major rivers were
 27 calculated using an average cell area for the major rivers [approximately 15,000 square meters
 28 (161,459 square feet)], a hydraulic conductivity value of 0.1 meter per day (0.3 feet per day)
 29 and an assumed thickness of 1 meter (3 feet). The rivers were initially separated into reaches
 30 based on large changes in stage (such as at dams), width, or bottom elevation (where
 31 available), with designated river reaches not exceeding 8,000 meters (5 miles). However, in
 32 order to minimize the number of parameters for calibration, the reaches were combined so
 33 that the Mississippi River and the St. Croix River each have three reaches, while the Minnesota
 34 River consists of two reaches. Final conductance values for the rivers are provided in Table C.5.

Table C.5. Riverbed conductance for St. Croix, Mississippi, and Minnesota rivers

River	Conductance (square meters per day)	Conductance (square feet per day)
St. Croix	316–15,000	3,401–161,459
Mississippi	50–1,670	538–17,976
Minnesota	154–1,000	1,658–10,764

35

1 Lakes were separated into reaches according to the predominant lithology underlying the lake
2 (till, sand, or organic sediment) in order to use an appropriate hydraulic conductivity value for
3 calculating lakebed conductance. Since cells intersecting a lake outside of Washington County
4 vary considerably in size, assigning unique conductance values to account for the various cell
5 sizes would have resulted in numerous reaches. In order to minimize the number of reaches
6 used for calibration, lakebed conductance for all lakes within the model domain were
7 calculated using an average cell area for southern Washington County [approximately 10,000
8 square meters (107,639 square feet)]. By doing this, lakebed conductance for lakes outside
9 Washington County is underestimated. Hence, simulated RIV lake flux is potentially too small.
10 Calibrated lakebed conductance ranges between 24 and 4,779 square meters per day (258 and
11 51,441 square feet per day). The lower end of the range applies to lakes overlying till and the
12 upper end of the range applies to lakes overlying sand. The calibrated conductance value
13 applied to lakes overlying organic material is 55 square meters per day (592 square feet per
14 day).

15 Perennial streams were also separated into reaches according to the predominant lithology
16 underlying the stream for assigning streambed hydraulic conductivity. Since the stream area is
17 much smaller than the boundary cell, the conductance was assigned using the stream length
18 and estimated width within the cell. Calibrated streambed conductance ranges between 83 and
19 3,000 square meters per day (893 and 32,292 square feet per day). The lower end of the range
20 applies to streams overlying organic material and the upper end of the range applies to streams
21 overlying sand. The calibrated conductance value applied to streams overlying till is 147 square
22 meters per day (1,582 square feet per day).

23 **C.3.2 Perimeter boundaries**

24 General and constant head boundaries were placed along the edge of the model domain where
25 groundwater was determined to enter or leave the model (Figures C.4a–p). A constant head boundary
26 was defined for all model layers on the eastern edge of the model where groundwater flows from the
27 eastern side of the St. Croix River in Wisconsin into the model domain. The general head boundaries
28 were assigned on the southwestern edges of the model in the deep bedrock units, and in the quaternary
29 along the northwestern edge of the model. Locations and associated head values where flux was
30 determined to enter or leave the model are based on monitoring well data, previous modeling efforts,
31 and potentiometric surfaces produced by Sanocki et al. (2009) and Berg (2016).

32 **C.4 Hydraulic conductivity**

33 **C.4.1 Quaternary layers**

34 Layers 1 through 5 were zoned according to the lithologies present within each layer. Six zones
35 were used to define hydraulic conductivity in Quaternary layers according to the following
36 groupings (Figures C.5a–e):

37 Zone 1 – Areas where the predominant texture is silt, clay, or clay loam

38 Zone 2 – Areas where the predominant texture is sandy loam

39 Zone 3 – Areas where the predominant texture is undifferentiated or alluvium

1 Zone 4 – Areas where both till and sand/gravel are present within the layer

2 Zone 5 – Areas where the predominant texture is sand and gravel

3 Zone 6 – Areas of no data (primarily in Wisconsin).

4 Lithologic zones in Washington and Chisago counties were defined using sand and till rasters that are
5 included with the County Geologic Atlas (Setterholm, 2010; Bauer et al., 2016). Point data provided by
6 MGS (Tipping, 2019) were used to define zones in Ramsey, Dakota, and Anoka counties; along with
7 digital quaternary maps included with the County Geologic Atlas (Balaban and Hobbs, 1990; Meyer and
8 Swanson, 1992; Setterholm, 2013). The data used to map hydraulic conductivity zones provide the
9 lithologies present within a layer; however, it does not account for the predominant lithology of the
10 layer. For example, if a model cell encompasses sand, gravel, and till, zone 3 hydraulic conductivity was
11 assigned to that cell; however, the predominant lithology may be either sand and gravel or till. Initial
12 hydraulic conductivity ranges for Quaternary sediment were established using Tipping (2011). Final
13 calibrated hydraulic conductivity values for Quaternary zones are provided in Table C.6.

Table C.6. Horizontal hydraulic conductivity (Kh) and vertical hydraulic conductivity (Kv) of Quaternary layers

Zone	Texture	Kh		Kv	
		(meters/day)	(feet/day)	(meters/day)	(feet/day)
1	Silt, clay, clay loam	1.83E-02	6.00E-02	1.83E-03	6.00E-03
2	Sandy loam	5.00E-01	1.64E+00	5.00E-02	1.64E-01
3	Undifferentiated, alluvium	1.00E+01	3.28E+01	1.00E-01	3.28E-01
4	Sand/gravel and till	8.00E+01	2.62E+02	8.00E+00	2.62E+01
5	Sand and gravel	8.00E+01	2.62E+02	8.00E+00	2.62E+01
6	No data	1.55E+00	5.09E+00	1.33E-01	4.36E-01

14

15 **C.4.2 Bedrock layers**

16 A uniform hydraulic conductivity was set for each bedrock layer, with the exception of Layer 6.
17 Layer 6 replaces the uppermost 18 meters (59 feet) of bedrock and was assigned properties
18 consistent with fractured bedrock. Hydraulic conductivity zones for the uppermost bedrock in
19 Layer 6 were defined using digital bedrock maps provided with the County Geologic Atlas for
20 each county represented in the model (Figure C.6). Therefore, a zone in Layer 6 represents a
21 bedrock unit directly underlying Quaternary deposits. Average shallow fractured bedrock
22 hydraulic conductivity values were assigned to bedrock units represented by those zones. The
23 shallow bedrock layer could consist of more than one bedrock unit if the uppermost bedrock
24 unit is less than 18 meters (59 feet). Therefore, a wider hydraulic conductivity range was used
25 for calibration that encompasses the uppermost bedrock unit and the underlying bedrock unit.
26 Average hydraulic conductivities assigned to deep and shallow bedrock units are based on
27 aquifer test data within the model domain or published values where local data are not
28 available (Runkel et al., 2003; DNR, 2020; MDH, 2020). Final calibrated hydraulic conductivity
29 values for bedrock units are provided in Table C.7.

Table C.7. Horizontal hydraulic conductivity (Kh) and vertical hydraulic conductivity (Kv) of bedrock layers

Zone	Formation/group	Kh		Kv	
		(meters/day)	(feet/day)	(meters/day)	(feet/day)
7	Decorah Shale (shallow)	8.13E-02	2.67E-01	8.13E-04	2.67E-03
8	Glenwood/Platteville (shallow)	3.00E-02	9.84E-02	3.00E-03	9.84E-03
9	St. Peter Sandstone (shallow)	8.69E+00	2.85E+01	8.69E-01	2.85E+00
10	Prairie Du Chien Group (shallow)	3.06E+01	1.00E+02	3.06E-01	1.00E+00
11	Prairie Du Chien Shakopee (shallow)	1.50E+02	4.92E+02	3.00E+00	9.84E+00
12	Prairie Du Chien Oneota (shallow)	3.37E+00	1.11E+01	3.37E-02	1.11E-01
13	Jordan Sandstone (shallow)	1.00E+01	3.28E+01	1.00E-01	3.28E-01
14	St. Lawrence (shallow)	1.50E+01	4.92E+01	1.50E-02	4.92E-02
15	Tunnel City Group (shallow)	3.00E-01	9.84E-01	3.00E-03	9.84E-03
18	Wonewoc Sandstone (shallow)	3.00E+01	9.84E+01	3.00E+00	9.84E+00
19	Eau Claire (shallow)	2.59E-03	8.50E-03	2.59E-05	8.50E-05
20	Mt. Simon (shallow)	2.00E+01	6.56E+01	1.23E+00	4.03E+00
21	Glenwood/Platteville (deep)	3.45E-04	1.13E-03	3.45E-07	1.13E-06
22	St. Peter Sandstone (deep)	3.00E-01	9.84E-01	3.00E-03	9.84E-03
23	Lower St. Peter Confining Unit (deep)	1.37E-02	4.50E-02	1.37E-04	4.50E-04
24	Prairie Du Chien Shakopee (deep)	4.14E+00	1.36E+01	4.14E-02	1.36E-01
25	Prairie Du Chien Oneota (deep)	3.00E+00	9.84E+00	3.00E-02	9.84E-02
26	Jordan Sandstone (deep)	3.00E+00	9.84E+00	3.00E-01	9.84E-01
27	St. Lawrence (deep)	3.00E-02	9.84E-02	3.00E-05	9.84E-05
28	Tunnel City Mozamania (deep)	8.29E+00	2.72E+01	8.29E-03	2.72E-02
29	Tunnel City Lone Rock (deep)	3.00E-04	9.84E-04	3.00E-06	9.84E-06
30	Wonewoc Sandstone (deep)	3.00E+00	9.84E+00	3.00E-01	9.84E-01
31	Eau Claire (deep)	3.00E-05	9.84E-05	3.00E-07	9.84E-07
32	Mt. Simon (deep)	6.00E+00	1.97E+01	6.00E-01	1.97E+00
33	Wisconsin shallow bedrock	3.00E+00	9.84E+00	3.00E-01	9.84E-01

1

2 C.5 Recharge

3 Areal recharge from precipitation for areas overlapping with the Northeast Metro Lakes
4 Groundwater Flow (NMLG) model domain was estimated by the DNR (2019g) using the USGS
5 SWB model (Westenbroek et al., 2010). Annual recharge rates for 2016, 2017, and 2018 were
6 provided to Wood Environment & Infrastructure Solutions, Inc. (Wood) as raster data in units of
7 inches per day. The rasters were averaged for the three years, converted to meters per day,
8 and because the recharge rate was of finer resolution compared to the groundwater model
9 cells outside of southern Washington County, an average raster value was calculated for each
10 groundwater model cell in ArcGIS. An average recharge value of 0.152 meters (6 inches) per
11 year was assigned to areas outside the NMLG model domain. Recharge was adjusted during
12 calibration using a recharge multiplier. The recharge multiplier for the calibrated model is 0.75.
13 Recharge for the calibrated model is shown in Figure C.7.

1 C.6 Pumping wells

2 Groundwater withdrawals from high-capacity wells (wells with permit totals that are greater
3 than 1 million gallons per year) were incorporated into the model as Connected Linear Network
4 (CLN) wells (Panday et al., 2013). The CLN wells, coupled with MODFLOW's Well package, are
5 capable of simulating the effects of wells that span more than one node (such as multi-aquifer
6 wells).

7 Annual pumping volumes for high-capacity wells were provided by the DNR (2019a). The
8 location coordinates for the wells were derived from the Minnesota Well Index (MDH, 2019).
9 An average 2016–2018 pumping rate was calculated for each well. A total of 606 wells with
10 permit volumes greater than 1 million gallons per year were imported into the model (Figure
11 C.8). Wells that did not have a designated aquifer were not included in the model. A majority of
12 these wells did not have significant pumping volumes (less than 10 million gallons per year).
13 Wells within 200 meters (656 feet) of the model boundary were also not included. Although
14 many of these wells did have pumping volumes greater than 10 million gallons per year, the
15 wells were removed in order to avoid non-convergence or overlapping boundary conditions.
16 The total wells removed make up less than 1% of the wells located within the model domain
17 that have average 2016–2018 pumping volumes greater than 1 million gallons per year. The
18 total volume not accounted for in the model is approximately 1,200 million gallons per year,
19 and the total volume applied to the model is approximately 32,000 million gallons per year.

20 Ninety-eight of the simulated wells are pumping from Quaternary aquifers. A majority of
21 pumping in the Quaternary is used for irrigation, pollution containment, and
22 commercial/industrial supplies. The pumping volumes applied to Quaternary aquifers range
23 from less than 1 million gallons per year to greater than 400 million gallons per year. The total
24 volume applied to the model from Quaternary wells is approximately 2,700 million gallons per
25 year. One of the permitted wells located along the Mississippi River in Ramsey County (DNR
26 permit number: 1965-0271) was simulated using MODFLOW's Drain package. The well is used
27 for groundwater dewatering. The average 2016–2018 volume for the well is approximately
28 576 million gallons per year. Simulating this withdrawal volume using MODFLOW's Well
29 package was causing a long run time and issues with convergence; therefore, the well was
30 converted to a drain and simulated using MODFLOW's Drain package. Construction details such
31 as depth and diameter of the drain are not available. The depth and conductance value applied
32 to the drain is 10 meters (33 feet) and 75 square meters (807 square feet) per day, respectively.
33 Despite the large conductance value, the drain was only able to remove approximately 12% of
34 the actual volume. Since the drain was not considered significant to the model's calibration and
35 predictions, no further effort was made to simulate the full average 2016–2018 volume for the
36 drain.

37 Bedrock aquifers are heavily utilized for municipal supply but are also utilized for industrial
38 processing, irrigation, and pollution containment. The average pumping volumes applied to
39 bedrock aquifers range between less than 1 gallon to greater than 600 million gallons per year.
40 The maximum pumping applied to bedrock aquifers occurs at a pollution containment well in
41 the Prairie du Chien. Of the simulated bedrock wells, 346 wells have pumping volumes greater

1 than 10 million gallons per year. Ninety-five of the wells have pumping volumes greater than
2 100 million gallons per year. The total volume applied to bedrock aquifers is approximately
3 29,000 million gallons per year. A majority of this volume is produced from the Prairie du Chien
4 and Jordan Sandstone aquifers. Approximately 16% of the total volume is produced from
5 deeper aquifers (Tunnel City through Mt. Simon).

6 MODFLOW's Well package has an automated flow-reduction capability (Niswonger et al., 2011).
7 If the saturated thickness of the model cell containing the CLN well is less than 1%, the pumping
8 rate will be reduced. Seven CLN nodes in the calibrated model had reduced rates. The flow
9 reduction from the seven CLN nodes was spread throughout the model with a combined total
10 reduction of 1,048 cubic meters per day (192 gallons per minute). The flow reduction accounts
11 for less than 1% of the total applied production and is considered negligible. The reduction in
12 rates could be due to several factors, including, but not limited to, inaccurate production rates
13 associated with using average rates and an unknown quality of rate measurements, areas
14 where the aquifer thickness and/or aquifer hydraulic conductivity is not accurately represented
15 in the model, completion intervals represented in the model differ from actual, hydraulic
16 conductivity is homogenous in the model for each bedrock unit and lumped for shallow units,
17 and heterogeneity leading to greater production rates in the areas of these wells may not have
18 been captured.

19 **C.7 Solver**

20 The Sparse Matrix Solver (SMS) was used to solve the system of equations formulated by
21 MODFLOW-USG. The SMS includes the unconfined Newton Raphson linearization option for
22 upstream weighting, as provided in MODFLOW-NWT (Niswonger et al., 2011). Various settings
23 used by the SMS package were adjusted until optimal settings were reached to achieve model
24 convergence and a mass balance error that is less than 0.1%. An explanation of settings is not
25 discussed here as it is beyond the scope of this report; however, the various options available in
26 the SMS package are documented by Panday et al. (2013). Key solver settings for the calibrated
27 model are summarized in Table C.8.

28

Table C.8. Key solver settings for the calibrated model

Parameter	Setting
Solver	SMS
Head change criterion (meters)	0.0003
Nonlinear method	Delta-Bar-Delta/Newton Raphson linearization
Linear solution method	Preconditioned conjugate gradient
Flow residual tolerance (meters cubed per day)	130

1

2 C.8 Calibration

3 The groundwater flow model was calibrated by adjusting model input parameters until the
 4 model simulated head matched average 2016–2018 groundwater elevations (DNR, 2019c)
 5 within an acceptable level of accuracy. The groundwater elevations were recorded at DNR
 6 observation wells and City of Woodbury observation wells (Table C.9). Additionally, simulated
 7 potentiometric surfaces were compared to potentiometric surfaces generated from measured
 8 groundwater elevations (Sanocki et al., 2009) as a qualitative evaluation of the simulated head
 9 distribution. Parameters adjusted during calibration included hydraulic conductivity, recharge,
 10 and river and lakebed conductance. Observed and simulated head at calibration targets is
 11 provided in Table C.9.

Table C.9. Observed and simulated head at calibration targets.

Well identification	X	Y	Layer	Observed head (meters)	Computed head (meters)	Residual head (meters)
227977	498129	4990823	1	281.04	281.15	-0.11
243778	512311	4953877	1	207.33	208.89	-0.57
272110	490344	5003193	1	271.49	271.72	-0.23
551575	500438	4990730	1	280.69	282.50	-1.81
591980	485678	4966748	1	221.63	222.41	-0.78
789993	490131	5012062	1	273.80	272.55	1.25
816925	509923	5005835	1	287.47	284.56	2.92
270208	510906	5021186	2	269.35	270.00	-0.65
482154	485678	4966748	2	221.96	222.51	-0.55
623066	512270	4990960	2	266.85	260.31	6.54
675586	513198	4973198	2	249.04	248.66	0.38
208135	490349	5003179	3	269.65	271.63	-1.98
227033	516232	4995471	3	249.00	250.78	-1.77
243178	490130	5012065	3	270.32	272.55	-2.23
243746	497303	4957498	3	230.50	235.29	-4.79
244359	498073	4990791	3	277.07	280.97	-3.90
482156	485749	4966962	3	221.56	221.70	-0.15
623058	498450	4982785	3	292.06	289.65	2.41
783243	509539	5003085	3	288.48	285.48	3.01
208137	490349	5003185	4	269.53	271.63	-2.10

Table C.9. Observed and simulated head at calibration targets.

Well identification	X	Y	Layer	Observed head (meters)	Computed head (meters)	Residual head (meters)
809291	496340	4983044	4	257.71	264.55	-6.84
227032	516232	4995471	5	240.27	250.70	-10.43
244346	498447	4982783	5	286.26	287.38	-1.12
763777	507076	5031910	5	264.04	268.64	-4.60
792506	506856	4967627	5	258.45	251.77	6.68
797201	502799	4988571	5	281.26	281.96	-0.70
797202	508493	4977346	5	268.04	267.99	0.046
123527	517936	4974847	6	208.22	210.05	-1.83
195689	509532	5003091	6	288.38	285.43	2.95
195728	513502	5007358	6	283.18	280.23	2.95
551565	507798	4997116	6	291.15	286.26	4.89
551576	501029	5003204	6	279.71	280.21	-0.50
761596	498645	4974804	6	219.20	228.28	-9.08
767633	498759	4973940	6	215.27	219.29	-4.03
799890	506858	4967626	6	258.42	251.75	6.67
799898	512824	5024652	6	266.43	271.95	-5.52
826487	509466	5005300	6	288.23	284.87	3.37
219492	511906	5026490	6	268.39	270.27	-1.89
123548	517940	4974844	6	208.46	210.03	-1.57
200105	488506	4983804	8	259.48	263.27	-3.79
124395	502831	4999575	10	283.49	284.52	-1.03
481807	498135	4990822	10	275.82	279.85	-4.03
551564	500438	4990730	10	278.05	278.51	-0.46
551577	506308	4984368	10	274.42	278.50	-4.07
675583	510867.3	4972215	10	258.14	262.22	-4.08
675585	513197.9	4973200	10	249.10	249.09	0.01
722705	512389.5	4971975	10	255.96	258.08	-2.12
767882	502422	4969799	10	237.13	238.79	-1.66
767883	504469	4970029	10	256.78	250.63	6.15
799899	499982.5	4993553	10	277.87	281.23	-3.36
817790	502791	4960821	10	221.41	212.66	8.76
825069	502796	4988561	10	281.34	281.42	-0.08
200054	501030	4975379	12	245.21	251.92	-6.71
200660	492491	4970981	12	223.40	225.61	-2.21
200874	501102	4981659	12	262.17	267.67	-5.50
206833	488966	4987763	12	257.94	264.31	-6.36
274285	517080	4968726	12	239.04	236.19	2.85
675580	509509.2	4972862	12	259.38	259.54	-0.16
675584	513199	4973199	12	249.27	249.17	0.10

Table C.9. Observed and simulated head at calibration targets.

Well identification	X	Y	Layer	Observed head (meters)	Computed head (meters)	Residual head (meters)
763366	504885	4970704	12	258.33	253.85	4.48
767884	504468	4970040	12	254.15	250.23	3.92
767885	502418	4969799	12	236.12	238.65	-2.53
799891	506861	4967626	12	258.03	251.37	6.67
799900	500103	4993452	12	277.89	281.42	-3.53
817789	502840	4960835	12	222.42	212.90	9.52
826486	509464	5005299	12	287.85	284.89	2.97
225652	486332	4988251	12	257.96	263.75	-5.79
244592	517117	4968757	13	221.53	229.14	-7.61
595649	512531.7	4991032	13	263.91	257.41	6.50
800954	506864	4967626	14	250.24	245.98	4.26
791036	500100	4993449	14	268.77	269.79	-1.01
767868	516538	4966106	16	225.78	224.00	1.78
826484	509468	5005298	16	252.61	256.89	-4.28
227031	516232	4995471	16	239.84	250.66	-10.81
603059	517060	4975967	16	233.44	220.10	13.33
225647	500127	4993313	18	219.77	225.79	-6.03
783609	516538	4966103	18	213.44	222.85	-9.41
785579	493532	5001562	18	225.98	236.33	-10.34
789735	502841	4960831	18	203.07	211.00	-7.93

1
2 The difference between observed and simulated head is the residual head. A positive residual is
3 a result of a lower model simulated head compared to the observed head and a negative
4 residual is a result of a higher simulated head compared to the observed head. The distribution
5 of residual head is shown in Figures C.9a–l. The average residual head (i.e., mean error) for the
6 calibrated model is -0.88 meters. A perfectly calibrated model would have a mean error of zero;
7 however, a small mean error does not necessarily indicate a well-calibrated model since
8 positive and negative errors can cancel each other out. The negative mean residual for the
9 calibrated model indicates that simulated heads are generally higher than observed heads at
10 calibration targets. The negative mean residual bias can also be observed in a plot of residual
11 versus observed heads at calibration targets (Figure C.10). More of the plotted residuals are
12 negative; however, the points are generally randomly distributed as they should be for a
13 spatially, non-biased calibrated model. The negative bias is reasonable, considering the model is
14 calibrated assuming steady state (long-term constant with time) based on a wet recharge
15 condition that has only been observed for the last five years. Additionally, there is a large
16 negative bias associated with the deeper layers, particularly the Mt. Simon (layer 18). The Mt.
17 Simon experienced historically greater pumping rates compared to the applied average
18 pumping rates from 2016 to 2018. The recovery associated with decreased pumping in the Mt.
19 Simon may not have been achieved in the 2016–2018 time period, which is inherently assumed
20 in the model calibration approach taken.

1 A plot of simulated versus observed heads at calibration targets is shown in Figure C.11. If the
 2 model were perfectly calibrated, the plotted points would fall on a line with a 45-degree slope
 3 such that simulated heads would equal observed heads at calibration targets. The less scatter
 4 around the line, the better the matching of observed heads with simulated heads, and a
 5 theoretically better calibration. The plot of simulated versus observed heads for the calibrated
 6 model shows some scatter from the theoretical line. However, the degree of scatter is within
 7 acceptable statistical criteria, where the majority of the data fall within the 95% prediction
 8 interval, providing confidence in the model calibration (Figure C.11).

9 The model accuracy was calculated using the scaled root mean square (RMS) error between
 10 actual head measurements and model simulated head measurements. The RMS error is the
 11 average of the squared differences in measured and simulated heads. The ratio of the RMS
 12 error to the total head loss over the model domain is the scaled RMS error. Normally this value
 13 should be less than 10% for a well-calibrated model. The scaled RMS for the calibrated model is
 14 5.5%.

15 A comparison of simulated potentiometric surfaces with those depicted by Sanocki et al (2009;
 16 Figures C-12a through C-12e) was used as a qualitative measure of the simulated head
 17 distribution. Overall, there is a good match between potentiometric surfaces. The simulated
 18 water table and potentiometric surfaces for bedrock aquifers are shown in Figures C.12f
 19 through C.12h. The groundwater model simulated the observed groundwater divide in
 20 Washington County (Berg, 2019; Sanocki et al, 2009). Groundwater flow in the Quaternary and
 21 bedrock aquifers (with exception of Mt. Simon) is generally toward the St. Croix and Mississippi
 22 rivers. Lakes and small perennial streams serve as both points of recharge and discharge within
 23 the model domain. The model did not simulate the regional cone of depression in the Mt.
 24 Simon. Simulated heads in the Mt. Simon were higher than average 2016–2018 measured
 25 heads. One possible reason may be due to the model simulating higher leakage than is
 26 occurring in areas where shallow bedrock directly overlies the Mt. Simon (primarily in the
 27 northern part of the model domain). However, it seems more likely that average 2016–2018
 28 pumping is an inadequate timeframe for calibration to the Mt. Simon head targets (i.e., a longer
 29 period of pumping is needed to match simulated and observed heads).

30 **C.8.1 Baseflow**

31 Baseflow was estimated by the DNR (2019b) for two gaging stations along Valley Creek and a
 32 gaging station along Browns Creek (Table C.10).

Table C.10. Estimated and model simulated baseflow at Valley and Browns creeks.

Year	2016 (cfs)	2017 (cfs)	2018 (cfs)
Station 37067001 (Valley Creek at Afton)			
Average flow	4.8	5.1	NA
Estimated average baseflow	4.8	5.0	NA
Simulated baseflow	0.77		
Station VA0010 (Valley Creek at Putman Boulevard)			
Average flow	20	22	19
Estimated average baseflow	20	22	18–19

Simulated baseflow	24		
Station BR0003 (Browns Creek and Dellwood Road)			
Average flow	8.8	8.8	8.5
Estimated average baseflow	6.1–7.2	6.7–7.7	6.2–7.2
Simulated baseflow	7.6		

cfs = cubic feet per second, NA = not available.

1 Baseflow estimates were compared to simulated flows at these locations to further assess the
 2 model’s calibration. Estimated and simulated baseflows at Valley Creek (Afton) were
 3 approximately 5 and 0.77 cubic feet per second, respectively. Estimated and simulated
 4 baseflows at Valley Creek (Putman Boulevard) were approximately 20 and 24 cubic feet per
 5 second, respectively. Simulated baseflow at Brown’s Creek was 7.6 cubic feet per second
 6 compared to the estimated baseflow of approximately 7 cubic feet per second. Additionally,
 7 streamflows were measured near the mouth of Trout Brook between 2004 and 2006. Baseflows
 8 estimated during this period varied from less than 1 cubic feet per second to 4.5 cubic feet per
 9 second, but was on average approximately 1 to 2.5 cubic feet per second (DNR, 2019b;
 10 Emmons & Olivier Resources, 2009). Simulated baseflow for Trout Brook was approximately 2.5
 11 cubic feet per second.

12 C.8.2 Water Balance

13 The water balance for the model is summarized in Table C.11.

Table C.11. Model water balance.

	Inflow (millions of gallons per day)	Outflow (millions of gallons per day)
Well	0	86.52 ^a
Perimeter boundaries	1,001.86	597.60
River	183.96	846.76
Recharge	340.82	0
Total	1,526.64	1,530.88

14 a. Includes well simulated as a drain.

15 A majority of the water entering the model is from groundwater flux along the perimeter of the
 16 model. Recharge from precipitation contributes approximately 22% of the total flow into the
 17 model, while recharge from surface water boundaries contributes approximately 12% of inflow.
 18 Groundwater leaving the model along perimeter boundaries accounts for approximately 39% of
 19 the water removed from the model. Discharge along perimeter boundaries primarily occurs in
 20 bedrock layers beneath the Mississippi River where head-dependent boundary cells were
 21 placed to simulate groundwater flux out of the model domain. Discharge at surface water
 22 boundaries removes approximately 55% of water from the model, while pumping wells remove
 23 approximately 6%. The water balance error for the model is approximately 0.27%. As shown in
 24 Table C.10, a slightly larger amount of water is leaving the model compared to the amount of
 25 water entering the model from recharge, rivers, and, flux along perimeter boundaries.

1 C.9 Effective porosity for particle tracking

2 Effective porosity values were uniformly applied to each model layer, with the exception of
3 Layer 6 for particle tracking analysis (discussed in Appendix E). Porosity values in Layer 6 were
4 assigned according to the hydraulic conductivity zone (which is based on the uppermost
5 bedrock layer). Porosity values used in the model for predictive scenarios were provided by
6 DNR as a range of values for each formation in written communication. However, the DNR did
7 not provide porosity values for all of the formations represented in the model including the
8 Decorah Shale, Glenwood/Platteville, and Eau Claire confining units. The formations missing
9 values were assigned porosity values using data from the Wisconsin Geological and Natural
10 History Survey (WGNHS, 2020). The lower end of the range of values were selected to provide
11 conservative predictions of transport (lower porosity values results in greater distances traveled
12 over the same amount of time), and then were refined within the ranges to a final set after
13 comparison of particle travel times to arrival of known PFAS contamination at municipal wells in
14 areas near sources (Table C.12). The particle tracking analysis was performed using mod-
15 PATH3DU (S.S. Papadopoulos & Associates, 2017).

Table C.12. Effective porosity used for particle tracking analysis.

Hydrostratigraphic unit	Porosity
Quaternary sediments	0.100
Decorah Shale	0.010
Glenwood/Platteville	0.043
St. Peter Sandstone	0.100
Lower St. Peter confining unit	0.100
Prairie du Chien Group	0.010
Jordan Sandstone	0.100
St. Lawrence Formation	0.050
Tunnel City Group	0.060
Wonewoc Sandstone	0.100
Eau Claire Formation	0.130
Mt. Simon Sandstone	0.100

16

17 C.10 Model Limitations

18 The calibrated model is a regional scale model based on average hydraulic parameters and
19 three-year average recharge rates, pumping rates, and river and lake stage values. The model
20 reasonably simulates regional groundwater flow within statistically acceptable criteria.
21 Although the three-dimensional, steady-state groundwater flow model is considered to be
22 calibrated within statistically acceptable criteria and is appropriate for evaluating various
23 pumping scenarios outlined in the Conceptual Plan, there are limitations to the model that
24 should be noted.

25 The model is steady-state, developed on a limited set of averaged data over a limited
26 timeframe, and calibrated to annual averages during recent wet conditions that could result in
27 locally different flow patterns at different times of the year. This currently limits the model to

1 matching any predictions related to transient conditions. However, a transient
2 verification/calibration could be implemented, and transient conditions could be simulated
3 with greater confidence.

4 Bulk average hydraulic parameters (e.g., hydraulic conductivity, porosity) were used in the
5 model for the various layers. Heterogeneities in aquifers and confining units were not
6 accounted for and could result in significantly different yields and associated drawdown on a
7 local scale. This can also limit the understanding of localized flow paths enhanced or reduced by
8 local or sub-regional scale fractures.

9 There are limitations and a certain amount of error related to the SWB model and estimation of
10 recharge that were used as the source of recharge in the model, and the values are assuming a
11 wet condition.

12 River and lakebed thickness values and bottom and stage elevations are not known at several
13 lakes and streams within the model domain. Many of these values along with river and lakebed
14 hydraulic conductivity are unknown and could result in locally different inflows and outflows
15 from lakes and river bodies. This can limit the understanding of potential surface water body
16 interactions with groundwater under different pumping conditions.


DRAFT

1 **Figure C.1. Location and extent of the model domain.**




2
3 Background imagery service layer credits: Esri, Garmin, GEBCO, National Oceanic and Atmospheric
4 Administration (NOAA) National Geophysical Data Center (NGDC), and other contributors.
5

1 Figure C.2. Model grid and cross-section through southern Washington County.




2
3

1 Figure C.3. Rivers, lakes, and perennial streams simulated with MODFLOW's RIV package.




2
3
4

1 Figure C.4a. Perimeter boundaries in Layer 1 (Quaternary).




2
3

1 Figure C.4b. Perimeter boundaries in Layer 2 (Quaternary).




2
3

1 Figure C.4c. Perimeter boundaries in Layer 3 (Quaternary).




2
3

1 Figure C.4d. Perimeter boundaries in Layer 4 (Quaternary).



2
3

1 Figure C.4e. Perimeter boundaries in Layer 5 (Quaternary).



2

Appendix D. Conceptual project list

1

2 **D.1 Conceptual project list**

3 Table D.1 provides the list of potential conceptual projects identified for each of the 14 communities
4 currently known to be affected by per- and polyfluoroalkyl substances (PFAS) contamination in the East
5 Metropolitan Area of the Twin Cities. This list includes projects that were identified by the Government
6 and the 3M Working Group, the Citizen-Business Group, Subgroup 1, members of the public, and the
7 Co-Trustees.

8 This list of conceptual projects represents the range of potential solutions for improving drinking water
9 supply for the affected communities in the East Metropolitan Area; however, additional projects may be
10 identified and evaluated at a later date as new information comes to light. As a next step, these
11 potential projects were bundled into scenarios and evaluated using the drinking water distribution and
12 groundwater models (see Chapter 6 of this Conceptual Plan). During scenario development, the
13 conceptual projects presented below may have been modified, combined, and/or expanded; or new
14 projects may have been identified.

DRAFT

- 1 **Table D-1. List of potential conceptual projects.** This list is organized by community-specific projects, multi-community projects, projects for all
- 2 communities, and other project submissions. The relevant water supply improvement option number (WSIO) and project submission source are
- 3 also indicated.

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
Community-Specific Projects					
1	Afton	Afton 1/ Individual GAC Filter Systems for Individual Private Wells	As individual private wells are found to have levels of PFAS near or above healthy levels, install individual granular activated carbon (GAC) filter systems to remove the PFAS. All properties in Afton have individual private wells. The individual GAC filter system for individual private wells is a cost-effective and flexible solution for the currently small but widely spread number of contaminated wells, and can also easily and cost-effectively be installed if the PFAS contamination moves and affects more wells.	1	Online
2	Afton	Wood- Afton 2a	Create new small community water systems with treatment: This conceptual project would create a new small community water system in Afton. The small community water system could be located east of Indian Trail and Tomahawk Drive. The system would supply five homes and require one shared, treated groundwater well. This option would require approximately 1,440 linear feet of 2" diameter polyvinyl chloride (PVC) piping.	2	Wood
3	Afton	Wood- Afton 2b	Create new small community water systems with treatment: This conceptual project would create a new small community water system in Afton. This system could be located south of Tomahawk Lane and Tomahawk Drive and would supply eight homes and require one shared, treated groundwater well. This option would require approximately 2,920 linear feet of 2" diameter PVC piping.	2	Wood
4	Afton	Wood-Afton 2c	Create new small community water systems with treatment: This conceptual project would create a new small community water system in Afton, which could be located at South Division Street on Croixview Avenue. The system would supply 10 homes and require 2 shared, treated groundwater wells. This option would require approximately 2,640 linear feet of 2" diameter PVC piping.	2	Wood
5	Afton	Wood- Afton 2d	Create new small community water systems with treatment: This conceptual project would create a new small community water system in Afton, which could be located on Tomahawk Dive South and Tomahawk Lane South. The system would supply 20 homes and require 2 shared, treated groundwater wells. This option would require approximately 6,480 linear feet of 4" diameter PVC piping.	2	Wood
6	Afton	Wood-Afton 3	Create a new surface water treatment plant (SWTP) off the St. Croix River: This conceptual project would create a new water treatment plant (WTP) using surface water from the St. Croix River. While this conceptual project is technically feasible, it is the	8	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			least administratively feasible option. Administratively, the permitting challenges with using St. Croix as a water source could take 3–5 years to resolve. The city has also stated that they do not have the resources to support a new WTP. In addition, this option would require Afton to implement a municipal water system. If this were to be considered, this option would need to be compared to the option of connecting to another neighborhood as part of a regional solution. As a result, a SWTP may be infeasible for Afton alone but could be evaluated as part of a regional surface water option considered in the following section.		
7	Cottage Grove	Wood – Cottage Grove 2c	<p>Connect private wells and non-community public water systems to an existing municipal water system: This conceptual project would extend waterlines to connect neighborhoods currently on private wells to Cottage Grove’s municipal water system. Considerations for this option would be the rate at which neighborhoods could be connected and a cost trade-off analysis with providing point of entry treatment (POET) systems for individual homes. There also might be a community/resident preference to remain on a private well. The following is a list of potential neighborhoods that could be connected:</p> <ul style="list-style-type: none"> i. Neighborhood A: This neighborhood is near the intersection of Goodview Avenue South and 70th Street South. A few of these residences have seen health risk index (health index, HI) values over 1 and the remaining homes have had detectable levels of PFAS in their non-municipal wells. The intent would be to connect these homes through the waterlines installed under Expedited Project 100014 – Granada Avenue. ii. Neighborhood B: This neighborhood is located off Grey Cloud Trail near the intersection with 103rd Street South. The majority of the residences in this area have already seen HI values over 1. Serving the area would require approximately 10,500 linear feet of waterline to reach all members of the neighborhood, with additional feet of waterline required to loop the system. This area also includes the golf course which, according to city personnel, will be up for sale soon for future development. Potential complications to consider would be how to loop the system and the crossing under the railroad track. An interim solution could be to install individual POET systems for non-municipal wells. iii. Neighborhood C: This neighborhood incorporates all the residences along Kimbro Avenue including Old Cottage Grove. It would require extensive water line installation to provide service and loop back into the existing system. Connecting to the city’s municipal water system may be a long-term solution that would require POET 	3	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			<p>systems for individual homes in the interim as homes in this area have seen HI values greater than 1.</p> <p>iv. Neighborhood D: This neighborhood is located in southeast Cottage Grove and remains far from the existing municipal water system. The timing of the municipal water system expansion would be an important consideration for this option. Connecting this area could be a possible long-term solution, and an interim solution could be the installation of POET systems or small community water systems with treatment depending on the number of homes in this area seeing HI values greater than 1.</p> <p>v. Neighborhood E: This neighborhood is located on Lower Grey Cloud Island and is similar to Neighborhood D. This option could be a possible long-term solution and an interim solution could be the installation of POET systems or small community water systems with treatment, depending on the number of homes in this area seeing HI values greater than 1.</p> <p>vi. Neighborhood F: This neighborhood is in the Langdon Area, which contains homes that are heavily contaminated with PFAS – 12 of the homes have HI values of 27. A preliminary analysis by the city determined it may not be cost-effective to extend the municipal water system to these homes due to the small number of homes and that other options should be considered.</p>		
8	Cottage Grove	Wood – Cottage Grove 3	<p>Drill new municipal supply wells in optimized locations: This conceptual project would drill one or more new municipal supply wells in Cottage Grove. This option is consistent with Cottage Grove’s Master Plan to drill new wells in optimized locations to either replace existing municipal supply wells (Wells 1 and 2) or meet future demand. The city currently has sufficient firm capacity [12.8 million gallons per day (mgd)] from their operational wells to meet the 2020 maximum daily demands of 11.5 mgd, assuming these wells maintain an HI value less than 1. However, recent testing has indicated that increased pumping of Well 9 has resulted in increasing HI values. It is anticipated that Well 9 will exceed an HI of 1 within the next testing round or the one after that. This would have an extremely significant impact on the firm capacity of the system due to the required blending needed to achieve the demand values listed above. In addition, the city will need to install additional wells to meet the 2040 maximum daily demands of 14.1 mgd. Ideally, new wells would be located in optimized areas where no PFAS treatment is required; however, there is the potential that new wells will need to be located in an area where PFAS treatment is required. The further evaluation of well</p>	5	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			locations will be coordinated with groundwater modeling efforts to assist in this determination.		
9	Cottage Grove	Wood – Cottage Grove 4	Provide POET systems for private wells and non-community public water systems: This conceptual project would provide POET systems for private wells and/or non-community public water systems in Cottage Grove. Some neighborhoods listed in Wood – Cottage Grove 2c may be better suited to be on POET systems as a long-term solution or as an interim solution until they can be brought onto the city’s municipal water system. Or, it may be found that certain residences that are unable or unwilling to connect to the city’s municipal water system can be outfitted with POET systems. This could include homes in Neighborhoods B, C, D, E, and F (as outlined in Wood – Cottage Grove 2c) that are farther away from the existing system and would require more time to connect.	1	Wood
10	Cottage Grove	Wood – Cottage Grove 5	Create new small community water systems with treatment: This conceptual project would create one or more small community water systems in Cottage Grove. Potential locations include Neighborhoods C, D, and E, as outlined in Wood – Cottage Grove 2c. There may be a cost advantage to implementing small community water systems for some neighborhoods as opposed to installing individual POET systems. A cost comparison of the two options will determine the most economically feasible option.	2	Wood
11	Cottage Grove	Cottage Grove Municipal Groundwater System Treatment & Supply Plan	This project would include the construction of two WTPs and associated raw water lines to serve Cottage Grove’s existing groundwater supply system. The WTPs would be located in low and intermediate pressure zones, and would be sized for expansion as additional municipal supply wells are constructed. This project would also include an analysis for connecting impacted rural residential neighborhoods to municipal water.	4	Online
12	Denmark	Wood – Denmark 1	Provide POET systems for private wells and non-community public water systems: This conceptual project would provide POET systems for private wells and/or non-community public water systems in Denmark. This option would be a good fit for wells that are not located near a municipal water system, and where the number of private wells does not justify the costs of connecting to an existing municipal water system or implementing a small community water system.	1	Wood
13	Denmark	Wood – Denmark 2	Create new small community water systems with treatment: This conceptual project would create one or more small community water systems in Denmark. The small community water systems would be supplied by a shared, treated groundwater well. The consideration for this would be the cost tradeoff of this option as opposed to individual POET systems and resident/community preferences.	2	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
14	Grey Cloud Island Township	Wood – GCI 1	Provide POET systems for private wells and non-community public water systems: This conceptual project would provide POET systems for private wells and/or non-community public water systems in Grey Cloud Island that have not had these systems installed to date.	1	Wood
15	Grey Cloud Island Township	Wood – GCI 2a	Create new small community water systems with treatment: This conceptual project would create a new small community water system in Grey Cloud Island. The small community water system could be located west of Grey Cloud Trail on Grey Cloud Island Drive. The system would supply five homes and require one shared, treated groundwater well. This option would require approximately 1,260 linear feet of 2” diameter PVC piping.	2	Wood
16	Grey Cloud Island Township	Wood – GCI 2b	Create new small community water systems with treatment: This conceptual project would create a new small community water system in Grey Cloud Island. The small community water system could be located west of Grey Cloud Trail. The system would supply eight homes and require one shared, treated groundwater well. This option would require approximately 2,240 linear feet of 2” diameter PVC piping.	2	Wood
17	Grey Cloud Island Township	Wood – GCI 2c	Create new small community water systems with treatment: This conceptual project would create a new small community water system in Grey Cloud Island. The small community water system could be located west of Pioneer Road on Grey Cloud Island Drive. The system would supply 10 homes and require 2 shared, treated groundwater wells. This option would require approximately 2,490 linear feet of 2” diameter PVC piping.	2	Wood
18	Grey Cloud Island Township	Wood – GCI 2d	Create new small community water systems with treatment: This conceptual project would create a new small community water system in Grey Cloud Island. The small community water system could be located west of Pioneer Road on Grey Cloud Island Drive. The system would supply 20 homes and require 2 shared, treated groundwater wells. This option would require approximately 8,500 linear feet of 4” diameter PVC piping.	2	Wood
19	Lake Elmo	Wood – Lake Elmo 1	Provide treatment of an existing municipal water supply: This conceptual project would provide treatment of Lake Elmo’s existing municipal water supply. Lake Elmo had previously explored the option to construct a WTP at their existing, unequipped Well 3 that had never been brought online. A study by Bolton & Menk indicated, however, that this was not a cost-effective option relative to drilling a new municipal supply well that did not require treatment and required almost twice the cost of implementing treatment at Well 1. This option of treating existing wells would need to be compared to	4	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			the option of drilling new supply wells in optimized locations such as Well 5, which do not require treatment. Considerations for this option would need to be made, such as the impact on White Bear Lake and locating any new wells outside the Special Well and Boring Construction Area. This option would have to be implemented in conjunction with one or more other options since the water supply available from Well 1 and/or Well 3 would not meet future demand.		
20	Lake Elmo	Wood – Lake Elmo 2	Drill new municipal supply wells in optimized locations: This conceptual project would drill one or more new municipal supply wells in Lake Elmo. Lake Elmo is currently implementing the results of a study by Bolton & Menk and are drilling a new municipal supply well, Well 5, in the northeast region of the city close to existing Well 4. Based on the study, the city estimates that they will need up to an additional two wells to meet buildout conditions, and the first well will be needed by 2023. If it is found that there are significant restrictions on pumping in the northern region due to the 5-mile proximity to White Bear Lake, Lake Elmo would need to consider the option of drilling new wells farther south, which may potentially require treatment. The Minnesota Department of Health (MDH) has also designated regions of Lake Elmo as Special Well and Boring Construction Areas. Requirements for such areas would need to be followed for all new wells. This option is consistent with Lake Elmo's Comprehensive Water System Planning efforts since 2006 and does not require costs to reconfigure the existing water distribution system.	5	Wood
21	Lake Elmo	Wood – Lake Elmo 3	Provide POET systems for private wells and non-community public water systems: This conceptual project would provide POET systems for private wells and/or non-community public waters systems in Lake Elmo. This could include residences that cannot be connected to the city's municipal water system or could be an interim solution until the city is able to bring them onto the municipal water system.	1	Wood
22	Lake Elmo	Wood – Lake Elmo 3e	Connect private wells and non-community public water systems to an existing municipal water system: This conceptual project would extend waterlines to connect neighborhoods currently on private wells to Lake Elmo's municipal water system. Lake Elmo has estimated that there are 175 well advisories from PFAS contamination in the southern two-thirds of the community. These wells are located within the 18 developed neighborhoods located within the Special Well and Boring Construction Area. The city plans to connect these existing neighborhoods to the municipal water system. New developments in these areas are required to connect to the municipal water system as they are developed.	3	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
23	Lake Elmo	Wood – Lake Elmo 4	Create new small community water systems with treatment: This conceptual project would create one or more small community water systems in Lake Elmo. This option would be most applicable for neighborhoods where the number of residences is large enough to justify the cost as opposed to installing individual POET systems.	2	Wood
24	Lake Elmo	Sustainable Water Usage Requirements in New Developments	I’ve had a number of talks with local officials in Lake Elmo and, while it is true that the water is contaminated and they are working towards resolution, the answer cannot simply be “drill another well.” <ul style="list-style-type: none"> • That’s very short-sighted. • With the explosive growth in Lake Elmo (and I am not anti-growth), I’ve been told by city staff that, despite the current water shortage, there have been no requirements for the new developments to use less water/use water more efficiently. • Swimming pools, yards with in ground sprinklers and herbicide-reliant yards are filling in all of the undeveloped land in and around Lake Elmo. • We are already water short, and we are doubling the close-in population with no requirements on the developers or homeowners to take a forward-looking, 21st century approach to water usage. • In short, we are boiling the frog slowly. 	10	Online
25	Lakeland/ Lakeland Shores	Wood – Lakeland/ Lakeland Shores 1a	Provide treatment of an existing municipal water supply: This conceptual project would provide treatment of Lakeland’s existing municipal water supply. Lakeland could provide treatment at their existing municipal supply wells to address any future PFAS contamination. The city is currently treating the water at each well with pressurized, permanganate coated GAC to address iron and manganese levels. As a result, there is potentially space available and land that can be purchased by the city to add new PFAS treatment technology. There is also a strong financial preference to reuse these treatment systems as they were recently updated.	4	Wood
26	Lakeland/ Lakeland Shores	Wood – Lakeland/ Lakeland Shores 1b	Provide treatment of an existing municipal water supply: This conceptual project would provide treatment of Lakeland’s existing municipal water supply. Lakeland could install a centralized WTP to address any future PFAS contamination in their two existing municipal supply wells. The WTP would be able to treat water from both wells. In order to convey water to the WTP, a dedicated raw water line would be constructed between the sites, which are 2.3 miles apart. However, these wells are currently not contaminated and do not require treatment for PFAS at this time.	4	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
27	Lakeland/ Lakeland Shores	Wood – Lakeland/ Lakeland Shores 2	Drill new municipal supply wells in optimized locations: This conceptual project would drill one or more new municipal supply wells in Lakeland. If either or both of their existing municipal supply wells were to become contaminated with PFAS, Lakeland could drill new wells in optimized locations where there is no evidence of PFAS contamination. However, there is a moratorium on drilling new wells in the Mt. Simon aquifer and there is uncertainty as to the migration of PFAS from upgradient and/or higher stratigraphy aquifers, given the downgradient position of the city for contamination in West Lakeland. Thus, providing treatment at existing well sites is preferred until additional wells are required. However, if Lakeland became a regional water provider for neighboring communities such as West Lakeland and Afton or portions of Afton, they would need to drill new wells to meet the added demand.	5	Wood
28	Lakeland/ Lakeland Shores	Wood – Lakeland/ Lakeland Shores 3	Connect private wells and non-community public water systems to an existing municipal water system: This conceptual project would extend waterlines to connect existing neighborhoods on private wells to Lakeland’s municipal water system. Lakeland has connected residents with private wells to their municipal water system each year and will continue to do so. According to the city, many residents that are on the municipal water system have also kept their private wells for irrigation. However, it is unknown if the city will require these residents to seal their wells if they are brought onto the municipal water system as a result of PFAS contamination. If these residences were connected to the city’s municipal water system, irrigation demands would need to be considered and water conservation efforts would need to be enforced to minimize peak demands on the existing municipal water system. According to available data for 2015, approximately 206 homes are on private wells. Bringing these private wells onto the city’s municipal water system would add 140,300 gallons per day during a maximum-day scenario, which would not require additional well capacity in Year 2020, but would require additional water supply in Year 2040. Total water usage per capita demand is currently at 97 gallons per capita per day, so the installation of smart irrigation controllers would help to reduce overall water consumption and help the city meet the Minnesota Department of Natural Resources (DNR) water conservation goal of 75 gallons per capita per day (DNR, 2018).	3	Wood
29	Lakeland/ Lakeland Shores	Wood – Lakeland/ Lakeland Shores 4	Provide POET systems for private wells and non-community public water systems: This conceptual project would provide POET systems for private wells and/or non-community public water systems in Lakeland and/or Lakeland Shores. Providing POET systems would likely only be necessary for two properties north of I-94 and west of State Highway 95. If connected to the municipal water system, the new water line would need to be routed	1	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			west under State Highway 95 and a booster pump station would be required as there is a 100-foot elevation difference. In terms of cost/benefit, that option would likely be infeasible for the purpose of serving only two households. Therefore, POET systems are the most-likely final solution for these households.		
30	Maplewood	Wood – Maplewood	Connect private wells and non-community public water systems to an existing municipal water system: This conceptual project would extend waterlines to connect residences currently on private wells in Maplewood to St. Paul Regional Water Services (SPRWS). This option would be primarily for those wells south of I-494.	3	Wood
31	Maplewood	Wood – Maplewood 2	Provide POET systems for private wells and non-community public water systems: This conceptual project would provide POET systems for private wells and/or non-community public water systems in Maplewood. This option would be most applicable for private wells that could not be connected to SPRWS.	1	Wood
32	Newport	Wood – Newport 1a	Provide treatment of an existing municipal water supply: This conceptual project would provide treatment of Newport’s existing municipal water supply. Approved treatment technologies (such as GAC) could be implemented at each of the existing supply wells to address any future PFAS contamination. Considerations for available space need to be made. While Well 1 has available space, there is limited space available at Well 2. However, the Minnesota Department of Transportation owns a parcel southwest of Well 2 that they have offered to the city in the past, which may be a site to consider acquiring for future treatment. Otherwise, the city may need to consider purchasing other available land for WTPs.	4	Wood
33	Newport	Wood – Newport 1b	Provide treatment of an existing municipal water system: This conceptual project would provide treatment of Newport’s existing municipal water supply. A centralized WTP could be constructed to treat water from both municipal supply wells as the distance between them is approximately 3,000 linear feet. However, the new raw water transmission main would need to cross Highway 61. It may be possible to repurpose the 8” water main that crosses Highway 61 at Glenn Road as a raw water transmission main between the two well sites. A new 600-linear-foot, 8” water main along 7th Avenue between 12th Street and 13th Street is necessary on the west side of the highway to reestablish looped water mains.	4	Wood
34	Newport	Wood – Newport 2	Drill new municipal supply wells in optimized locations: This conceptual project would drill one or more new municipal supply wells for Newport. Newport does not require new municipal supply wells to meet current or projected potable water demands through 2040. However, if either or both of their existing municipal supply wells were to become contaminated with PFAS, Newport could drill new wells in optimized locations	5	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			where there is no evidence of PFAS contamination. However, because there is uncertainty as to the migration of PFAS from upgradient and/or higher-stratigraphy aquifers, and the location of future contamination is unknown, it is preferred to provide treatment at the existing well sites until additional wells are required. New wells would also be required if Newport were ever to become a supply of clean drinking water to meet additional demand.		
35	Newport	Newport 3/ Municipal Water Service Area Expansion	Expand city water service area to replace private wells.	3	Online
36	Newport	Wood – Newport 4	Provide POET systems for private wells and non-community public water systems: This conceptual project would provide POET systems for private wells and/or non-community public water systems in Newport. This option would be most applicable for those residences that cannot be connected to the city’s municipal water system. POET systems could be considered for 14 residences in the southeast corner. However, there is a Cottage Grove water main that extends into this area to service the TEN-E Packaging Plant, so there is potential that Cottage Grove could serve the residents in this area as well (see the Wood – Cottage Grove – Newport 1 project).	1	Wood
37	Newport	Wood – Newport 5	Create new small community water systems with treatment: This conceptual project would create one or more new small community water systems in Newport. Newport is actively connecting as many residents as possible to the city’s municipal water system. However, for those areas where connection is infeasible, a small community water system could be installed. A small community water system would be feasible for the 14 residences in the southeast corner of the city, if treatment is required in the future.	2	Wood
38	Newport	Monitor Newport Municipal Wells, Filter if Needed	Regularly monitor Newport’s two municipal wells, prepare action plan (for filtering, temporary supply from interconnect, etc.) in case of exceedance, and implement action plan if needed.	N/A	Online
39	Newport	Newport Looping	Loop pressure zones within Newport to improve resilience in the event of a supply disruption.	N/A	Online
40	Oakdale	Wood- Oakdale 1b	Provide treatment of an existing municipal water supply and drill new municipal supply wells in optimized locations: This conceptual project would provide treatment of	4, 5	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			municipal supply wells in Oakdale. This option would expand the existing GAC WTP at the Public Works location and add new wells in the area to replace the four affected wells, essentially creating a new well field and centralized WTP.		
41	Oakdale	Wood-Oakdale 1c	Provide treatment of an existing municipal water supply: This conceptual project would provide treatment of Oakdale’s existing municipal water supply. Oakdale took Well 6 out of service due to high iron and manganese levels; however, according to available data, it is not contaminated with PFAS. Providing treatment at Well 6 could either replace some of the contaminated well(s) or provide for future demand in the North Pressure Zone. If Well 6 were to serve other areas of Oakdale, infrastructure changes would be required.	4	Wood
42	Oakdale	Wood-Oakdale 2	Drill new municipal supply wells in optimized locations: This conceptual project would drill one or more new municipal supply wells in Oakdale. According to available data and similar to Lake Elmo, the northern region of the city has detectable levels of PFAS, but HI values are less than 1. An option may be to drill new wells in the northern region to supply the southern region. However, considerations for this option would need to be made regarding additional water quality parameters such as iron and manganese, and the potential impacts on White Bear Lake and/or the well restrictions for those located within a 5-mile radius of White Bear Lake. Furthermore, wells in the northern zone are currently only able to supply the north pressure zone of the city’s municipal water system and water supply to other zones would require infrastructure changes.	5	Wood
43	Oakdale	Wood-Oakdale 3	Connect private wells and non-community public water systems to an existing municipal water system: This conceptual project would extend waterlines to connect neighborhoods currently on private wells to Oakdale’s municipal water system. The residential neighborhood of Olsen Lake could be easily connected to the city’s municipal water system.	3	Wood
44	Oakdale	Wood-Oakdale 4	Provide POET systems for private wells and non-community public water systems: This conceptual project would provide POET systems for private wells and/or non-community in Oakland. This option would be most applicable for those residences with PFAS-impacted private wells that cannot be brought onto the city’s municipal water system.	1	Wood
45	Oakdale	Wood-Oakdale 5	Create new small community water systems with treatment: This conceptual project would create a new small community water system in Oakdale. The residential neighborhood of Olsen Lake is the only pocket of homes in Oakdale that appear suitable for a small community water system. However, this option is less feasible than connecting these homes to the existing municipal water system.	2	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
46	Oakdale	Wood-Oakdale 6	Connect a subset of a community to SPRWS: This conceptual project would connect Oakdale to SPRWS. However, there are concerns with water quality, cost, taste, public acceptability, etc. Oakdale does have 16" and 12" trunk water mains within one mile of the Maplewood border that could be used to convey SPRWS's water throughout its water system.	7	Wood
47	Prairie Island Indian Community	Wood-PIIC 2	Provide POET systems for private wells and non-community public water systems: This conceptual project would drill a new well and provide POET systems for every new residence planned for this community. The Prairie Island Indian Community is currently planning 71 homes and a commercial development in this area.	1, 5	Wood
48	St. Paul Park	Wood-St. Paul Park 1	Provide treatment of an existing municipal water supply: This conceptual project would provide treatment of St. Paul Park's existing municipal water supply. The city is currently installing a temporary 2,200 gallons per minute (gpm) WTP to treat water from Wells 3 and 4, with the intent to serve Well 2 at a future date.	4	Wood
49	St. Paul Park	Wood-St. Paul Park 2	Drill new municipal supply wells in optimized locations: This conceptual project would drill a new municipal supply well for St. Paul Park. Once St. Paul Park's WTP is online and the existing municipal supply wells can be utilized at their full potential, the city should have sufficient firm capacity (1.73 mgd) to provide for their 2040 maximum daily demands (1.7 mgd) with their largest well out of service. However, if the city plans on taking more than one well off-line for maintenance, an additional municipal supply well will be required to meet firm capacity. It is assumed that any new wells will require PFAS treatment due to the extent of the observed contamination in the area. The city had previously done a feasibility study looking at deeper wells that used the Mt. Simon-Hinckley aquifer. However, there is a moratorium on this aquifer in the Metropolitan Area and DNR seldom approves permits to pump groundwater from it. In addition, the Mt. Simon-Hinckley aquifer is known to produce water with high concentrations of radium that may require treatment for this contaminant.	5	Wood
50	St. Paul Park	Wood-St. Paul Park 3a	Connect private wells and non-community public water systems to an existing municipal water system: This conceptual project would extend waterlines to connect neighborhoods on private wells to St. Paul Park's municipal water system. Very few private wells are left in St. Paul Park, but those that remain, particularly the homes on the south side of the city, could be connected to the city's system.	3	Wood
51	St. Paul Park	Wood-St. Paul Park 3b	Connect private wells and non-community public water systems to an existing municipal water system: This conceptual project would extend waterlines to connect	3	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			new developments to St. Paul Park's municipal water system, such as the new Forest Edge housing development.		
52	St. Paul Park	Wood-St. Paul Park 3c	Connect private wells and non-community public water systems to an existing municipal water system: This conceptual project would extend waterlines to connect new developments to St. Paul Park's municipal water system, such as the vacant parcels at the south end of St. Paul Park that are owned by the railroad but may get developed if sold.	3	Wood
53	St. Paul Park	Wood-St. Paul Park 4	Provide POET systems for private wells and non-community public water systems: This conceptual project would provide POET systems for private wells and/or non-community public water systems in St. Paul Park. Two homes north of the State Highway 61 are currently on private wells and, if they were to become contaminated with PFAS, could be given POET systems as a short-term measure. There is no benefit to create a small community water system for two homes; however, there is a potential for these homes to connect to Cottage Grove's municipal water system in the future if Cottage Grove extended their waterlines.	1	Wood
54	West Lakeland	Wood-West Lakeland 1	Provide POET systems for private wells and non-community public water systems: This conceptual project would provide POET systems for private wells and/or non-community public water systems in West Lakeland. POET systems are already being implemented and the interim solution is providing residents with bottled water. There will be a cost tradeoff between this option and implementing small community water systems for these residences.	1	Wood
55	West Lakeland	Wood-West Lakeland 2a	Create new small community water systems with treatment: This conceptual project would create a new small community water system in West Lakeland, which could be located south of Nordic Avenue on Nordic Circle. This system would supply five homes and require one shared, treated groundwater well. This option would require approximately 1,430 linear feet of 2" diameter PVC piping. A consideration for implementing this solution would be the cost tradeoff of this option as opposed to individual POET systems and resident/community preference.	2	Wood
56	West Lakeland	Wood-West Lakeland 2b	Create new small community water systems with treatment: This conceptual project would create a new small community water system in West Lakeland, which could be located east of Neal Ave on 4th Street. This system would supply eight homes and require one shared, treated groundwater well. This option would require approximately 2,520 linear feet of 2" diameter PVC piping.	2	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
57	West Lakeland	Wood-West Lakeland 2c	Create new small community water systems with treatment: This conceptual project would create a new small community water system in West Lakeland, which could be located east of Neal Avenue on 6th Street. This system would supply 10 homes and require 2 shared, treated groundwater wells. This option would require approximately 2,490 linear feet of 2" diameter PVC piping.	2	Wood
58	West Lakeland	Wood-West Lakeland 2d	Create new small community water systems with treatment: This conceptual project would create a new small community water system in West Lakeland, which could be located north of 10th Street on Paris Avenue. This system would supply 20 homes and require 2 shared, treated groundwater wells. This option would require approximately 5,120 linear feet of 4" diameter PVC piping.	2	Wood
59	West Lakeland	Wood-West Lakeland 3	Drill new municipal supply wells in optimized locations: This conceptual project would drill one or more new municipal supply wells for West Lakeland. West Lakeland could establish a municipal water system by drilling new wells with WTPs and installing a new distribution system. A consideration is that the township does not currently have the resources to support a WTP or a large-scale distribution system. In addition, cost and blending water are two very large concerns for residents.	5	Wood
60	Woodbury	Wood-Woodbury 1b	Connect private wells and non-community public water systems to an existing municipal water system: This conceptual project would extend waterlines to connect neighborhoods currently on private wells to Woodbury's municipal water system. This may potentially include the southwestern region of Woodbury; however, so far, this area has not been considered to be connected to the city's municipal water system due to the large lot sizes.	3	Wood
61	Woodbury	Wood-Woodbury 2	Provide POET systems for private wells and non-community public water systems: This conceptual project would provide POET systems for private wells and/or non-community public water systems in Woodbury. This option would be most applicable for remote areas that either could not be served by the city's municipal water system or considered as an interim solution until they could be served. It is recommended that these POET systems would serve the entire house.	1	Wood
62	Woodbury	Wood-Woodbury 4	Drill new municipal supply wells in optimized locations: This conceptual project would drill one or more new municipal supply wells in Woodbury. The city's proposed plan is to construct any new wells required to meet future demands in the South Well Field. This evaluation, in conjunction with the groundwater model, will help identify if there are any optimal locations for new wells that would require no PFAS treatment in the South Well Field and other available areas within the city. As previously mentioned, while the	5	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			individual well capacities indicate the city should be able to meet future demands, running all Tamarack wells simultaneously effectively reduces the pumping capacity of each well, which has not been measured at this time. As a result, it is likely that at least one new high-capacity well will be required to meet projected water demand. However, depending upon the extent of PFAS contamination, the location of new wells may or may not be within Woodbury and/or require treatment.		
63	Woodbury	Wood-Woodbury 5a	Create new small community water systems with treatment: This conceptual project would create one or more small community water systems in Woodbury. Potential locations could be in the southeastern region where development is least likely and land use will remain mostly rural. This region is also the location of the 3M disposal site. Therefore, a new groundwater well would either need to be located upgradient from the 3M disposal site or treatment may be necessary. Another consideration for this option would be the potential impacts on the head waters of Valley Creek for which the State has implemented pumping restrictions on the city’s eastern wells. Furthermore, as part of their City Plan, Woodbury plans to develop this area in the future and extend their municipal water system to these residents.	2	Wood
64	Woodbury	Wood-Woodbury 5b	Create new small community water systems with treatment: This conceptual project would create one or more small community water systems in Woodbury. Potential locations could be in the southwestern region, which is developed with large residential lots but is not connected to Woodbury’s municipal water system.	2	Wood
65	Woodbury	Municipal Water for Salem Meadows Neighborhood, Woodbury, MN	Replace private wells, and eliminate the need for private reverse osmosis water treatment systems, by extending municipal water into the Salem Meadows neighborhood in Woodbury, MN.	3	Online
66	Woodbury	Two (2) Treatment Plant Solutions (Tamarack and South Well Fields)	Two WTP solutions (Tamarack and South Well Fields) <ul style="list-style-type: none"> • Would be a groundwater-based system. • Tamarack WTP to treat Tamarack Well Field. South WTP to treat South Well Field wells and new wells installed in the Woodbury South Well Field to meet growth demands. • Would consider costs and logistics to construct a raw water pipeline from the East Well Field to the South Well Field. 	4, 5	Online

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			<ul style="list-style-type: none"> • Would include PFAS treatment with consideration of or some combination thereof at both WTPs: <ul style="list-style-type: none"> • Treatment of iron and manganese • Lime softening • PFAS treatment (GAC or ion exchange). 		
67	Woodbury	Woodbury Centralized Treatment	<p>Centralized treatment (one WTP):</p> <ul style="list-style-type: none"> • Would be a groundwater-based system. • WTP location is flexible but should consider centralized location in southern portion of Woodbury for potential service connections to neighboring community(ies). • Would include costs and logistics to construct raw water pipeline from the Tamarack East Well Fields and South Well Fields to the centralized WTP location. • Would include PFAS treatment with consideration of or some combination thereof: <ul style="list-style-type: none"> • Treatment of iron and manganese • Lime softening • PFAS treatment (GAC or ion exchange). • Would include and assumes growth in demand for the new wells installed in Woodbury’s South Well Fields. 	4, 5	Online
68	Woodbury	Woodbury Three (3) Plant Solutions	<p>Three WTP solutions (one PFAS WTP located near each City of Woodbury Well Field for full system treatment):</p> <ul style="list-style-type: none"> • Would include treatment of iron and manganese and GAC or ion exchange. • Would include new wells to meet City of Woodbury growth. • Would not include softening. 	4, 5	Online
Multi-Community Projects					
69	Afton – Lakeland	Wood Afton-Lakeland 1	<p>Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect Afton to Lakeland’s municipal water system. In order to connect to a neighboring system such as Lakeland, Afton would need to install a municipal water system. Lakeland had previously offered to serve the downtown area and bordering communities of Afton; however, the City of Afton is hesitant to implement a municipal water system if it is owned and operated by another community because of concerns regarding what a regional agreement would entail and what the cost would mean to residents. However, the City of Afton is more receptive to this idea instead of owning, operating, and maintaining their own WTP due to the availability of resources. In addition, if Afton and Lakeland were to interconnect, the City of Lakeland would need to drill new wells to meet the additional demand. Varying</p>	6	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			topography (100+ feet) between Lakeland and neighboring communities would have to be considered and pump stations may be required.		
70	Afton – Woodbury	Wood Afton-Woodbury 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect Afton to Woodbury’s municipal water system. Afton could tie into the neighboring system of Woodbury by extending a water main along Hudson Road South to the area of contaminated non-municipal wells on the north end of the city.	6	Wood
71	Cottage Grove – Denmark	Wood – Cottage Grove – Denmark 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect Denmark to Cottage Grove’s municipal water system. If Cottage Grove were to extend their municipal water system to serve the eastern region, it would provide a connection point with Denmark. If a regional groundwater WTP or supply facility and distribution system were to be constructed in Denmark, this interconnect would provide an additional water supply for Cottage Grove.	6	Wood
72	Cottage Grove – Grey Cloud Island	Wood – Cottage Grove – Grey Cloud Island 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect Grey Cloud Island to Cottage Grove’s municipal water system. Extending Cottage Grove’s existing municipal water system to Grey Cloud Island would require several miles of new water mains to be installed in both Cottage Grove and Grey Cloud Island, since Grey Cloud Island does not currently have a municipal water system and the two communities are partially separated from each other by a fork of the Mississippi River with limited utility pathways and a railroad. A municipal water system in Grey Cloud Island may not be feasible as a standalone project from a constructability standpoint. However, expansion of the Cottage Grove municipal water system to a residential area along Grey Cloud Trail South on the southern Cottage Grove/Grey Cloud Island border (as outlined in Cottage Grove 2c Neighborhood B) could provide a more convenient pathway to connect Grey Cloud Island to Cottage Grove’s municipal water system.	6	Wood
73	Cottage Grove – Newport	Wood – Cottage Grove – Newport 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would expand an interconnect between Cottage Grove and Newport. Newport currently has a packaging plant located in the southeast corner that is being supplied by Cottage Grove’s municipal water system. This existing interconnect could be expanded to supply the small neighborhood on Oakridge Drive. If Newport’s municipal supply wells were to become contaminated with PFAS, they could extend Cottage Grove’s water main to connect to their municipal water system via a	6	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			3,600-foot water main. However, considerations regarding looping in the distribution system and managing pressure zones would need to be made.		
74	Cottage Grove – St. Paul Park	Wood-Cottage Grove – St. Paul Park 1a	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect a portion of St. Paul Park to Cottage Grove’s municipal water system. St. Paul Park could connect the two homes mentioned in Wood-St. Paul Park 4 to Cottage Grove’s municipal water system, since Cottage Grove plans to connect the adjoining neighborhoods through their Expedited Project 100014 and extending lines to their proposed Neighborhood A (see Wood-Cottage Grove 2c).	6	Wood
75	Cottage Grove – St. Paul Park	Wood-Cottage Grove – St. Paul Park 1b	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would expand an interconnect between Cottage Grove and St. Paul Park. Cottage Grove could provide water to St. Paul Park by utilizing their existing interconnect, which has an estimated capacity of 350 gpm. This is approximately 40% of St. Paul Park’s current maximum daily demand if Cottage Grove has a sufficient water supply. This interconnect is currently for emergency use only; however, if the existing 350-gpm interconnect and the 2,200-gpm WTP in St. Paul Park were operational, this would allow St. Paul Park to meet their current 2020 and future 2040 demands (unless more than one well was taken off-line at a time).	6	Wood
76	Cottage Grove – Woodbury	Wood Cottage Grove – Woodbury 1a	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect portions of Woodbury to Cottage Grove’s municipal water system. There is no existing interconnect between Cottage Grove and Woodbury; however, Cottage Grove could extend lines to supply treated water to the southwest region of Woodbury. This would require new water distribution infrastructure to be installed in Woodbury.	6	Wood
77	Cottage Grove – Woodbury	Wood Cottage Grove 6d – Woodbury 1b	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect portions of Cottage Grove to Woodbury’s municipal water system. Woodbury could extend their water lines south to provide the northeastern region of Cottage Grove with treated water. This option would require new water supply infrastructure to be installed in both Cottage Grove and Woodbury. In addition, Woodbury would need to provide treatment at their existing municipal supply wells and new municipal supply wells (potentially with treatment) would be required to meet the additional demand.	6	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
78	Grey Cloud Island Township – St. Paul Park	Wood – Grey Cloud Island – St. Paul Park 1	Create a new regional water public water through interconnects with neighboring communities: This conceptual project would connect portions of Grey Cloud Island to St. Paul Park’s municipal water system. Grey Cloud Island could connect to St. Paul Park’s municipal water system to supply water to the northern portion of Grey Cloud Island along Grey Cloud Trail South. This would require treatment and expansion of St. Paul Park’s municipal water system (in progress) in order to meet future demands of St. Paul Park and Grey Cloud Island. New water lines would also need to be installed in Grey Cloud Island along Grey Cloud Trail South to serve the northern residents.	6	Wood
79	Lake Elmo – Oakdale	Wood – Lake Elmo-Oakdale 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would create an interconnect between Lake Elmo and Oakdale. Lake Elmo had previously evaluated an interconnect with Oakdale in a study by Bolton & Menk but found that the cost to reconfigure their current municipal water system exceeded the cost of drilling a new well. Two existing interconnects between Lake Elmo and Oakdale could supply 0.58 mgd of clean water or receive treated water. The capacity of these interconnects would need to be verified to determine if an interconnect is a viable option from a regional standpoint. In addition, the difference in hydraulic grade may require booster pump station(s) to deliver water from Lake Elmo to Oakdale.	6	Wood
80	Lake Elmo – Oakdale	15th Street North Water Main	Lake Elmo has a water main along Inwood Avenue – County 13 – with a water tower. Oakdale has a water main on 15th Street North ending at the border with Lake Elmo. Connecting these two water mains by a pipe running east to west along 15th Street North will provide public water availability in the future. The Armstrong Farm has donated their development rights to the Minnesota Land Trust and planted over 65,000 trees – there will be no further subdivisions on 15th Street North.	6	Online
81	Lake Elmo – West Lakeland	Wood – Lake Elmo-West Lakeland 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect West Lakeland to Lake Elmo’s municipal water system. However, Lake Elmo’s demands would need to be met prior to providing water and new infrastructure would need to be installed to provide West Lakeland with a municipal water system.	6	Wood
82	Lake Elmo – Woodbury	Wood – Lake Elmo-Woodbury 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would create an interconnect between Lake Elmo and Woodbury to supply clean water or receive treated water. Considerations for differences in system pressure and crossing I-94 would need to be made, which may make this a less technically feasible option than other neighboring communities.	6	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
83	Lakeland/Lakeland Shores – West Lakeland	Wood – Lakeland/Lakeland Shores – West Lakeland 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect West Lakeland to Lakeland’s municipal water system. Under this option, Lakeland has the potential to become a provider of treated groundwater to the neighboring community of West Lakeland. This could include both the southern half of West Lakeland, which has experienced extensive PFAS contamination; as well as the northern half, which was previously contaminated by a trichloroethylene plume. West Lakeland seemed very open about the possibility of receiving water from Lakeland; however, West Lakeland would need to install a municipal water system. If Lakeland became a regional water provider for neighboring communities such as West Lakeland and Afton or portions of Afton, they would need to drill new wells to meet demand. Varying topography (100+ feet) between Lakeland and neighboring communities would have to be considered, and additional elevated storage and pump stations may be required.	6	Wood
84	Maplewood – Newport	Wood – Maplewood – Newport 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect portions of Maplewood to Newport’s municipal water system. This would be most applicable for Maplewood residences with non-municipal wells that cannot be connected to SPRWS or do not want a POET system installed.	6	Wood
85	Maplewood – Woodbury	Wood – Maplewood – Woodbury 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect portions of Maplewood to Woodbury’s municipal water system. This is most applicable for Maplewood residences with non-municipal wells that cannot be connected to SPRWS or do not want a POET system installed.	6	Wood
86	Newport – St. Paul Park	Newport-Saint Paul Park Water Interconnect	Cross-connect municipal water supplies to improve resilience in event of supply disruption.	6	Online
87	Newport – Woodbury	Newport-Woodbury Water Interconnect	Cross-connect municipal water supplies to improve resilience in event of supply disruption.	6	Online
88	Oakdale – Woodbury	Wood-Oakdale-Woodbury 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would create an interconnect between Oakdale and Woodbury. Oakdale currently has a 2.88 mgd interconnect with Woodbury that is	6	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			capable of meeting the city's current water supply gap for both a 2020 maximum daily demand (1.7 mgd needed) and a 2040 maximum daily demand (2.7 mgd needed). Considerations for this option would be any required infrastructure upgrades to accommodate differences in hydraulic conditions and new infrastructure to convey the water supply.		
89	Prairie Island Indian Community – Lake Elmo	Wood-PIIC-Lake Elmo 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect Prairie Island Indian Community to Lake Elmo's municipal water system. This option would require that Lake Elmo extend their water lines out to Manning Avenue. A new water distribution system would also need to be installed to convey Lake Elmo's water.	6	Wood
90	Prairie Island Indian Community – Lakeland	Wood-PIIC-Lakeland 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect Prairie Island Indian Community to Lakeland's municipal water system. In the case that Lakeland became a regional water supplier that supplied West Lakeland, Prairie Island Indian Community could connect to Lakeland's municipal water system through West Lakeland's infrastructure. This option will require a new distribution system in West Lakeland as well as in Prairie Island Indian Community for the future development.	6	Wood
91	Prairie Island Indian Community – West Lakeland	Wood-PIIC-West Lakeland 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would create an interconnect between Prairie Island Indian Community and West Lakeland. Prairie Island Indian Community could supply water to West Lakeland. A new water distribution system would need to be installed to convey the treated water in both communities. A new well in Prairie Island Indian Community would also be needed to provide redundancy for a centralized treatment and distribution system, and the wells would need to meet Minnesota's Well Code. This would require a new distribution system in West Lakeland as well as in Prairie Island Indian Community for future development.	6	Wood
92	Prairie Island Indian Community – Woodbury	Wood-PIIC-Woodbury 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would connect Prairie Island Indian Community to Woodbury's municipal water system. However, Woodbury's municipal water system would require treatment and the extension of their water distribution system lines. Additional wells within Woodbury may also be required to meet Prairie Island Indian Community's demands. The challenges associated with this option would be the installation of water lines across the Manning Avenue and the I-94 interchange.	6	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
93	West Lakeland – Afton	Wood-West Lakeland-Afton 1	Create a new regional public water system through interconnects with neighboring communities: This conceptual project would create an interconnect between West Lakeland and Afton. If Afton developed a municipal water system to provide water to their northern region, West Lakeland could tie into Afton’s system. West Lakeland would need to install new infrastructure.	6	Wood
94	Cottage Grove, Grey Cloud Island, Lake Elmo, Newport, Oakdale, St. Paul Park, and Woodbury	Wood Surface Water Regional 3	Connect subsets of communities to St. Paul regional Water Services: This conceptual project would connect the western communities to SPRWS by routing water through existing municipal water systems of neighboring communities. This would not be a standalone option for any one community and would require participation of multiple communities to take advantage of the cost savings. However, water quality and cost considerations regarding water age and potential water rates should be made.	7	Wood
Project for All Communities					
95	All Communities	Wood Surface Water Regional 1	Create a new SWTP on the Mississippi River: This conceptual project would add a SWTP on the Mississippi River to provide treated water to all communities of the East Metropolitan Area. This would not be a standalone option for any given community as it would require participation from multiple communities for cost-sharing purposes. Considerations for the location of the new SWTP would be the proximity of the two refineries and the wastewater treatment plant that discharges to the Mississippi River, and the additional treatment required. Additionally, infrastructure upgrades and installations to convey treated water would need to be considered and evaluated.	8	Wood
96	All Communities	Wood Surface Water Regional 2	Create new SWTPs on the Mississippi River and the St. Croix River: This conceptual project would supply all communities of the East Metropolitan Area with treated water from one SWTP on the St. Croix River and one SWTP on the Mississippi River. This would not be a standalone option for any one community as it would require participation from multiple communities for cost-sharing purposes. Considerations for the implementation of the St. Croix SWTP would be the permitting and regulatory review and approval process of various state and federal agencies. Considerations for the location of the new SWTP would be the proximity of the two refineries and the wastewater treatment plant that discharges to the Mississippi River, and the additional treatment required. Additionally, infrastructure upgrades and installations to convey treated water would need to be considered and evaluated.	8	Wood

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
97	All Communities	Wood Groundwater Regional 1	Create a new groundwater WTP: This conceptual project would connect communities to a centralized groundwater WTP and distribution system. Further evaluation is required to optimize regional WTP(s) and potential location(s) across the East Metropolitan Area, as well as coordination with the groundwater model to optimize new well locations. Existing municipal supply wells will be evaluated to determine how they can be incorporated into this option.	6	Wood
Other Project Submissions					
98	All Communities	Reverse Osmosis Filtration	All homes should be given reverse osmosis filtration filters: This is the only way to ensure all perfluorinated chemicals (PFCs) and perfluorooctanoic acids (PFOAs) are removed.	1	Online
99	All Communities	Non-Community Public Water Systems	MDH wants to ensure that the non-community public water system supply wells are being addressed: MDH has compiled a list of those supply wells that have been impacted by PFAS contamination and that should be considered in future scenario evaluations.	1	Online
100	All Communities	Washington County Parks	The county would like to ensure county parks have continued access to safe drinking water: There are four existing county parks and one regional trail within the PFAS-affected area. Our parks receive many thousands of visitors each year and there is also a planned county park on Grey Cloud Island that is heavily impacted by PFAS in private wells. The larger solutions for the Conceptual Water Supply Plan may in fact result in water systems that are close enough to consider connecting in park facilities. If that is not the case, at a minimum, the treatment of water within these facilities, as needed, can and should be considered to ensure safe drinking water.	1	Online
101	All Communities	Water Testing and Treatment Endowment	Endowment to fund ongoing testing and water supply maintenance, and upgrades for all areas covered by the settlement.	N/A	Online
102	All Communities	Managed Aquifer Recharge	Managed aquifer recharge includes both passive approaches where treated water is directed to unconfined aquifers, and an active approach wherein treated water is injected and recovered through wells: This is also called aquifer storage and recovery (ASR). Both methods are used around the world and have been implemented in Minnesota. For communities affected by perfluorooctanesulfonic acid (PFOS) and PFOA, a bubble of clean water could be injected into the flow field of existing wells and be drawn upon for public water supply. This would also displace and redirect polluted water that may be flowing to the pumping center. An interdisciplinary team led by the Water Resources Center (WRC) is currently evaluating the engineering, hydrogeologic,	N/A	Online

Project Number	Community	Project Name	Project Description	WSIO	Source ^a
			economic, and policy benefits of and barriers to aquifer recharge in four places in Minnesota and one of those study areas is Washington County. The team will produce recommendations for recharge and how the State might proceed if recharge is the economic and practical approach.		
103	Washington County	Washington County Aquifer Augmentation District (WCAAD)	This water supply option would establish a WCAAD, built on the premise of targeted ASR principles. Normal aquifer recharge projects are typically designed to replenish water in an aquifer, but under this plan groundwater recharge is used for dilution and dispersion, the two primary means of contaminant attenuation these past decades, which would be used to lower in-situ PFC concentrations in the bedrock aquifers. In essence, it is a water flooding of the bedrock aquifers where recharge water increases potentiometric levels and augments groundwater flow, and serves as flushing of the resident PFC impacted groundwater with fresh (treated) water. This would be accomplished through the installation of both vertical injection wells and horizontal wells, or an underground injection aqueduct down the spine of the county's groundwater divide. Several ASR injection systems would need to be installed, based on the current understanding of groundwater impacts. A horizontal injection system could transect the groundwater divide running from the Washington County Landfill in Lake Elmo in the north and southward through eastern Woodbury and south of the Woodbury Disposal Site, and then deviate southeast to the 3M Cottage Grove Plant. The source water would be treated Mississippi River water. To address PFC-impacted wells in West Lakeland Township and northern Afton, a second ASR injection system would be installed utilizing St. Croix River water. A third ASR system would be installed in the southeast portion of the county with Mississippi River water to augment the bedrock aquifer in St. Paul Park and Grey Cloud Island, and running east to the 3M Cottage Grove plant. Under this system, largely, individual residences and municipalities would continue to own and maintain their current water distribution systems, a major cost in developing new infrastructure. The county would establish and run the ASR district.	N/A	Online

1 a. Wood = projects initially identified by Wood Environment & Infrastructure Solutions, Inc. and subsequently refined using input from the work
2 groups and Subgroup 1. Online = projects submitted via the online project portal located on the Minnesota 3M Settlement website
3 (<https://3msettlement.state.mn.us/>) between 8/6/2019 and 9/4/2019.

4
5

1 **References**

- 2 DNR. 2018. Minnesota Water Conservation Report 2018. November. Available:
- 3 [https://files.dnr.state.mn.us/waters/watermgmt_section/water_conservation/2018-water-](https://files.dnr.state.mn.us/waters/watermgmt_section/water_conservation/2018-water-conservation-report.pdf)
- 4 [conservation-report.pdf](https://files.dnr.state.mn.us/waters/watermgmt_section/water_conservation/2018-water-conservation-report.pdf)

DRAFT

Appendix E. Scenario results

- 1
- 2 Appendix E is provided under separate cover.

DRAFT

Appendix F. Scenarios supporting documentation

1

2 **F.1 Unit cost estimations**

3 **F.1.1 Introduction**

4 This section summarizes the unit costs that were developed for drinking water-related construction
5 projects within Washington County, Minnesota. This information assisted in determining the total
6 estimated costs associated with conceptual projects included in this Conceptual Plan.

7 Costs were developed for the following construction projects (and described in more detail in the
8 sections below):

- 9 • Installing water mains (Section F.1.2)
- 10 • Constructing water storage tanks or towers (Section F.1.3)
- 11 • Constructing booster pump stations (Section F.1.4)
- 12 • Constructing buildings used for booster pump stations, well pump houses, and water treatment
13 plants (Section F.1.5)
- 14 • Drilling new municipal and non-municipal wells (Section F.1.6)
- 15 • Acquiring land (Section F.1.7).

16 **F.1.2 Water mains**

17 The approximate unit cost (in dollars per foot) of installing water mains in Washington County was
18 estimated for this Conceptual Plan. This allowed for the total cost of water main installation to be
19 calculated based on the distance of the water main installation project.

20 The unit costs were developed for varying percentages of the pipe that would be aligned under
21 roadways in both urban and rural areas, and included costs for street reconstruction, materials, labor,
22 and permitting. The cost estimates for pavement removal/replacement, trench excavation/backfill, pipe,
23 and installation costs were found using bid tabulations from cities within Washington County along with
24 the Washington County Municipal Water Coalition Water Supply Feasibility Assessment (Metropolitan
25 Council, 2016). All pricing from years before 2019 were moved forward to 2019 pricing using the
26 Construction Cost Index from the Engineering News Record (ENR). The assumptions used in the analysis
27 are as follows:

- 28 • The total cost for street reconstruction was applied for 100% in roadways (or 100% under
29 roadway pavement), and assumed two lanes of roadway would be removed and replaced. Half
30 of the total cost for street reconstruction was applied for 50% in roadways and assumed
31 one lane of roadway would be removed and replaced. None of the costs for street
32 reconstruction were applied for 0% in roadways and no lanes were assumed to be removed or
33 replaced.
- 34 • Some of the pipe would not be installed under roadways as defined by 100%, 50%, or 0% in
35 roadways (or under roadway pavement).
- 36 • The curb, gutter, and sidewalks would be removed and replaced for water mains in urban areas.
37 Curb, gutter, and sidewalks were not included for water mains installed in rural areas.
- 38 • The pipe would be buried 8-feet deep.

- 1 • Excavation protection was included for water main installation in urban and rural areas.
2 Protection of existing utilities is also included.
- 3 • Fire hydrants were assumed to be included every 300 feet.
- 4 • For pipes with diameters ranging from 4 to 8 inches, valves were assumed to be installed every
5 400 feet and fittings were assumed to be installed every 200 feet.
- 6 • For pipes with a 12-inch diameter, valves were assumed to be installed every 600 feet and
7 fittings were assumed to be installed every 200 feet.
- 8 • For pipes with diameters ranging from 16 to 24 inches, valves were assumed to be installed
9 every 800 feet and fittings were assumed to be installed every 200 feet.
- 10 • For pipes with diameters ranging from 20 to 42 inches, the costs for valves and fittings were
11 included in the unit costs per linear foot of pipe.
- 12 • Stormwater protection and utility conflicts were taken into consideration as part of the street
13 reconstruction estimates. Bid tabs used included stormwater protection in their estimates and
14 \$2 per linear foot was also included for erosion control.
- 15 • Engineering permits, right-of-way permits, and construction inspections were included as a
16 percentage of the total costs (assumed in the 15% professional services).

17 The remaining costs were converted using the sum within the project total from varying bid tabulations
18 to estimate the cost per linear foot of each contributing item. Table F.1 outlines the individual costs that
19 were included in the total unit price per linear foot for water main installations.

20 Table F.2 summarizes the total cost per linear foot for water main installations of varying pipe sizes. The
21 costs are organized by the diameter of the pipe, the percentage in the roadway, and the type of area
22 where the project would occur. The total project cost can be estimated by multiplying the unit cost (in
23 dollars per linear foot) by the approximate distance of the water main installation project (in linear feet).
24 Pricing in Table F.2 assumes that rock excavation is required for 50% of the water main alignment.

1 **Table F.1. Individual costs included in water main installations.**

Urban	Rural
<ul style="list-style-type: none"> • Roadway and driveway removal/replacement • Curb, gutter, and sidewalk removal/replacement • Removal/replacement of median • Trench excavation and backfill • Excavation protection • Landscape repairs and improvements • Clearing and grubbing • Rock excavation (0%, 50%, 100% of alignment) • Ductile iron piping, fittings, and valves • Existing sewer, water, and utility pipe removal/replacement • Pipe insulation and bedding • Other trenching costs • Costs of construction including mobilization, overhead, profit, and general conditions • Labor • Engineering permits and city inspections 	<ul style="list-style-type: none"> • Roadway and driveway removal/replacement • Trench excavation and backfill • Excavation protection • Landscape repairs and improvements • Clearing and grubbing • Rock excavation (0%, 50%, or 100% of alignment) • Ductile iron pipping, fittings, and valves • Pipe insulation and bedding • Other trenching costs • Costs of construction including mobilization, overhead, profit, and general conditions • Labor • Engineering permits and city inspections

2
3 **Table F.2. Unit cost summary for water main installation.**

Pipe diameter (inches)	Percent in roadway (%)	Urban cost per foot (\$ per foot)	Rural cost per foot (\$ per foot)
2"	0%	\$178	\$99
2"	50%	\$370	\$142
2"	100%	\$562	\$184
4"	0%	\$208	\$129
4"	50%	\$400	\$171
4"	100%	\$592	\$213
6"	0%	\$217	\$137
6"	50%	\$409	\$179
6"	100%	\$601	\$222
8"	0%	\$226	\$145
8"	50%	\$417	\$187
8"	100%	\$609	\$229
12"	0%	\$240	\$158
12"	50%	\$432	\$200

Pipe diameter (inches)	Percent in roadway (%)	Urban cost per foot (\$ per foot)	Rural cost per foot (\$ per foot)
12"	100%	\$624	\$242
16"	0%	\$260	\$176
16"	50%	\$452	\$218
16"	100%	\$644	\$260
18"	0%	\$276	\$191
18"	50%	\$468	\$234
18"	100%	\$660	\$276
20"	0%	\$371	\$285
20"	50%	\$563	\$327
20"	100%	\$754	\$370
24"	0%	\$411	\$324
24"	50%	\$603	\$366
24"	100%	\$795	\$408
30"	0%	\$474	\$385
30"	50%	\$666	\$427
30"	100%	\$858	\$469
36"	0%	\$560	\$469
36"	50%	\$752	\$511
36"	100%	\$944	\$553
42"	0%	\$614	\$520
42"	50%	\$806	\$562
42"	100%	\$998	\$604
48"	0%	\$680	\$584
48"	50%	\$872	\$626
48"	100%	\$1,064	\$668
54"	0%	\$747	\$648
54"	50%	\$938	\$690
54"	100%	\$1,130	\$732
60"	0%	\$808	\$708
60"	50%	\$1,000	\$750
60"	100%	\$1,192	\$792

1 For watermains that require rock excavation along 100% of the pipe length a total of \$58 per
2 cubic yard is added to the cost per linear foot of watermain installation. Table F.3 displays the
3 cost summary for watermain projects that require 100% rock excavation and the unit cost of
4 watermains without rock excavation being required.

1 Table F.3 – Unit Cost Summary with and without Rock Excavation

Pipe Diameter (in)	Percent in Roadway	Urban Costs per Foot without Rock Excavation	Rural Costs per Foot without Rock Excavation	Urban Cost for Rock Excavation per Cubic Yard	Rural Cost for Rock Excavation per Cubic Yard	Urban Costs per Foot with 100% Rock Excavation	Rural Costs per Foot with 100% Rock Excavation
2	0%	\$152	\$71	\$42	\$46	\$204	\$128
2	50%	\$344	\$113			\$396	\$170
2	100%	\$535	\$155			\$588	\$213
4	0%	\$180	\$98	\$46	\$50	\$236	\$160
4	50%	\$372	\$140			\$428	\$202
4	100%	\$564	\$183			\$620	\$244
6	0%	\$187	\$104	\$49	\$53	\$247	\$170
6	50%	\$379	\$147			\$439	\$212
6	100%	\$571	\$189			\$631	\$255
8	0%	\$194	\$110	\$52	\$56	\$258	\$179
8	50%	\$385	\$152			\$449	\$222
8	100%	\$577	\$194			\$641	\$264
12	0%	\$204	\$119	\$58	\$62	\$276	\$196
12	50%	\$396	\$162			\$468	\$238
12	100%	\$588	\$204			\$659	\$281
16	0%	\$221	\$134	\$64	\$68	\$299	\$218
16	50%	\$412	\$176			\$491	\$260
16	100%	\$604	\$218			\$683	\$303
18	0%	\$235	\$147	\$67	\$71	\$317	\$235
18	50%	\$427	\$190			\$509	\$278
18	100%	\$619	\$232			\$701	\$320
20	0%	\$327	\$239	\$70	\$74	\$414	\$331
20	50%	\$519	\$282			\$606	\$373
20	100%	\$711	\$324			\$798	\$415
24	0%	\$365	\$274	\$76	\$80	\$458	\$373
24	50%	\$556	\$316			\$650	\$416
24	100%	\$748	\$359			\$841	\$458
30	0%	\$422	\$330	\$84	\$89	\$527	\$440
30	50%	\$614	\$372			\$718	\$482
30	100%	\$806	\$414			\$910	\$524
36	0%	\$503	\$408	\$94	\$98	\$618	\$529
36	50%	\$694	\$450			\$810	\$572
36	100%	\$806	\$493			\$1,002	\$614
42	0%	\$503	\$454			\$677	\$586

Pipe Diameter (in)	Percent in Roadway	Urban Costs per Foot without Rock Excavation	Rural Costs per Foot without Rock Excavation	Urban Cost for Rock Excavation per Cubic Yard	Rural Cost for Rock Excavation per Cubic Yard	Urban Costs per Foot with 100% Rock Excavation	Rural Costs per Foot with 100% Rock Excavation
42	50%	\$694	\$496	\$102	\$107	\$869	\$628
42	100%	\$886	\$538			\$1,061	\$671
48	0%	\$550	\$512	\$111	\$116	\$749	\$655
48	50%	\$742	\$554			\$941	\$698
48	100%	\$934	\$596			\$1,133	\$740
54	0%	\$611	\$570	\$121	\$125	\$822	\$726
54	50%	\$803	\$612			\$1,013	\$768
54	100%	\$1,055	\$655			\$1,205	\$810
60	0%	\$729	\$627	\$127	\$131	\$887	\$789
60	50%	\$921	\$669			\$1,079	\$831
60	100%	\$1,113	\$711			\$1,271	\$874

1

2 Annual operation and maintenance costs for water mains are assumed to be 0.5% of the
3 installation cost and are inclusive of general operation and maintenance costs, such as; valve
4 exercising, fire hydrant or blowoff flushings, water main repairs, and water quality
5 sampling. Recapitalization costs are also included in the annual O&M cost assuming a 50-year
6 service life, or 2% of the installation cost.

7 **F.1.3 Storage tanks or towers**

8 The approximate unit cost (in dollars per gallon) of constructing a storage tank or tower in Washington
9 County was estimated for this Conceptual Plan. This allowed for the total cost of a storage tank or tower
10 to be calculated based on the gallons of water the tank or tower would hold.

11 The unit costs related to sitework and storage tank construction were estimated using a bid tabulation
12 from Woodbury, Lake Elmo, Hamburg, Freeport, and Lyon County. All pricing from years before 2019
13 were moved forward to 2019 pricing using the Construction Cost Index from ENR. The assumptions used
14 in the analysis are as follows:

- 15 • The storage tank could be constructed as a steel fluted column water tower or a steel pedestal
16 spheroid water tower. Larger volume tanks may have steel/concrete composite bases.
- 17 • The estimated cost for the storage tank does not include the costs for all required tank
18 equipment.
- 19 • Yard piping was assumed to be 200 linear feet of 24-inch ductile iron water main.
- 20 • Annual tank maintenance was assumed to be 1.5% of tank capital cost. This includes general
21 maintenance items often performed by the operations staff; such as level sensor replacement,
22 cathodic system adjustment, sediment removal, gasket replacements, screening replacements.
- 23 • Site operating costs included \$2,000 for heating and \$2,000 for general site maintenance.
24 Operator costs were assumed to be \$50 per hour for four hours per week.

- Internal and external tank coatings were assumed to be removed and recoated every 20 years at \$39 per square foot, which is based on five bid tabs from the East Metro area.

Eight water storage tank projects from Minnesota for the last 15 years yielded an average unit cost for a storage tank or tower that ranged from \$1.89 to \$6.68 per gallon, depending on the tank volume. The tank installation cost can be estimated by multiplying the unit cost (in dollars per gallon) by the storage capacity (in gallons). Then this value can be added to the estimated sitework cost of \$0.15/gallon (minimum of \$50,000) to obtain an estimated total capital cost for the project. Table F.4 provides example unit cost estimates for construction of a storage tank or tower.

Table F.4. Unit cost summary for storage tank or tower construction.

Cost per gallon (\$ per gallon)	Storage capacity (gallons)	Cost of storage tank (\$)	Sitework cost (\$)	Total capital cost (\$)	Annual O&M costs (\$)
\$6.68	75,000	\$501,000	\$50,000	\$551,000	\$31,000
\$5.12	150,000	\$768,000	\$50,000	\$818,000	\$40,000
\$3.22	500,000	\$1,611,000	\$76,000	\$1,687,000	\$70,000
\$2.47	1,000,000	\$2,469,000	\$151,000	\$2,620,000	\$101,000
\$1.89	2,000,000	\$3,784,000	\$301,000	\$4,085,000	\$150,000

O&M = operation and maintenance.

F.1.4 Booster pump stations

The approximate unit cost (in dollars per gallons per minute) of constructing a booster pump station in Washington County was estimated for this Conceptual Plan. This allowed for the total costs of a booster pump station to be calculated based on the gallon-per-minute firm pumping capacity or flow rate of the booster pump station.

The unit costs used in this analysis came from a bid tabulation in Lake Elmo. Many assumptions follow those outlined in the Washington County Municipal Water Coalition Water Supply Feasibility Assessment (Metropolitan Council, 2016) and from the 2019 RSMeans Cost Data Book. All pricing from years before 2019 were moved forward to 2019 pricing using the Construction Cost Index from ENR. The 6/10th rule was used to scale construction costs. The assumptions used in the analysis are as follows:

- Assumed four hours per week for operations staff, with an hourly labor cost estimate of \$50 per hour.
- Booster pumps assumed to run 12 hours a day.
- Pumping energy costs were assumed to be 74% of pump efficiency, using a kilowatt-hour cost of \$0.072.
- Assumed equipment maintenance to be 3% of pump capital cost.
- Additional annual maintenance costs included \$2,000 for heating the building and \$2,000 for miscellaneous building costs.

From the analysis, the unit cost to build a complete booster pump station was estimated to be \$800 for every gallon per minute. This cost includes all related sitework and assumes two pumps were used in the station. Multiplying \$871 by the number of gallons per minute sent to the booster pump station provides the total cost for equipment and construction. The horsepower of each pump relates to the pumping energy costs and contributes to the estimated annual O&M costs. Table F.5 provides an

1 example unit cost estimate for a booster pump station. This pricing includes the cost to construct a
 2 building and all required sitework.

3 **Table F.5. Unit cost summary for booster pump station construction.**

Pumping capacity or flow rate (gallons per minute)	Horsepower (hp)	Annual operating cost (\$)	Capital cost (\$)	Cost per gallons per minute (\$ per gallons per minute)
1,200	150	\$82,300	\$1,045,400	\$871

4 **F.1.5 Buildings**

5 The approximate unit cost (in dollars per square foot) of constructing a building used for a booster pump
 6 station or well pump house in Washington County was estimated for this Conceptual Plan. This allowed
 7 for the total cost of a building to be calculated based on the building size.

8 The contractor’s schedule of values from St. Paul Park’s granular activated carbon (GAC) water
 9 treatment plant were used to determine the building cost.

10 It was estimated to cost \$560 per square foot to construct a building, which includes all necessary
 11 sitework. The total cost for constructing a building can be estimated by multiplying the unit cost (in
 12 dollars per square foot) by the building size (in square feet). Table F.6 provides examples of varying costs
 13 based on the building size.

14 **Table F.6. Unit cost summary for building construction.**

Building dimensions (feet)	Building cost per square foot (\$ per square foot)	Capital cost (\$)
45' x 20'	\$560	\$504,000
30' x 15'	\$560	\$252,000
10' x 10'	\$560	\$56,000

15 **F.1.6 Municipal and non-municipal wells**

16 The approximate total cost to drill a new municipal or non-municipal well in Washington County was
 17 estimated for this Conceptual Plan.

18 For drilling a new municipal well, pricing came from the Washington County Municipal Water Coalition
 19 Water Supply Feasibility Assessment (Metropolitan Council, 2016) and a bid tabulation from Hastings,
 20 Minnesota. Using this information, the cost to drill a new municipal well capable of supplying 800–
 21 1,200 gallons per minute was estimated to be \$2,178,000. Installation costs for wells outside of this
 22 range were scaled using the 6/10th rule.

23 For drilling a new non-municipal well, the approximate cost was determined using a bid tabulation from
 24 West Lakeland. Using this information, the cost to drill a new non-municipal well capable of supplying
 25 20 gallons per minute was estimated to be \$12,000.

26 Table F.7 summarizes the estimated costs to drill a new municipal or non-municipal well. The pricing
 27 includes the costs to construct a new well house and sitework. All pricing from years before 2019 were
 28 moved forward to 2019 pricing using the Construction Cost Index from ENR.

1 **Table F.7. Unit cost summary for drilling new municipal and non-municipal wells.**

Well description	Water Pumping Rate (gallons per minute)	Capital cost (\$)
Municipal well	800–1,200	\$2,178,000
Non-municipal well (single home)	20	\$12,000

2 **F.1.7 Land acquisition**

3 The approximate unit costs (in dollars per square foot) to acquire land in Washington County was
 4 estimated for this Conceptual Plan. This allowed for the total cost of land acquisition to be calculated
 5 based on the lot size.

6 In order to estimate the current cost of land in Washington County, the costs of two lots per community
 7 were analyzed. The resources used in this analysis included Realtor.com, Zillow, and the Metro East
 8 Commercial Real Estate Services.

9 Table F.8 summarizes the results of this analysis. Based on the price per acre of each lot throughout
 10 Washington County, an estimated cost of \$3.11 per square foot was derived. The total cost of the land
 11 acquisition project can be estimated by multiplying the unit cost (in dollars per square foot) by the lot
 12 size (in square feet).

13 **Table F.8. Unit cost summary for land acquisition.** Information sorted by cost per square foot, going
 14 from lowest to highest cost.

Lot size (acres)	Community	Cost per square foot (\$ per square foot)
5.5	Denmark	\$0.93
4.2	Cottage Grove	\$1.64
3.4	St. Paul Park	\$1.82
3.0	Grey Cloud Island	\$2.04
5.1	Afton	\$2.12
1.3	Newport	\$2.18
2.6	West Lakeland	\$3.24
2.5	Oakdale	\$4.11
1.8	Lake Elmo	\$4.36
1.2	Maplewood	\$4.38
1.5	Lakeland/Lakeland Shores/Lake St. Croix Beach	\$4.41
1.4	Woodbury	\$6.03
Average Land Acquisition Cost for East Metro		\$3.11

15 **F.2 Small community water system analysis**

16 **F.2.1 Introduction**

17 This section summarizes the theoretical exercise that was performed to examine the validity of small
 18 community water systems for the rural communities in the East Metropolitan Area. Selected areas were
 19 analyzed to determine if drilling and treating a well to service 8 or 20 homes would create a more cost-
 20 effective solution over treating each non-municipal well individually with a GAC point-of-entry

1 treatment (POET) system. The analysis included neighborhoods in Afton, Grey Cloud Island, and West
2 Lakeland.

3 Important considerations for this analysis included how many homes could be grouped together and any
4 associated service requirements. The 1974 Safe Drinking Water Act states that when at least 15 service
5 connections or 25 people are served for at least 60 days a year by a single source, the water system is
6 considered a public water system, which has associated redundancy requirements (see below). A system
7 for eight homes with approximately three people per home is the maximum number of homes that can
8 be grouped together and serviced by one well without redundancy requirements. When analyzing
9 20 homes per well, the redundancy requirements consist of two wells, a certified water operator, a
10 backup generator, and additional water quality testing. These additional costs required for a public
11 water system that can service 20 homes are reflected in the analyses below.

12 **F.2.2 Methods**

13 Key steps of this analysis included identifying homes close enough to form an area to be serviced,
14 measuring the average distances between homes with ArcGIS Earth, and determining the cost of
15 creating a small community water system versus treating each well individually with a POET system. The
16 methods are described in more detail in the sections below.

17 **F.2.2.1 Well counts**

18 Well data were taken from initial well counts provided by the Minnesota Pollution Control Agency
19 (MPCA) and the Minnesota Department of Health (MDH) in 2019. These well counts do not match the
20 final private well counts used in Appendix E of the Conceptual Plan, but illustrate the conclusions of this
21 analysis with the same efficacy.

22 **F.2.2.2 Geographic information system analysis**

23 The ArcGIS Earth interface was used to identify the number of homes in each community that were
24 close enough to be considered for a small community water system. For this analysis, clusters of 8 and
25 20 homes were considered.

26 **F.2.2.3 Cost development**

27 Costs were developed by utilizing unit costs from recent bid tabulations in the project area, obtaining
28 installation quotes from private well drillers in the project area, obtaining vendor quotes for equipment,
29 and utilizing MPCA's experience and current contracted rates for installing POET systems on private
30 wells.

31 The total 20-year costs for a small community water system were calculated by summing the initial costs
32 for drilling and equipping a well 200–400-foot deep, installing 24-inch polyvinyl chloride (PVC) pipe, and
33 installing a treatment system; as well as including the anticipated 20-year O&M costs with a 3% discount
34 rate related to the net present value. It was assumed 4-inch PVC piping would be used for an 8-home
35 system and 2-inch PVC piping would be used for a 20-home system. The GAC treatment system was
36 sized based on the gallons per minute it would treat. The total 20-year O&M costs assume that PVC
37 piping would last 50 years, and a recapitalization cost was estimated along with piping maintenance
38 costs. The PVC piping service life estimate was determined from the American Society of Testing and
39 Materials' (ASTM's) Annual Book of ASTM Standards, Volume 8.04 Plastic Pipe and Building Products
40 (ASTM, 2006). The cost assumes that the well pump and pressure tank would need to be replaced every
41 10 years.

1 POET system costs used for individual homes/wells were assumed to be \$2,500 for capital costs and
 2 \$1,000 for annual O&M costs. The GAC treatment system for the wells was assumed to need
 3 maintenance and filter change-outs once yearly.

4 Legal expenses and administrative costs of setting up and running a small community water system
 5 were not accounted for in these cost estimates. Similarly, the legal, administrative, and ongoing well
 6 monitoring; and other indirect or overhead costs associated with managing the POET systems and
 7 carbon change-outs were also not accounted for in the cost estimates.


8 **F.2.3 Afton**

9 For Afton, two analyses were performed to determine if a small community water system of 8 or
 10 20 homes would create cost savings over treating non-municipal wells with POET systems.

11 The first analysis was performed to calculate the total 20-year costs for grouping 8 homes together in
 12 Afton to form a small community water system. Figure F.1 shows an example of four, eight-home
 13 groupings in Afton, located off 2nd and 3rd streets west of Neal Avenue. In Afton, there are many areas
 14 of opportunity to create small community water systems. The average distance between homes in Afton
 15 was calculated to be 350 feet using ArcGIS Earth. Thus, the average estimated feet of pipe required to
 16 connect eight homes in Afton would be approximately 2,800 feet.

17 As shown in Table F.9, grouping eight homes to create a small community water system would not
 18 provide sufficient cost savings over individual treatment with a POET system. As the number of small
 19 community water systems increase and the number of POET systems decrease, the total 20-year costs
 20 increase (Table F.9).

21 **Figure F.1. Example of four, eight-home groupings in Afton.**



22
 23
 24


Table F.9. Cost analysis for grouping eight homes in Afton.

Alternative	Groups of 8-home small community water systems	Individual homes with private wells and POETS	Initial cost (capital)	Annual operating cost	20-year cost (capital + O&M)	20-year cost (capital + O&M) net present value with 3% discount rate

1	0	1,105	\$2,763,000	\$1,105,000	\$25,747,000	\$28,620,000
2	10	1,025	\$5,653,000	\$1,125,000	\$28,715,000	\$31,688,000
3	35	825	\$12,878,000	\$1,175,000	\$36,135,000	\$39,358,000
4	65	585	\$21,548,000	\$1,235,000	\$45,039,000	\$48,562,000
5	95	345	\$30,218,000	\$1,295,000	\$53,943,000	\$57,766,000
6	135	25	\$41,778,000	\$1,375,000	\$65,815,000	\$70,038,000

1
2 A similar analysis was performed to calculate the total 20-year costs for grouping 20 homes. Figure F.2
3 shows an example of a 20-home grouping located off Trading Post Trail and 42nd Street in Afton.
4 However, Afton has limited areas where 20 homes are close enough to be connected as one small
5 community water system, and there would need to be supplemental systems with less than 20 homes
6 per group to make this option possible. The average estimated feet of pipe required to connect
7 20 homes in Afton would be approximately 7,000 feet. In order for redundancy requirements to be met,
8 two wells would be required along with a certified water operator, additional water quality testing, and
9 a backup generator for one well. As shown in Table F.10, creating a small community water system of
10 20 homes would provide no cost savings over individual treatment with POET systems.

11 **Figure F.2. Example of a 20-home grouping in Afton.**



12
13
14 **Table F.10. Cost analysis for grouping 20 homes in Afton.**

Alternative	Groups of 20-home small community water systems	Individual homes with private wells and POETS	Initial cost (capital)	Annual operating cost	20-year cost (capital + O&M)	20-year cost (capital + O&M) net present value with 3% discount rate
-------------	---	---	------------------------	-----------------------	------------------------------	--

1	0	1,105	\$2,763,000	\$1,105,000	\$25,747,000	\$28,620,000
2	10	905	\$18,193,000	\$1,535,000	\$49,055,000	\$52,660,000
3	25	605	\$41,338,000	\$2,180,000	\$84,017,000	\$88,720,000
4	35	405	\$56,768,000	\$2,610,000	\$107,325,000	\$112,760,000
5	45	205	\$72,198,000	\$3,040,000	\$130,633,000	\$136,800,000
6	55	5	\$87,628,000	\$3,470,000	\$153,941,000	\$160,840,000

1
2 From the results above, grouping 8 or 20 homes to create a small community water system is possible
3 but would not produce cost-saving benefits when compared to treating each home individually with a
4 POET system. The unit costs used for the calculations are shown in Table F.11. A map of the potential
5 small community water systems in this community is shown in Figure F.3.

6 **Table F.11. Cost summary for Afton.**

Item	Description	Source	Quantity	Units	Unit cost	Subtotal
City of Afton cost estimate for 8-home community						
Treatment facility capital costs						
1	2" piping installed	Washington County bid tabs	2,800	LF	\$97	\$272,000
2	Capital cost POET	Wood experience	4	LS	\$5,500	\$22,000
3	New private well with hook-up	E.H. Renner & Sons Well Drilling MN	400	FT	\$30	\$12,000
4	Well pump	Wood experience	1	EA	\$2,000	\$2,000
5	Pressure tank	Grainger	1	EA	\$1,000	\$1,000
Subtotal – Capital costs						\$309,000
Annual O&M costs						
6	Filter maintenance cost	Estimate	4	LS	\$1,000	\$4,000
7	Cost to replace piping	Wood experience	1	LS	\$5,500	\$5,500
Subtotal – Annual O&M costs						\$10,000
20-year O&M costs						
8	Cost to replace PVC piping	Wood experience	1	LS	\$110,000	\$110,000


Item	Description	Source	Quantity	Units	Unit cost	Subtotal
9	Well repair costs	Estimate	1	LS	\$6,000	\$6,000
10	Filter maintenance cost	Estimate	1	LS	\$80,000	\$80,000
Subtotal – 20-year O&M costs						\$196,000
Subtotal – 20-year capital + O&M costs						\$505,000
City of Afton cost estimate for 20-home community						
Treatment facility capital costs						
1	4" piping installed	Washington County bid tabs	7,000	LF	\$127	\$889,000
2	Capital cost GAC	Wood experience	1	LS	\$660,000	\$660,000
3	New well with hook-up	E.H. Renner & Sons Well Drilling MN	800	FT	\$50	\$40,000
4	Well pump	Wood experience	2	EA	\$2,000	\$4,000
5	Pressure tank	Grainger	2	EA	\$1,000	\$2,000
Subtotal – Capital cost						\$1,595,000
Annual O&M costs						
6	Annual media cost	Estimate	1	LS	\$12,000	\$12,000
7	Annual operating costs	Estimate	1	EA	\$33,000	\$33,000
8	Cost to replace piping	Wood experience	1	LS	\$18,000	\$18,000
Subtotal – Annual O&M costs						\$63,000
20-year O&M costs						
9	Cost to replace piping	Wood experience	1	LS	\$360,000	\$360,000
10	Operating costs	Estimate	1	EA	\$660,000	\$660,000
11	Well repair costs	Estimate	1	LS	\$8,000	\$8,000
12	Filter maintenance cost	Estimate	1	LS	\$240,000	\$240,000
Subtotal – 20-year O&M costs						\$1,268,000

Item	Description	Source	Quantity	Units	Unit cost	Subtotal
Subtotal – 20-year capital + O&M costs						\$2,863,000

EA = each, FT = feet, LF = linear feet, LS = lump sum, Wood = Wood Environment & Infrastructure Solutions, Inc.

1
2

Figure F.3. Potential small community water systems in Afton.



3

F.2.4 Grey Cloud Island

4 For Grey Cloud Island, two analyses were performed to determine if a small community water system of
5 8 or 20 homes would create cost savings over treating non-municipal wells with POET systems. These
6 analyses were similar to those performed for Afton (Section F.2.3).
7

8 The first analysis was performed to calculate the total 20-year costs for grouping 8 homes together in
9 Grey Cloud Island to form a small community water system. Figure F.4 shows an example of three, eight-
10 home groupings in Grey Cloud Island, located off Grey Cloud Island Drive west of Pioneer Road. In Grey
11 Cloud Island, the homes are spread farther apart, with an average distance between homes of 380 feet,
12 compared to 350 feet for Afton (see Section F.2.3) and 300 feet for West Lakeland (see Section F.2.5).

1 Due to the larger spacing between homes, there are only a few pockets where eight homes exist within
 2 close-enough distance to create a small community water system. On average, 3,040 feet of pipe would
 3 be required to connect eight homes in Grey Cloud Island.

4 As shown in Table F.12, grouping eight homes to create a small community water system would not
 5 provide sufficient cost savings over individual treatment with a POET system. As the number of small
 6 community water systems increase and the number of POET systems decrease, the total 20-year costs
 7 increase (Table F.12).

8 **Figure F.4. Example of three, eight-home groupings in Grey Cloud Island.**



9

10

11

Table F.12. Cost analysis for grouping eight homes in Grey Cloud Island.

Alternative	Groups of 8-home small community water systems	Individual homes with private wells and POETS	Initial cost (capital)	Annual operating cost	20-year cost (capital + O&M)	20-year cost (capital + O&M) net present value with 3% discount
1	0	126	\$315,000	\$126,000	\$2,936,000	\$2,264,000
2	3	102	\$1,251,000	\$132,000	\$3,924,000	\$4,280,000
3	6	78	\$2,187,000	\$138,000	\$4,911,000	\$5,297,000
4	9	54	\$3,123,000	\$144,000	\$5,898,000	\$6,313,000
5	12	30	\$4,059,000	\$150,000	\$6,885,000	\$7,329,000
6	15	6	\$4,995,000	\$156,000	\$7,873,000	\$8,346,000

12

13

14

A similar analysis was performed to calculate the total 20-year costs for grouping 20 homes. Figure F.5 shows an example of a 20-home grouping located off Grey Cloud Island Drive west of Pioneer Road. The

1 average estimated feet of pipe required to connect 20 homes in Grey Cloud Island would be
 2 approximately 7,600 feet. In order for redundancy requirements to be met, two wells would be required
 3 along with a certified water operator, additional water quality testing, and a backup generator for
 4 one well. As shown in Table F.13, creating a small community water system of 20 homes would provide
 5 no cost savings over individual treatment with POET systems.

6 **Figure F.5. Example of a 20-home grouping in Grey Cloud Island.**



7
8
9

Table F.13. Cost analysis for grouping 20 homes in Grey Cloud Island.

Alternative	Groups of 20-home small community water systems	Individual homes with private wells and POETS	Initial cost (capital)	Annual operating cost	20-year cost (capital + O&M)	20-year cost (capital + O&M) net present value with 3% discount
1	0	126	\$315,000	\$126,000	\$2,936,000	\$3,264,000
2	2	86	\$3,553,000	\$216,000	\$7,811,000	\$8,290,000
3	3	66	\$5,172,000	\$261,000	\$10,248,000	\$10,803,000
4	4	46	\$6,791,000	\$306,000	\$12,685,000	\$13,316,000
5	5	26	\$8,410,000	\$351,000	\$15,122,000	\$15,829,000
6	6	6	\$10,029,000	\$396,000	\$17,559,000	\$18,342,000

10
 11 From the results above, grouping 8 or 20 homes to create a small community water system is possible
 12 but would not produce cost-saving benefits compared to treating each home individually with a POET
 13 system. The unit costs used for the calculations are shown in Table F.14. A map of the potential small
 14 community water systems in this community is shown in Figure F.6.


1 Table F.14. Cost Summary for Grey Cloud Island.

Item	Description	Source	Quantity	Units	Unit cost	Subtotal
Grey Cloud Island cost estimate for 8 home community						
Treatment facility capital costs						
1	2" piping installed	Washington County bid tabs	3,040	LF	\$97	\$295,000
2	Capital cost POET	Wood experience	4	LS	\$5,500	\$22,000
3	New private well with hook-up	E.H. Renner & Sons Well Drilling MN	400	FT	\$30	\$12,000
4	Well pump	Wood experience	1	EA	\$2,000	\$2,000
5	Pressure tank	Grainger	1	EA	\$1,000	\$1,000
Subtotal – Capital costs						\$332,000
Annual O&M costs						
6	Filter maintenance cost	Estimate	4	LS	\$1,000	\$4,000
7	Cost to replace piping	Wood experience	1	LS	\$6,000	\$6,000
Subtotal – Annual O&M costs						\$10,000
20-year O&M costs						
8	Cost to replace PVC piping	Wood experience	1	LS	\$118,000	\$118,000
9	Well repair costs	Estimate	1	LS	\$6,000	\$6,000
10	Filter maintenance cost	Estimate	1	LS	\$80,000	\$80,000
Subtotal – 20-year O&M costs						\$204,000
Subtotal – 20-year capital + O&M costs						\$536,000

Item	Description	Source	Quantity	Units	Unit cost	Subtotal
Grey Cloud Island cost estimate for 20 home community						
Treatment facility capital costs						
1	4" piping installed	Washington County bid tabs	7,600	LF	\$127	\$965,000
2	Capital cost GAC	Wood experience	1	LS	\$661,000	\$661,000
3	New well with hook-up	E.H. Renner & Sons Well Drilling MN	800	FT	\$50	\$40,000
4	Well pump	Wood experience	2	EA	\$2,000	\$4,000
5	Pressure tank	Grainger	2	EA	\$1,000	\$2,000
Subtotal – Capital costs						\$1,672,000
Annual O&M costs						
6	Annual media cost	Estimate	1	LS	\$12,000	\$12,000
7	Annual operating costs	Estimate	1	EA	\$33,000	\$33,000
8	Cost to replace piping	Wood experience	1	LS	\$19,000	\$19,000
Subtotal – Annual O&M costs						\$64,000
20-year O&M costs						
9	Cost to replace piping	Wood experience	1	LS	\$380,000	\$380,000
10	Operating costs	Estimate	1	EA	\$660,000	\$660,000
11	Well repair costs	Estimate	1	LS	\$8,000	\$8,000
12	Filter maintenance cost	Estimate	1	LS	\$240,000	\$240,000
Subtotal – 20-year O&M costs						\$1,288,000
Subtotal – 20-year capital + O&M costs						\$2,960,000

EA = each, FT = feet, LF = linear feet, LS = lump sum.

1 **Figure F.6. Potential small community water systems in Grey Cloud Island.**



3 **F.2.5 West Lakeland**


4 For West Lakeland, two analyses were performed to determine if a small community water system of
5 8 or 20 homes would create cost savings over treating non-municipal wells with POET systems. These
6 analyses were similar to those performed for Afton (Section F.2.3) and Grey Cloud Island (Section F.2.4).

7 The first analysis was performed to calculate the total 20-year costs for grouping 8 homes together in
8 West Lakeland to form a small community water system. Figure F.7 shows an example of four, eight-
9 home groupings in West Lakeland, located east of Manning Avenue off 24th Street. In West Lakeland,

1 there are many areas of opportunity to create small community water systems. The average distance
 2 between homes in West Lakeland was calculated to be 300 feet using ArcGIS Earth. Thus, the average
 3 estimated feet of pipe required to connect eight homes in West Lakeland would be approximately
 4 2,400 feet.

5 As shown in Table F.15, grouping eight homes to create a small community water system would not
 6 provide sufficient cost savings over individual treatment with a POET system. As the number of small
 7 community water systems increase and the number of POET systems decrease, the total 20-year costs
 8 increase (Table F.15).

9 **Figure F.7. Example of four, eight-home groupings in West Lakeland.**



10

11


12 **Table F.15. Cost analysis for grouping eight homes in West Lakeland.**

Alternative	Groups of 8-home small community water systems	Individual homes with private wells and POETS	Initial cost (capital)	Annual operating cost	20-year cost (capital + O&M)	20-year cost (capital + O&M) net present value with 3% discount rate
1	0	1,314	\$3,285,000	\$1,314,000	\$30,617,000	\$34,033,000
2	30	1,074	\$10,785,000	\$1,344,000	\$37,886,000	\$41,587,000
3	60	834	\$18,285,000	\$1,374,000	\$45,155,000	\$49,141,000
4	90	594	\$25,785,000	\$1,404,000	\$52,424,000	\$56,695,000
5	130	274	\$35,785,000	\$1,444,000	\$62,116,000	\$66,767,000
6	160	34	\$43,285,000	\$1,474,000	\$69,385,000	\$74,321,000

13

1 A similar analysis was performed to calculate the total 20-year costs for grouping 20 homes. Figure F.8
 2 shows an example of a 20-home grouping located on Morgan Avenue and Mystic Ride Avenue. The
 3 average estimated feet of pipe required to connect 20 homes in West Lakeland would be approximately
 4 6,000 feet. In order for redundancy requirements to be met, two wells would be required along with a
 5 certified water operator, additional water quality testing, and a backup generator for one well. As
 6 shown in Table F.16, creating a small community water system of 20 homes would provide no cost
 7 savings over individual treatment with POET systems.

8 **Figure F.8. Example of a 20-home grouping in West Lakeland.**



9
10
11

Table F.16. Cost analysis for grouping 20 homes in West Lakeland.

Alternative	Groups of 20-home small community water systems	Individual homes with private wells and POETS	Initial cost (capital)	Annual operating cost	20-year cost (capital + O&M)	20-year cost (capital + O&M) net present value with 3% discount rate
1	0	1,314	\$3,285,000	\$1,314,000	\$30,617,000	\$34,033,000
2	15	1,014	\$24,540,000	\$1,929,000	\$62,928,000	\$67,423,000
3	25	814	\$38,710,000	\$2,339,000	\$84,469,000	\$89,683,000
4	35	614	\$52,880,000	\$2,749,000	\$106,010,000	\$111,943,000
5	45	414	\$67,050,000	\$3,159,000	\$127,551,000	\$134,203,000
6	65	14	\$95,390,000	\$3,979,000	\$170,633,000	\$178,723,000

12
13 From the results above, grouping 8 or 20 homes to create a small community water system is possible
14 but would not produce cost-saving benefits when compared to treating each home individually with a

1 POET system. The unit costs used for the calculations are shown in Table F.17. A map of the potential
 2 small community water systems in this community is shown in Figure F.9.

3 **Table F.17. Cost summary for West Lakeland.**


Item	Description	Source	Quantity	Units	Unit cost	Subtotal
West Lakeland cost estimate for 8-home community						
Treatment facility capital costs						
1	2" piping installed	Washington County bid tabs	2,400	LF	\$97	\$233,000
2	Capital cost POET	Wood experience	4	LS	\$5,500	\$22,000
3	New private well with hook-up	E.H. Renner & Sons Well Drilling MN	400	FT	\$30	\$12,000
4	Well pump	Wood experience	1	EA	\$2,000	\$2,000
5	Pressure tank	Grainger	1	EA	\$1,000	\$1,000
Subtotal – Capital costs						\$270,000
Annual O&M costs						
6	Filter maintenance cost	Estimate	4	LS	\$1,000	\$4,000
7	Cost to replace piping	Wood experience	1	LS	\$5,000	\$5,000
Subtotal – Annual O&M costs						\$9,000
20-year O&M costs						
8	Cost to replace PVC piping	Wood experience	1	LS	\$93,000	\$93,000
9	Well repair costs	Estimate	1	LS	\$6,000	\$6,000
10	Filter maintenance cost	Estimate	1	LS	\$80,000	\$80,000
Subtotal – 20-year O&M costs						\$179,000
Subtotal – 20-year capital + O&M costs						\$449,000
West Lakeland cost estimate for 20-home community						
Treatment facility capital costs						
1	4" piping installed	Washington County bid tabs	6,000	LF	\$127	\$762,000
2	Capital cost GAC	Wood experience	1	LS	\$661,000	\$661,000

Item	Description	Source	Quantity	Units	Unit cost	Subtotal
3	New well with hook-up	E.H. Renner & Sons Well Drilling MN	800	FT	\$50	\$40,000
4	Well pump	Wood experience	2	EA	\$2,000	\$4,000
5	Pressure tank	Grainger	2	EA	\$1,000	\$2,000
Subtotal – Capital costs						\$1,469,000
Annual O&M costs						
6	Annual media cost	Estimate	1	LS	\$12,000	\$12,000
7	Annual operating costs	Estimate	1	EA	\$33,000	\$33,000
8	Cost to replace piping	Wood experience	1	LS	\$16,000	\$16,000
Subtotal – Annual O&M costs						\$61,000
20-year O&M costs						
9	Cost to replace piping	Wood experience	1	LS	\$320,000	\$320,000
10	Operating costs	Estimate	1	EA	\$660,000	\$660,000
11	Well repair costs	Estimate	1	LS	\$8,000	\$8,000
12	Filter maintenance cost	Estimate	1	LS	\$240,000	\$240,000
Subtotal – 20-year O&M costs						\$1,228,000
Subtotal – 20-year capital + O&M costs						\$2,697,000

EA = each, FT = feet, LF = linear feet, LS = lump sum.

1

1 **Figure F.9. Potential small community water systems in West Lakeland.**



2

3 **F.2.6 Average cost per home for community water systems**

4 Results from the 8- and 20-home small community water systems were extrapolated further to 100- and
5 500-home systems. This analysis was conducted for Afton and West Lakeland. However, this analysis
6 was not performed for Grey Cloud Island due to the small number of homes and large spaces between
7 homes within the community.

8 In Table F.18, the average cost per home over 20 years can be estimated to further compare the cost
9 differences between treating wells individually with POET systems or with 8–500 home small community
10 water systems. Treating private wells individually with POET systems remain the most cost-effective
11 option, followed by treating an 8-home community, a 500-home community, a 100-home community,
12 and a 20-home community.

13 The two most significant parameters affecting the total 20-year costs include installing the GAC
14 treatment systems and pipe. The parameter that impacts the total cost the least is the cost for drilling a
15 new community well. Table F.19 illustrates how small community water systems progressively add costs
16 for additional upfront capital infrastructure items.

1 **Table F.18. Average cost per home over 20 years.**

Community	Private well with POETS	8-home community water system with treatment	20-home community water system with treatment	100-home community water system with treatment	500-home community water system with treatment
Afton	\$26,000	\$65,000	\$149,000	\$97,000	\$112,000
West Lakeland	\$26,000	\$58,000	\$138,000	\$84,000	\$81,000
Grey Cloud Island	\$26,000	\$70,000	\$169,000	N/A	N/A

2
3 **Table F.19. Scope of work that influences cost estimates of individual POET systems versus community**
4 **water systems.**

Infrastructure item	POET on existing private well	Small community water system (< 8 homes)	Medium community water system (20 homes)	Large community water system (up to 100 to 500 homes)
Well	Existing	New 1 required	New 2 required	New 2 or more required
Linear infrastructure (water supply piping)	None	New	New	New
Treatment system	New	New	New	New
Building	In existing home	New structure at well (with electrical and heat)	New structure at well (with electrical and heat)	New structure at well (with electrical and heat)
Operating cost	Annual media change-out	Annual media change-out	Annual media change-out	Annual media change-out
Care and monitoring	By homeowner	By homeowner	By qualified operator	By qualified operator

5 **F.2.7 Conclusion**

6 The results from this analysis suggest that implementing a small community water system for any of the
7 three communities examined – Afton, Grey Cloud Island, or West Lakeland – is more expensive than

1 installing POET systems. It can be noted that the costs for a small community water system of 8 homes is
2 less than the costs for a public water system of 20–500 homes due to redundancy requirements.
3 However, both options require costs greater than individually treating each well with a POET system.
4 For all three communities, the population density and lack of existing infrastructure create conditions
5 where the use of POET systems is the most cost-effective method to deliver safe drinking water,
6 compared to community treatment systems of any size.

7 **F.3 Treatment technology comparison**

8 **F.3.1 Introduction**

9 This section provides information on the various technologies available for the treatment of per- and
10 polyfluoroalkyl substances (PFAS) in drinking water in the East Metropolitan Area. The life cycle of
11 technology development, as presented in Figure F.10, illustrates how technologies are developed from
12 research and development through to demonstration and validation, and on to full-scale
13 commercialization. Full-scale commercialized options to treat PFAS in drinking water are limited due to
14 the difficulty in degrading PFAS, especially perfluorooctanesulfonic acid (PFOS) and perfluorooctanoic
15 acid (PFOA), and because of the strict requirements for technology approval. Examples of these rigorous
16 standards include the National Science Foundation (NSF) International certification to meet the drinking
17 water treatment requirements in accordance with strict public health standards and state health
18 department requirements for approval and/or certification of drinking water treatment technologies.
19 Current research and development on PFAS treatment sites provide insights into promising and partially
20 demonstrated new technologies. Research and development activities for PFAS water treatment include
21 chemical oxidation, biological degradation, and novel sorption technologies that can be applied in
22 drinking water applications. Although this testing may show promise, these technologies are not
23 currently applicable to drinking water treatment applications, and would still need to achieve applicable
24 strict public health standards and state-level certifications. To date, all mature commercially available
25 technologies for treating PFAS in drinking water rely on separation rather than degradation.

26 Pretreatment is an important consideration when evaluating primary treatment technologies. The
27 presence of organic and inorganic co-contaminants can have a significant effect on the efficacy and
28 longevity of the drinking water treatment system. For instance, presence of organic co-contaminants
29 can result in adsorption sites being preferentially filled while presence of inorganic contaminants can
30 result in significant bed fouling issues that can result in premature breakthrough of target constituents.
31 Pretreatment options should consider residuals formation, residuals disposal, and chemical
32 consumption associated with the pre-treatment step. Pre-treatment variables are considered further in
33 Table F.21 and F.22. Below, information is presented on technology effectiveness, limitations, and
34 sustainability pertaining to the following categories of drinking water treatment:

- 35 • Mature technologies that are commercially available and have been implemented at full scale
36 for treating PFAS in drinking water across the United States
 - 37 • GAC
 - 38 • Ion exchange (IX)
 - 39 • Membrane [reverse osmosis (RO), nanofiltration (NF)]
- 40 • Developing technologies that have been tested at various scales for treating PFAS in drinking
41 water but have not yet been implemented fully and are not approved for use in drinking water


1 treatment. While these systems show promise, they currently are not considered technologies
 2 that can be readily deployed into a drinking water system.

- 3 • Zeolite/organoclay media systems
- 4 • Biochar systems
- 5 • Advanced oxidation systems
- 6 • Sonolysis treatment systems.

7 Technologies that are currently considered in the demonstration and validation as well as research and
 8 development stages are not considered further in this Conceptual Plan as they are not deemed
 9 appropriate for consideration at this time as they are not commercially available, and full-scale
 10 implementation is not feasible without demonstration and validation at a minimum.

11 Treatment technologies may be similar in many ways but can present several potential advantages and
 12 disadvantages regarding sustainable practices. These considerations are presented in Section F.3.2.4.

13 **Figure F.10. Life cycle of technology development.**



14
 15 *Source: S. Thomas, Wood, used with permission.*

16 **F.3.1.1 Key variables for consideration**

17 When developing a drinking water system for the treatment of PFAS, many important technical and
 18 non-technical considerations need to be evaluated. Key variables are presented in Table F.20 and
 19 discussed for the various technologies presented.

20 **Table F.20. Key treatment technology variables for consideration.**

Technical	Non-technical
Final water treatment requirements	Operational costs
Pretreatment requirements	Capital costs
Co-contaminants	Ease of operation
Water hardness	System complexity
Competing ionic species	Space required
Product water generated/wastewater generated	State certifications/approvals

Disposal of media/residuals	NSF/American National Standards Institute (ANSI) certification
Performance criteria	Availability of equipment/media
System contact volume	Impact of changing regulations

1 **F.3.2 Mature technologies**

2 Currently, there are three (3) treatment technologies for drinking water that are commercially available.
 3 These include GAC, single use IX resins, and membrane processes (RO and NF). Sections F.3.2.1 through
 4 F.3.2.3 provide descriptions of these technologies, and Table F.21 provides a comparison.

5 **F.3.2.1 GAC**

6 GAC is used in drinking water treatment, usually as a polishing step, to remove synthetic organic
 7 chemicals, natural organic compounds, and other compounds affecting taste and odor. GAC currently is
 8 the most widely used treatment method for the removal of PFAS compounds from drinking water.

9 The removal efficiency of PFAS by GAC depends on the functional group and perfluorocarbon chain
 10 length of the individual PFAS compound. Removal efficiency increases with increasing perfluorocarbon
 11 chain length. Additionally, GAC is less effective for carboxylate functional groups than for sulfonate
 12 functional groups.

13 Other factors that will impact the removal efficiency of PFAS by GAC include:

- 14 • Naturally occurring organic matter (NOM): NOM competes with PFAS for adsorption sites. The
 15 presence of NOM in drinking water systems will reduce the adsorption capacity for the targeted
 16 organic chemicals to be removed.
- 17 • The presence of chlorine. Activated carbon reacts with chlorine (or other oxidants) in a
 18 reduction-oxidation reaction, which may change surface characteristics of the activated carbon
 19 and reduce treatment effectiveness.
- 20 • GAC does not degrade or destroy PFAS. This is considered an adsorption technology only.

21 GAC systems can be installed relatively easily and require relatively low maintenance and operation
 22 effort. GAC is placed in packed-bed, flow-through pressure vessels, usually operated in series (lead-lag
 23 configuration), with typical empty bed contact times of 10–15 minutes per vessel for PFAS applications.
 24 Breakthrough, which is the point at which the contaminant (PFAS) is no longer captured by the
 25 treatment method, is monitored by sampling water, at a minimum, between the lead and lag vessels.
 26 When breakthrough exceeds the identified criteria, the lead vessel is taken offline and the spent GAC is
 27 removed and replaced with new (either virgin or reactivated) GAC. The spent media are disposed of
 28 offsite, typically by incineration/thermal destruction, but can also be reused by employing high-
 29 temperature thermal reactivation. Reactivated PFAS GAC is allowed for use in drinking water application
 30 but this should be considered with caution and in accordance with the AWWA B605-13 Reactivation of
 31 Granular Activated Carbon standard. Many states do not allow its use for drinking water applications.
 32 (ITRC, 2020)

33 GAC can be manufactured using various materials [e.g., coal (bituminous), coconut shells, wood], which
 34 all have shown some ability to remove PFAS. Re-agglomerated bituminous GAC has generally been
 35 demonstrated to be the most effective GAC media and is used for the majority of existing PFAS
 36 treatment systems. Media selection and life cycle cost will depend on a number of factors, including
 37 PFAS and co-contaminant concentrations, media availability and pricing, and disposal options/costs.

1 Two significant benefits of GAC is that it is widely used with a large network of providers and good
2 availability of material, and there are a number of vendors that provide turnkey replacement services.

3 **F.3.2.2 IX resin**

4 IX is a widely accepted process for the removal of targeted, typically inorganic compounds. IX involves
5 the use of resins. Most synthetic IX resins are manufactured by a process in which styrene and
6 divinylbenzene are copolymerized. The styrene serves as the basic matrix of the resin, and
7 divinylbenzene is used to cross-link the polymers to produce insoluble tough resin beads. Important
8 properties of IX resin include exchange capacity, particle size, and stability. IX resins can be considered
9 non-regenerable (or single use) that are disposed of after one application or regenerable. IX
10 regeneration involves backwashing the resin bed with a variety of proprietary solutions to remove and
11 concentrate the PFAS into a smaller liquid volume, subsequent rinses are used to purge the regenerant
12 solution from the bed and prepare the resin bed for reuse. Regenerable resins are not currently
13 approved for use in drinking water treatment applications in the United States and are not considered
14 further in this Conceptual Plan.

15 According to a number of studies (Woodard, 2017, McCleaf, 2017, Amec Foster Wheeler, 2017,
16 Gagliano, 2020) (), non-regenerable IX resin has the highest capacity for PFAS, followed by GAC,
17 and then regenerable IX resin.

18 The removal efficiency of the non-regenerable IX system depends on a variety of factors, including the
19 nature of the resin within the beads, competing ions, treatment design (e.g., empty bed contact times,
20 size of resin beads), and physical and chemical properties of the PFAS requiring treatment:

- 21 • According to a previous literature review conducted by Wood, anion exchange resins are the
22 only effective resin for PFAS removal (Amec Foster Wheeler, 2017)
- 23 • Competing ions such as sulfate, nitrates, and heavy metals may impact the sorption capacity of
24 the resin. TOC in groundwater can also result in biofouling of IX resins.
- 25 • Based on the bench-scale study conducted by Wood (Woodard, 2017), the long-chain PFAS
26 compounds are generally more effectively removed than short-chain PFAS when using non-
27 regenerable IX resin.

28 Many factors drive IX resin system design decisions other than removal efficiency. Compared with a GAC
29 system, the capital costs for an IX resin system are lower. Factors such as influent and target PFAS
30 concentration, replacement of resin, arrangement of resin vessels (lead-lag or lead-lag-standby), and
31 strength of the resin beads will all impact the operation cost of the IX resin system and will be used to
32 decide whether a GAC or IX system is more economical.

33 Non-regenerable IX resin, as indicated by its name, is for one-time use. Once the resin is exhausted, it is
34 disposed of, resulting in a more expensive disposal cost than for reactivation of GAC. Waste disposal is
35 discussed further in Section F.3.3 below.

36 For conventional ion exchange systems operational costs represent between 30 and 70% of the life cycle
37 costs (Schwartz, 2013). Operations must consider optimization of key process operational parameters,
38 an understanding of the impacts of influent and effluent parameters, and an understanding of system
39 capacity in terms of flow and loading to effectively manage system costs.

1 **F.3.2.3 Pressurized membrane processes (RO and NF)**

2 RO and NF are forms of membrane filtration technology that are pressure-driven and shown to be
3 effective in the removal of PFAS. Typically, NF systems reject constituents as small as 0.001 μm , whereas
4 RO systems reject particles as small as 0.0001 μm .

5 The removal efficiency for PFAS by these types of membranes are typically more than 90% effective at
6 removing a wide range of PFAS (EPA, 2018). The high removal rate for PFAS is primarily due to the
7 molecular weight cut-off (MWCO) of the NF and RO membranes. MWCO is a measure of the removal
8 characteristics of a membrane in terms of atomic weight. The typical range of MWCO levels for NF
9 ranges from 200 to 1,000 Daltons, while for RO it is generally less than 100 Daltons (EPA, 2005). The
10 molecular weight for PFOA and PFOS are 500 and 414 Daltons, respectively, meaning PFOA and PFOS
11 can be easily removed by NF and RO systems.

12 The following factors will impact the performance of membrane filtration systems:

- 13 • Pressure: The operation pressure will affect the water flux across the membrane and the
14 recovery rate. For NF membranes, the typical feed pressure range is between 50 and
15 150 pounds per square inch; while for RO membranes, the typical feed pressure ranges between
16 125 and 1,200 pounds per square inch, depending on osmotic pressure and required production
17 flux.
- 18 • Temperature: The membrane filtration system performance is very sensitive to changes in the
19 feed water temperature. As the feed water temperature increases, the water flux increases
20 almost linearly (which is often preferred since it will increase the recovery rate); however, the
21 contaminant removal/rejection rate will be lowered (not preferred since it decreases the quality
22 of treated water).
- 23 • Salt concentration: For RO systems, osmotic pressure is a function of the salt concentration. As
24 the salt concentration increases, the osmotic pressure increases. If the feed pressure remains
25 constant, a higher salt concentration will result in a lower membrane water flux since the
26 increased osmotic pressure offsets the feed water driving pressure.
- 27 • Recovery rate: Recovery rate is defined as the ratio between permeate stream flow and feed
28 stream flow. Typically, the recovery rate for NF is typically higher than for RO systems. Systems
29 used for drinking water applications should be able to attain 90% recovery for NF systems and
30 80% recovery for RO systems.

31 Despite its high removal efficiency for PFAS, the capital and O&M costs for membrane systems are
32 usually high compared to sorption systems (i.e., GAC and IX resins). Other than economic factors,
33 operational issues such as membrane fouling and rejected stream treatment usually limit the application
34 of membrane filtration systems.

35 Pretreatment and posttreatment are often necessary when working with NF and RO systems. The
36 primary objective of pretreatment is to remove or reduce the constituents that contribute to membrane
37 fouling and make the feed water compatible with the membrane. It is expected that by pretreatment,
38 the efficiency and life expectancy of the membrane elements will be improved. RO systems will provide
39 a very pure product water that requires remineralization and decarbonation to provide non-corrosive
40 drinking water.

41 Another operation issue for the membrane filtration system is the production of a concentrated waste
42 stream. The concentrate from NF and RO facilities will not only contain elevated concentrations of
43 contaminants of interest, but it can also contain hardness, heavy metals, and high-molecular-weight

- 1 organics. The disposal of the waste stream includes discharge to wastewater collection systems and
- 2 thermal evaporation.

3 **Table F.21. Comparison of drinking water treatment technologies.**

Technology	Advantages	Disadvantages
GAC	<ol style="list-style-type: none"> 1) GAC is the most widely used technology for PFAS removal, especially for long-chain PFAS; the removal efficiency is > 90% for long-chain PFAS. 2) Given the design and operation configuration of the fixed-bed column, it is possible to achieve very low PFAS levels in treated water. 3) Low capital and operation costs. 4) GAC can be reactivated for non-potable use or incinerated to destroy PFAS 	<ol style="list-style-type: none"> 1) Not suitable for treating water that contains high levels of organic compounds. 2) As carbon can react with oxidants such as chlorine, its use should be avoided after chlorine disinfection. 3) Not as efficient as IX for shorter-chain PFAS.
Non-regenerable IX resin	<ol style="list-style-type: none"> 1) Non-regenerable resin has the highest sorption capacity among GAC and regenerable IX resin; the removal efficiency is > 90% for long-chain PFAS. 2) Given the design and operation configuration of the fixed-bed column, it is possible to achieve very low PFAS levels in treated water. 3) No concentrated waste stream will be produced (since no regeneration is required); however, need to consider the disposal of spent resin. 4) Operation costs are expected to be significantly lower than the membrane filtration system (NF and RO) 	<ol style="list-style-type: none"> 1) Not suitable for treating water containing high levels of sulfates, nitrates, and heavy metals unless pre-treatment measures are in place. 2) Since regeneration is not feasible, the spent resin needs to be changed out once it is exhausted and disposed via incineration. Operating costs need to consider the treatment and disposal of the spent resin.

Technology	Advantages	Disadvantages
NF	<ul style="list-style-type: none"> 1) Removal efficiency for PFAS is greater than 90%. 2) Less footprint compared to traditional treatment options. 	<ul style="list-style-type: none"> 1) Pretreatment is required. 2) Usually high capital cost. 3) Operation costs are high due to energy cost, cleaning cost, labor, and chemical consumption. 4) Recovery rate may be low depending on the quality of raw water. 5) Treatment for the concentrated waste stream requires evaporation and residual incineration/encapsulation at a significant cost. 3) High demand for O&M to achieve optimal treatment.
RO	<ul style="list-style-type: none"> 1) Removal efficiency for PFAS is close to 100%, and effective for both long- and short-chain PFAS. 2) Less footprint compared to traditional treatment options. 	<ul style="list-style-type: none"> 1) Pretreatment is required. 2) Usually high capital costs. 3) Operation costs are high due to energy cost, cleaning cost, labor, and chemical consumption. 4) Recovery rate may be low depending on the quality of raw water. 5) Treatment for the concentrated waste stream requires evaporation and residual incineration/encapsulation at a significant cost. 6) High demand for O&M to achieve optimal treatment.

1 **F.3.2.4 Comparison of key treatment variables and sustainability evaluation**

2 In the evaluation of PFAS drinking water technologies, specific treatment variables are considered to
 3 ensure reliability, efficiency, and long-term system economics are optimized. Sustainability
 4 considerations, including environmental impacts of the system manufacturing, carbon emissions, and
 5 disposal, are also drivers to the selection of the treatment technology of choice.

6 **Table F.22. Key treatment variables and sustainability evaluation factors.**

Sustainability consideration	GAC	IX	Membrane systems
Media materials	Can be coal (less sustainable), or coconut shells and	Synthetically manufactured materials.	A variety of materials are used for NF and RO membranes, including

Sustainability consideration	GAC	IX	Membrane systems
	wood (more sustainable).		cellulose acetate, poly amide, and ceramic media.
Media availability	More widely used treatment technology, and therefore more widely available.	Media widely used, but specialty media demands may outweigh supply.	Widely used and easily procured materials.
Pretreatment requirements	Pretreatment of organic constituents that compete for adsorption sites may be required. Elevated iron or manganese may cause bed fouling due to the formation of solids and may require pretreatment.	Pretreatment of organic constituents that result in biofouling may be required. Elevated iron or manganese may cause bed fouling due to the formation of solids and may require pretreatment.	Pretreatment required to prevent membrane fouling. Use of membrane cleaning chemicals required to routinely clean membranes.
Timeline to Implement	Easily implementable systems. Vessels and media readily available.	Easily implementable systems. Vessels available but media may require lead time.	More complex implementation. Systems are generally custom-built with longer equipment lead times and onsite fabrication.
Vessel size/amount of media required	Larger media vessels (more media required) relative to IX.	Vessels sizes are approximately 25-30% that of GAC vessels.	Relatively small system footprint compared to GAC and IX systems.
Building space/footprint	Larger buildings to house treatment system due to large vessels.	Smaller vessel sizes result in less building space than GAC.	Small building footprint required for membrane systems, but ancillary systems for reject water management and chemical cleaning of membranes increase systems space requirements.
Waste/disposal	Reactivation of media; destruction or	Destruction or disposal of spent	Reject water requires disposal. A critical factor

Sustainability consideration	GAC	IX	Membrane systems
	disposal of spent media available.	non-regenerable media available; regenerated media not applicable for drinking water applications.	in assessing a membrane system is the ability to dispose of the contaminated reject water.
Lifespan	Media in drinking water applications depend on feed water concentrations. For typical applications in drinking water, expected life of media is 6 months to 1 year.	Compared to GAC, media life is up to 2–3 times greater.	Typically RO and NF membranes have a life of 5 to 10 years in a drinking water application.
O&M	Pressurized flow-through operation. Media cost and disposal are the primary O&M costs.	Pressurized flow-through operation. Media cost and disposal are the primary O&M costs.	More complex operation due to high-pressure feed pump systems and the need to re-mineralize product water.
Adaptability	GAC is very effective at removing longer-chain PFAS compounds. Shorter-chain compounds break through more rapidly. Less adaptable to future regulations due to lower effectiveness for short chain compounds that may be regulated in the future. Adaptable to a range of flows	IX systems lend themselves to future regulations on shorter-chain PFAS compounds as IX media are typically more effective in removing these compounds than GAC. Adaptable to a range of flows.	Highly adaptable to changing feedwater characteristics and regulations due to molecular level rejection. Very sensitive to flow changes.
Ancillary benefits	Taste and odor control where NOM is present.		Will provide soft water (RO). Co-contaminant removal.

Sustainability consideration	GAC	IX	Membrane systems
	Removal of organic co-contaminants-		
Other impacts			RO generated water can be aggressive toward infrastructure and needs to be re-mineralized to reduce corrosion/metal leaching impacts.

1 **F.3.3 Waste disposal and management**

2 **F.3.3.1 Incineration**

3 Incineration is a waste destruction process that involves the combustion of organic substances
4 contained in waste materials. Incineration and other high-temperature waste treatment systems are
5 termed “thermal treatment processes.” Incineration is a mature technology that has been used for a
6 wide variety of organic wastes. Heat is applied directly to the contaminated solids or liquids to
7 completely oxidize them. Gaseous combustion by-products are controlled to prevent atmospheric
8 pollution. To date, concentrated waste-generating technologies previously discussed (GAC, IX, or RO)
9 are often followed by incineration as a PFAS destruction step.

10 Incineration is one of the few technologies that can completely destroy PFAS however many questions
11 remain as to the efficacy of combustion (ITRC, 2020). Hazardous waste incinerators are fixed facilities
12 capable of reaching PFAS-destructive temperatures. Federal and state permits dictate the materials that
13 may be processed; core incinerator operations (e.g., temperature, time); and control of process air,
14 liquid, and solid wastes. Permit and design/construction similarities reduce the operational and
15 performance differences between individual incinerators. Transportation costs, energy costs, and final
16 disposal of process waste residues differ among incinerators. The cost of incineration has a significant
17 impact on treatment costs.

18 The sustainability impacts of incineration include transporting contaminated material and the energy-
19 intensive processing involving the combustion of fossil fuels to achieve the thermal destruction of
20 contaminants. No hazardous waste incinerators are located in the East Metropolitan Area with the
21 exception of the 3M incinerator at the Cottage Grove Facility.

22 **F.3.3.2 Landfill**

23 Landfill disposal is a common method for the disposal of solids waste materials generated by water
24 treatment and industrial residuals. PFAS treatment residuals, including single-use IX resins and non-
25 regenerable activated carbon, can be disposed of in a secure industrial landfill. Some landfills, both
26 municipal and hazardous waste, will not accept PFAS-containing materials. Current federal regulations
27 do not define PFAS as hazardous substances or hazardous wastes; however, that may be a consideration
28 in the future as new regulations are passed.

29 The sustainability impacts of landfilling include the hauling of waste material, landfill activities
30 (e.g., construction, backfill), as well as general emissions from landfills including contaminated leachate
31 treatment requirements. If future federal designation of PFAS as a hazardous waste requires out-of-

1 state transportation for landfill disposal, significant costs and secondary environmental impacts may be
 2 incurred for these waste materials.

3 **F.3.4 Other variables**

4 Additional considerations in the selection of a PFAS drinking water technology include regulatory
 5 requirements, industry specific certifications, state or federal certifications, and regulatory performance
 6 for non-regulated contaminants (e.g., short-chain PFAS). Table F.22 is a summary of additional
 7 considerations in the selection of PFAS drinking water treatment technologies.

8 **Table F.22. Additional considerations in the selection of PFAS drinking water treatment technologies.**

Additional considerations	GAC	IX	Membrane systems
NSF 61 Certification	Specific GAC media are NSF 61 certified. Widest range of available NSF media.	IX resins have limited NSF certification. Of those, only a few are applicable to PFAS.	RO and NF membranes are widely used in a variety of potable water applications. A wide array of membranes have NSF 61 certification.
State certification/ approval	Widely used treatment technology that is most generally accepted by regulators.	Gaining acceptance with regulators as systems come on line. Not currently approved by MDH for PFAS. With supporting information and demonstration (piloting), it is expected that MDH will approve.	Widely used treatment technology that is generally accepted by regulators. Not currently approved by MDH for PFAS. With supporting information and demonstration (piloting), it is expected that MDH will approve.
Regulatory performance	As more short-chain PFAS compounds become regulated, GAC applicability may decrease or require post-treatment. Able to meet regulated PFAS compound criteria.	Better performance for short-chain compounds so long-term outlook may be better than GAC. Currently able to meet regulated PFAS compound criteria.	RO systems are able to remove 100% of PFAS compounds to below detection. High degree of regulatory confidence. Waste material compliance is uncertain. Liquid disposal is more difficult than solid phase media (GAC and IX).

9 **F.3.5 Conclusions**

10 In conclusion, adsorption (i.e., GAC) or IX (i.e., non-regenerable IX) are currently the technologies of
 11 choice for drinking water treatment for PFAS-contaminated drinking water compared to membrane

1 filtration. The advantages of adsorption and IX are the relative simplicity of the technologies, low
2 residuals production, and the high degree of effectiveness. Between these two methods for treatment
3 of PFAS, GAC has the widest application and has relatively low capital and O&M costs. Currently GAC is
4 the only approved technology for PFAS treatment of drinking water in the state of Minnesota. IX
5 systems will have generally lower capital costs to implement over GAC systems, but the availability of
6 resins and the disposal of exhausted resin material may be challenges with the current demand on the
7 supply chain for these materials. The quality of the raw water needs to be considered and if the raw
8 water has significant co-contaminant concentrations, GAC will lose its sorption capacity relatively
9 quickly, resulting in increased media consumption. IX is currently undergoing pilot trials in Cottage
10 Grove with the intent of providing MPCA with data to demonstrate its effectiveness.

11 Several technologies that are in development have the potential to provide high-efficiency removal of
12 PFAS in drinking water treatment systems. Advancements in regenerable IX technology have been
13 applied to remediation pump-and-treat systems, and it is possible that these systems may prove to be
14 applicable to drinking water systems in the United States in the future (see Black and Veatch, 2017).
15 Advanced oxidation systems (e.g., ozone, persulfate, electrochemical) show some promise for the
16 treatment of PFAS material and may provide a means to destroy PFAS in the drinking water process. To
17 date, these systems have shown limited effectiveness, but research advancements in this area may have
18 applicability in drinking water systems. Finally, the application of biological treatment processes is an
19 area that has seen recent advancements, with reports of complete mineralization of PFAS. These
20 systems also have the ability to destroy PFAS and may provide an option for the treatment of PFAS in
21 drinking water in the future.

22 References

- 23 ASTM. 2006. *Annual Book of ASTM Standards*. Volume 8.04, Plastic Pipe and Building Products. ASTM
24 International.
- 25 Black and Veatch. 2017. Draft Technical Memorandum 1, Desktop Evaluation of Alternatives – GenX and
26 Other PFAS Treatment Options Study. Prepared for Cape Fear Public Utility Authority. July. Available:
27 <https://www.cfpu.org/DocumentCenter/View/9227/Cape-Fear-TM?bidId=>.
- 28 EPA, 2005. Membrane Filtration Guidance Manual. Office of Water. EPA 815-R-06-009.
- 29 EPA. 2018. Reducing PFAS in Drinking Water with Treatment Technologies.
30 <https://www.epa.gov/sciencematters/reducing-pfas-drinking-water-treatment-technologies>. Published
31 August 23, 2018 and accessed August 25, 2020.
- 32 ITRC (Interstate Technology & Regulatory Council). 2020. *PFAS Technical and Regulatory Guidance*
33 *Document and Fact Sheets* PFAS-1. Washington, D.C.: Interstate Technology & Regulatory Council, PFAS
34 Team. <https://pfas-1.itrcweb.org/>
- 35 Metropolitan Council. 2016. Washington County Municipal Water Coalition Water Supply Feasibility
36 Assessment. Prepared by Short Elliott Hendrickson Inc. Metropolitan Council: Saint Paul. October.
37 Available: [https://metro council.org/Wastewater-Water/Publications-And-Resources/WATER-SUPPLY-
38 PLANNING/Washington-County-Municipal-Water-Coalition.aspx](https://metro council.org/Wastewater-Water/Publications-And-Resources/WATER-SUPPLY-PLANNING/Washington-County-Municipal-Water-Coalition.aspx).
- 39 Woodard, Steve, John Berry, and Brandon Newman. 2017. “Ion exchange resin for PFAS
40 removal and pilot test comparison to GAC.” *Remediation Journal* 27 (3):19-27.

- 1 McCleaf, Philip; Sophie Englund, Anna Östlund, Klara Lindegren, Karin Wiberg, and Lutz Ahrens.
2 2017. "Removal efficiency of multiple poly- and perfluoroalkyl substances (PFASs) in drinking
3 water using granular activated carbon (GAC) and anion exchange (AE) column tests." *Water*
4 *Research* 120:77-87.
- 5 Amec Foster Wheeler. 2017. Site 8 Pilot Test Results Report, Former Pease Air Force Base.
6 Texas Prepared for Air Force Civil Engineering Center. Joint Base San Antonio – Lakeland.
- 7 Gagliano, Erica, Massimiliano Sgroi, Pietro P. Falciglia, Federico G.A Vagliasindi, Paolo Rocco,
8 2020. "Removal of poly- and perfluoroalkyl substances (PFAS) from water by adsorption: Role of
9 PFAS chain length, effect of organic matter and challenges in adsorbent regeneration" *Water*
10 *Research* Volume 171
- 11 Schwartz, P.E., William, Envirogen Technologies, Rancho Cucamonga, CA, "Ion Exchange System
12 Selection Criteria: Design and Operational Considerations" 2013 International Water Conference,
13 Orlando, FL.

DRAFT

Appendix G. Scenario evaluation

1 This appendix provides the detailed results of the scenario evaluations. Each scenario consists of a set of
 2 conceptual projects, that when combined, addresses drinking water quality and quantity issues for the
 3 14 communities currently known to be affected by per- and polyfluoroalkyl substances (PFAS)
 4 contamination in the East Metropolitan Area of the Twin Cities. The scenarios were evaluated using a set
 5 of evaluation criteria, as presented below.

G.1 Recommended scenarios

7 The following three scenarios are part of the three recommendations described in detail in Chapter 7.
 8 The evaluations for those three recommended scenarios are presented first, followed by all the other
 9 scenarios.

G.1.1 Scenario A.1 (HI>0.5, GAC) – Recommended Option 1

11 Table G.1 summarizes the ratings against the applicable evaluation criteria, including the rationale for
 12 each rating.

13 **Table G.1 Evaluation Criteria of the Community-Specific Scenario A1, HI>0.5, GAC**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Wells with HI<0.5 do not receive treatment/hook-up and may require treatment with future plume movement or changes in HBVs or HRLs

Criteria	Priority	Rating	Rationale
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required. Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon <p>Continued impact on White Bear Lake</p>
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is below the median cost
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is among the lowest across all scenarios
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies

Criteria	Priority	Rating	Rationale
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities Projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.1.2 Scenario A.1 (HI>0.3, GAC) – Recommended Option 2**

2 Table G.2 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.2. Evaluation Criteria of the Community-Specific Scenario A1, HI>0.3, GAC**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater With HI<0.3 there are fewer wells that do not receive treatment/hook-up and may require treatment with future plume movement or changes in HBVs or HRLs

Criteria	Priority	Rating	Rationale
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required. Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon <p>Continued impact on White Bear Lake</p>
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is below the median cost
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is among the lowest across all scenarios
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies

Criteria	Priority	Rating	Rationale
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities Projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.1.3 Scenario C.1 (SPRWS, HI>0.5, GAC) – Recommended Option 3**

2 Table G.3 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.3 Evaluation Criteria of the Community-Specific Scenario SPWRS, HI>0.3, GAC**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions SPRWS can sustainably support anticipated demands for Oakdale and Lake Elmo Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand

Criteria	Priority	Rating	Rationale
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> • Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs • Many homes on private wells are hooked up to municipal water systems with treated groundwater • Wells with HI<0.3 do not receive treatment/hook-up and may require treatment with future plume movement or changes in HBVs or HRLs • Homes connected to SPRWS receive water with much less PFAS concentrations
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> • The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions • SPRWS is unlikely to be impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	O	<ul style="list-style-type: none"> • Serving Oakdale and Lake Elmo with SPRWS will bring an increase in disinfection byproducts (DBPs); SPRWS meets EPA requirements for DBPs, but levels are higher than current groundwater-based systems • Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers • Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals) • There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required. • Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual

Criteria	Priority	Rating	Rationale
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon <p>Continued impact on White Bear Lake</p>
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	0	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is above the median cost
14. Has low long-term O&M costs	Medium	0	<ul style="list-style-type: none"> Long-term annual O&M is in the middle range across all scenarios
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	0	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council SPRWS serving Oakdale & Lake Elmo diverges from the Met Council approved community water plans Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	0	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale and Lake Elmo Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2 Other scenarios**

2 **G.2.1 Scenario A (HI>1, GAC)**

3 Table G.4 summarizes the ratings against the applicable evaluation criteria, including the rationale for
 4 each rating.

5 **Table G.4 Evaluation Criteria of the Community-Specific Scenario A, HI>1, GAC**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Wells with HI<1 do not receive treatment/hook-up and may require treatment with future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required. Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual

Criteria	Priority	Rating	Rationale
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is below the median cost
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is among the lowest across all scenarios
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities Projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.2 Community Scenario, A HI>0, GAC**

2 Table G.5 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4

1 **Table G.5. Evaluation Criteria of the Community-Specific Scenario A, HI>0, GAC**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Nearly all wells receive treatment/hook-up and as a result would not be affected by future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required. Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Continued impact on White Bear Lake

Criteria	Priority	Rating	Rationale
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	0	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is above the median cost
14. Has low long-term O&M costs	Medium	-	<ul style="list-style-type: none"> Long-term annual O&M is among the highest across all scenarios
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities Projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.3 Community Scenario A, HI>1, IX**

2 Table G.6 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

- 4
- 5
- 6
- 7
- 8

1 **Table G.6. Evaluation Criteria of the Community-Specific Scenario A, HI>1, IX**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Wells with HI<1 do not receive treatment/hook-up and may require treatment with future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> There is some risk of corrosivity issues with IX but it is usually minor and easy to manage with existing techniques Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual.

Criteria	Priority	Rating	Rationale
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is below the median cost
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is among the lowest across all scenarios
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities Projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.4 Community Scenario A, HI>0, IX**

2 Table G.7 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4

1 **Table G.7 Evaluation Criteria of the Community-Specific Scenario A, HI>0, IX**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Nearly all wells receive treatment/hook-up and as a result would not be affected by future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> There is some risk of corrosivity issues with IX but it is usually minor and easy to manage with existing techniques Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual.

Criteria	Priority	Rating	Rationale
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	O	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this roughly at the median cost
14. Has low long-term O&M costs	Medium	O	<ul style="list-style-type: none"> Long-term annual O&M is in the middle range among all scenarios
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities Projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.5 Community Scenario B, HI>1, GAC**

2 Table G.8 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4

1 **Table G.8. Evaluation Criteria of the Community-Specific Scenario B, HI>1, GAC**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions SPRWS can sustainably support anticipated demands for Oakdale Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Wells with HI<1 do not receive treatment/hook-up and may require treatment with future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions SPRWS is unlikely to be impacted or harmed by remedial actions

Criteria	Priority	Rating	Rationale
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	O	<ul style="list-style-type: none"> Serving Oakdale with SPRWS will bring an increase in disinfection byproducts (DBPs); SPRWS meets EPA requirements for DBPs, but levels are higher than current groundwater-based systems Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals) There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required.
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	O	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is above the median cost
14. Has low long-term O&M costs	Medium	O	<ul style="list-style-type: none"> Long-term annual O&M is in the middle range among all scenarios
Other criteria			

Criteria	Priority	Rating	Rationale
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council SPRWS serving Oakdale diverges from the Met Council approved community water plans Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.6 Community Scenario B, HI>1, IX**

2 Table G.9 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.9. Evaluation Criteria of the Community-Specific Scenario B, HI>1, GAC**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions SPRWS can sustainably support anticipated demands for Oakdale Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years

Criteria	Priority	Rating	Rationale
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Wells with HI<1 do not receive treatment/hook-up and may require treatment with future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions SPRWS is unlikely to be impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	O	<ul style="list-style-type: none"> Serving Oakdale with SPRWS will bring an increase in disinfection byproducts (DBPs); SPRWS meets EPA requirements for DBPs, but levels are higher than current groundwater-based systems Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals) There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required.
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Continued impact on White Bear Lake

Criteria	Priority	Rating	Rationale
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	O	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is above the median cost
14. Has low long-term O&M costs	Medium	O	<ul style="list-style-type: none"> Long-term annual O&M is in the middle range across all scenarios
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council SPRWS serving Oakdale diverges from the Met Council approved community water plans Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.7 Community Scenario B, HI>0, GAC**

2 Table G.10 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4

1 **Table G.10. Evaluation Criteria of the Community-Specific Scenario B, HI>0, GAC**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions SPRWS can sustainably support anticipated demands for Oakdale Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Nearly all wells receive treatment/hook-up and as a result would not be affected by future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions SPRWS is unlikely to be impacted or harmed by remedial actions

Criteria	Priority	Rating	Rationale
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	O	<ul style="list-style-type: none"> Serving Oakdale with SPRWS will bring an increase in disinfection byproducts (DBPs); SPRWS meets EPA requirements for DBPs, but levels are higher than current groundwater-based systems Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals) There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required.
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	-	<ul style="list-style-type: none"> Total 20-year cost exceeds available funds
14. Has low long-term O&M costs	Medium	-	<ul style="list-style-type: none"> Long-term annual O&M is among the highest across all scenarios
Other criteria			

Criteria	Priority	Rating	Rationale
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council SPRWS serving Oakdale diverges from the Met Council approved community water plans Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.8 Community Scenario B, HI>0, IX**

2 Table G.11 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.11. Evaluation Criteria of the Community-Specific Scenario B, HI>0, IX**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions SPRWS can sustainably support anticipated demands for Oakdale Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years

Criteria	Priority	Rating	Rationale
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Nearly all wells receive treatment/hook-up and as a result would not be affected by future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions SPRWS is unlikely to be impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	0	<ul style="list-style-type: none"> Serving Oakdale with SPRWS will bring an increase in disinfection byproducts (DBPs); SPRWS meets EPA requirements for DBPs, but levels are higher than current groundwater-based systems Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals) There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required. Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual

Criteria	Priority	Rating	Rationale
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	-	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds
14. Has low long-term O&M costs	Medium	-	<ul style="list-style-type: none"> Long-term annual O&M is among the highest across all scenarios
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council SPRWS serving Oakdale diverges from the Met Council approved community water plans Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.9 Community Scenario C, HI>1, GAC**

2 Table G.12 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

1 **Table G.12. Evaluation Criteria of the Community-Specific Scenario C, HI>1, GAC**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions SPRWS can sustainably support anticipated demands for Oakdale and Lake Elmo Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Wells with HI<1 do not receive treatment/hook-up and may require treatment with future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions SPRWS is unlikely to be impacted or harmed by remedial actions

Criteria	Priority	Rating	Rationale
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	O	<ul style="list-style-type: none"> Serving Oakdale and Lake Elmo with SPRWS will bring an increase in disinfection byproducts (DBPs); SPRWS meets EPA requirements for DBPs, but levels are higher than current groundwater-based systems Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals) There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required. Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is below the median cost
14. Has low long-term O&M costs	Medium	O	<ul style="list-style-type: none"> Long-term annual O&M is in the middle range across all scenarios
Other criteria			

Criteria	Priority	Rating	Rationale
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council SPRWS serving Oakdale & Lake Elmo diverges from the Met Council approved community water plans Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale and Lake Elmo Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.10 Community Scenario C, HI>1, IX**

2 Table G.13 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.13. Evaluation Criteria of the Community-Specific Scenario C, HI>1, IX**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems

Criteria	Priority	Rating	Rationale
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions SPRWS can sustainably support anticipated demands for Oakdale and Lake Elmo Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	0	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Wells with HI<1 do not receive treatment/hook-up and may require treatment with future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions SPRWS is unlikely to be impacted or harmed by remedial actions

Criteria	Priority	Rating	Rationale
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	O	<ul style="list-style-type: none"> Serving Oakdale and Lake Elmo with SPRWS will bring an increase in disinfection byproducts (DBPs); SPRWS meets EPA requirements for DBPs, but levels are higher than current groundwater-based systems Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals) There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required. Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	O	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Reduced impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is below the median cost
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is among the lowest across all scenarios
Other criteria			

Criteria	Priority	Rating	Rationale
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council SPRWS serving Oakdale & Lake Elmo diverges from the Met Council approved community water plans Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale and Lake Elmo Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.11 Community Scenario C, HI>0, GAC**

2 Table G.14 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.14. Evaluation Criteria of the Community-Specific Scenario C, HI>0, GAC**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions SPRWS can sustainably support anticipated demands for Oakdale and Lake Elmo Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years

Criteria	Priority	Rating	Rationale
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Nearly all wells receive treatment/hook-up and as a result would not be affected by future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions SPRWS is unlikely to be impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	0	<ul style="list-style-type: none"> Serving Oakdale and Lake Elmo with SPRWS will bring an increase in disinfection byproducts (DBPs); SPRWS meets EPA requirements for DBPs, but levels are higher than current groundwater-based systems Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals) There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required. Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual

Criteria	Priority	Rating	Rationale
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	O	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Reduced impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	O	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is above the median cost
14. Has low long-term O&M costs	Medium	-	<ul style="list-style-type: none"> Long-term annual O&M is among the highest across all scenarios
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council SPRWS serving Oakdale & Lake Elmo diverges from the Met Council approved community water plans Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale and Lake Elmo Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.12 Community Scenario C, HI>0, IX**

2 Table G.15 summarizes the ratings against the applicable evaluation criteria, including the rationale for
 3 each rating.

4 **Table G.15. Evaluation Criteria of the Community-Specific Scenario C, HI>0, IX**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions SPRWS can sustainably support anticipated demands for Oakdale and Lake Elmo Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Nearly all wells receive treatment/hook-up and as a result would not be affected by future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions SPRWS is unlikely to be impacted or harmed by remedial actions

Criteria	Priority	Rating	Rationale
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	O	<ul style="list-style-type: none"> Serving Oakdale and Lake Elmo with SPRWS will bring an increase in disinfection byproducts (DBPs); SPRWS meets EPA requirements for DBPs, but levels are higher than current groundwater-based systems Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals) There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required. Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	O	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Reduced impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	-	<ul style="list-style-type: none"> Total 20-year cost exceeds available funds
14. Has low long-term O&M costs	Medium	-	<ul style="list-style-type: none"> Long-term annual O&M is among the highest across all scenarios
Other criteria			

Criteria	Priority	Rating	Rationale
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council SPRWS serving Oakdale & Lake Elmo diverges from the Met Council approved community water plans Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale and Lake Elmo Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.13 Community Scenario D, HI>1, GAC**

2 Table G.16 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.16. Evaluation Criteria of the Community-Specific Scenario C, HI>1, GAC**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)s	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand

Criteria	Priority	Rating	Rationale
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Wells with HI<1 do not receive treatment/hook-up and may require treatment with future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required. Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	O	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Reduced impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	O	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is above the median cost
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is among the lowest for the all scenarios Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			

Criteria	Priority	Rating	Rationale
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.2.14 Community Scenario D, HI>1, IX**

2 Table G.17 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.17. Evaluation Criteria of the Community-Specific Scenario D, HI>1, IX**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)s	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand

Criteria	Priority	Rating	Rationale
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Wells with HI<1 do not receive treatment/hook-up and may require treatment with future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> There is some risk of corrosivity issues with IX but it is usually minor and easy to manage with existing techniques Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual.
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	O	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Reduced impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is below the median cost
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is among the lowest for the all scenarios Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			

Criteria	Priority	Rating	Rationale
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale and Lake Elmo Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1

2 G.2.15 Community Scenario D, HI>0, GAC

3 Table G.18 summarizes the ratings against the applicable evaluation criteria, including the rationale for
4 each rating.

5 **Table G.18. Evaluation Criteria of the Community-Specific Scenario D, HI>0, GAC**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)s	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand

Criteria	Priority	Rating	Rationale
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Nearly all wells receive treatment/hook-up and as a result would not be affected by future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> There is low likelihood of bacterial contamination in new GAC treatment plants; chlorination would be required. Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	O	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is above the median cost
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is among the highest for all the scenarios Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			

Criteria	Priority	Rating	Rationale
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale and Lake Elmo Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1

2 G.2.16 Community Scenario D, HI>0, IX

3 Table G.19 summarizes the ratings against the applicable evaluation criteria, including the rationale for
4 each rating.

5 **Table G.19. Evaluation Criteria of the Community-Specific Scenario D HI>0, IX**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)s	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping for proposed new wells can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Negligible ancillary benefits

Criteria	Priority	Rating	Rationale
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater Nearly all wells receive treatment/hook-up and as a result would not be affected by future plume movement or changes in HBVs or HRLs
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> There is some risk of corrosivity issues with IX but it is usually minor and easy to manage with existing techniques Expansion of distribution systems is relatively minor and carries only low likelihood of health impacts associated with disinfection byproducts and potential loss of chlorine residual.
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	O	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Reduced impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	O	<ul style="list-style-type: none"> Total 20-year cost does not exceed available funds Of scenarios that do not exceed available funds, this one is above the median cost
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is among the lowest for the all scenarios Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			

Criteria	Priority	Rating	Rationale
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Met Council Additional input has been sought from the working groups, Met Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of projects developed in collaboration with the communities, except for SPRWS serving Oakdale and Lake Elmo Most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High		<ul style="list-style-type: none"> This rating will be completed based on feedback from working groups and public comment.

1 **G.3 Previous Community-specific scenarios**

2 The sections below provide the detailed evaluations of the community-specific scenario, separated by
3 treatment technology. The community-specific scenario with granular activated carbon (GAC) is
4 presented in Section G.1.1., while the version with ion exchange (IX) is presented in Section G.1.2.

5 **G.3.1 Community-Specific Scenario 1A – GAC**

6 Table G.20 summarizes the ratings against the applicable evaluation criteria, including the rationale for
7 each rating.

8 **Table G.20. Evaluation of the Community-Specific Scenario 1A – GAC.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
4. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
6. Provides long-term benefits [e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary operations and maintenance (O&M) activities are conducted]	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years

Criteria	Priority	Rating	Rationale
7. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Relatively little disruption to existing drinking water systems and infrastructure Negligible additional benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	0	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater By treating wells with a HI equal to or greater than 0.5, this scenario leaves relatively few, but some, wells without treatment and vulnerable to future changes in HBVs/HRLs or PFAS plume movement
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> Low likelihood of bacterial contamination of GAC treatment systems; chlorination would be required Low likelihood of increase in disinfection byproducts and loss of chlorine residual due to modest expansion of distribution systems
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
15. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	-	<ul style="list-style-type: none"> Total 20-year cost exceeds available funds

Criteria	Priority	Rating	Rationale
16. Has low long-term O&M costs	Medium	O	<ul style="list-style-type: none"> Long-term annual O&M is above the median for scenarios when outliers are removed from the analysis Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
21. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by the Metropolitan Council Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
22. Is consistent with local planning (e.g., city comprehensive plans)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities In general, most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
23. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1 **G.3.2 Community-Specific Scenario 1A – IX**

2 Table G.21 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.21. Evaluation of the Community-Specific Scenario 1A – IX.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> IX is not yet approved by the Minnesota Department of Health (MDH) but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems

Criteria	Priority	Rating	Rationale
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Relatively little disruption to existing drinking water systems and infrastructure Negligible additional benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs or HRLs Many homes on private wells are hooked up to municipal water systems with treated groundwater By treating wells with HI Equal to or greater than 0.5, this scenario leaves relatively few wells, but some, without treatment and vulnerable to future changes in HBVs/HRLs or PFAS plume movement
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> There is some risk of corrosivity issues with IX but it is usually minor and easy to manage with existing techniques. Low likelihood of increase in disinfection byproducts and loss of chlorine residual due to modest expansion of distribution systems.
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			

Criteria	Priority	Rating	Rationale
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	O	<ul style="list-style-type: none"> Total cost per millions gallons per day (mgd) is above the median among scenarios for which the total 20 year cost does not exceed available funds
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is below the median for scenarios when outliers are removed from the analysis Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with community planning, which is approved by the Metropolitan Council Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities In general, most projects have been determined to be consistent with the communities existing long-term water supply plans and current efforts Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1 G.4 Previous regional scenarios

2 The sections below provide the detailed evaluations of the regional scenarios. Sections G.2.1-G.2.3
3 present the scenarios with surface water treatment plants (SWTPs) on either the Mississippi and/or St.
4 Croix Rivers. Section G.2.4 presents the scenario that would involve expanding St. Paul Regional Water
5 Services (SPRWS). Sections G.2.5-G.2.6 present the sub-regional groundwater scenario, separated by
6 GAC and IX. The regional groundwater scenario (Regional Scenario 2D) was not evaluated because the
7 groundwater model showed that the aquifers could not sustainably support the necessary pumping
8 rates.

9 G.4.1 Regional Scenario 2A

10 Table G.22 summarizes the ratings against the applicable evaluation criteria, including the rationale for
11 each rating.

1 **Table G.22. Evaluation of the Regional Scenario 2A.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Mississippi River can sustain anticipated withdrawals; the maximum daily demand would represent less than 10% of daily river flow in the driest month on record since 1892 Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	+	<ul style="list-style-type: none"> Surface water systems have the benefit of redundancy of supply (maintain groundwater for backup) Ensure long-term safe water through centralized systems
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> With surface water as the primary source of drinking water for most communities, future issues with PFAS in groundwater or changes in HBVs/HRLs are largely avoided Communities without a municipal water system would get point of entry treatment (POET) systems; people in those homes that do not get a POET system now could be vulnerable to changing PFAS or HBVs/HRLs in the future; the Consent Order would cover homes with HI>=1 Maintaining groundwater as back-up supply protects against future risks to surface water sources, including climate change. Proposed SWTP sites are well outside current 100-year and 500-year floodplains, so flood risk under future conditions is very small.
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> Surface water sources and associated infrastructure are unlikely to be significantly impacted or harmed by remedial actions

Criteria	Priority	Rating	Rationale
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	-	<ul style="list-style-type: none"> • Conversion to surface water will almost certainly lead to an increase in disinfection byproducts; while the WTPs will likely meet regulatory requirements, there is still a health impact associated with those levels of disinfection byproducts • Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers • Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals)
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	+	<ul style="list-style-type: none"> • Less impact on Medium-High and Medium value areas identified by the Wildlife Action Network • Moderate amount of impact on Low-Medium value areas identified by the Wildlife Action Network • Reduced impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	-	<ul style="list-style-type: none"> • Total 20-year cost exceeds available funds
14. Has low long-term O&M costs	Medium	O	<ul style="list-style-type: none"> • Long-term annual O&M is above the median for scenarios when outliers are removed from the analysis • Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			

Criteria	Priority	Rating	Rationale
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> • Diverges from the Metropolitan Council approved community water supply plans • Metropolitan Council is concerned with the sustainability of groundwater in the region • Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	-	<ul style="list-style-type: none"> • Requires a switch from groundwater to surface water for a majority of the communities • Requires a reliance on a regional water supplier rather than local or non-municipal water supply • Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1

2 G.4.2 Regional Scenario 2B.1

3 Table G.23 summarizes the ratings against the applicable evaluation criteria, including the rationale for
 4 each rating.

5 **Table G.23. Evaluation of the Regional Scenario 2B.1.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> • All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> • Mississippi River can sustain anticipated withdrawals; the maximum daily demand would represent less than 8% of daily river flow in the driest month on record since 1892 • St. Croix River can sustain anticipated withdrawals; the maximum daily demand would represent less than 2% of daily river flow in the driest month on record since 1902 • Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years

Criteria	Priority	Rating	Rationale
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	+	<ul style="list-style-type: none"> • Surface water systems have the benefit of redundancy of supply (maintain groundwater for backup) • Ensure long-term safe water through centralized systems
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> • Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> • With surface water as the primary source of drinking water for most communities, future issues with PFAS in groundwater or changes in HBVs/HRLs are largely avoided • Communities without a municipal water system would get POET systems; people in those homes that do not get a POET system now could be vulnerable to changing PFAS or HBVs/HRLs in the future; the Consent Order would cover homes with HI>=1 • Maintaining groundwater as back-up supply protects against future risks to surface water sources, including climate change. • Proposed SWTP sites are well outside current 100-year and 500-year floodplains, so flood risk under future conditions is very small.
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> • Surface water sources and associated infrastructure are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	-	<ul style="list-style-type: none"> • Conversion to surface water will almost certainly lead to an increase in disinfection byproducts; while the WTPs will likely meet regulatory requirements, there is still a health impact associated with those levels of disinfection byproducts • Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers • Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals)

Criteria	Priority	Rating	Rationale
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	+	<ul style="list-style-type: none"> • Less impact on Medium-High and Medium value areas identified by the Wildlife Action Network • Moderate amount of impact on Low-Medium value areas identified by the Wildlife Action Network • Reduced impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	0	Construction would affect a moderate number of residential and total parcels compared to other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	-	<ul style="list-style-type: none"> • Total 20-year cost exceeds available funds
14. Has low long-term O&M costs	Medium	0	<ul style="list-style-type: none"> • Long-term annual O&M is above the median for scenarios when outliers are removed from the analysis • Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	0	<ul style="list-style-type: none"> • Diverges from the Metropolitan Council approved community water supply plans • Metropolitan Council is concerned with the sustainability of groundwater in the region • Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	-	<ul style="list-style-type: none"> • Requires a switch from groundwater to surface water for a majority of the communities • Requires a reliance on a regional water supplier rather than local or non-municipal water supply • Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/0/ +	

1 **G.4.3 Regional Scenario 2C – SPRWS**

2 Table G.24 summarizes the ratings against the applicable evaluation criteria, including the rationale for
 3 each rating.

4 **Table G.24. Evaluation of the Regional Scenario 2C.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> SPRWS would expand facilities to support maximum daily demand of 52 mgd and has indicated that their Mississippi River diversion and back up groundwater sources can sustainably support anticipated demands Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	+	<ul style="list-style-type: none"> Surface water systems have the benefit of redundancy of supply (maintain groundwater for backup) Ensure long-term safe water through centralized systems
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> With surface water as the primary source of drinking water for most communities, future issues with PFAS in groundwater or changes in HBVs/HRLs are largely avoided Communities without a municipal water system would get POET systems; people in those homes that do not get a POET system now could be vulnerable to changing PFAS or HBVs/HRLs in the future; the Consent Order would cover homes with HI>=1 Maintaining groundwater as back-up supply protects against future risks to surface water sources, including climate change. Proposed SWTP sites are well outside current 100-year and 500-year floodplains, so flood risk under future conditions is very small.
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions

Criteria	Priority	Rating	Rationale
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	-	<ul style="list-style-type: none"> • Conversion to surface water will almost certainly lead to an increase in disinfection byproducts; while the SWTPs will likely meet regulatory requirements, there is still a health impact associated with those levels of disinfection byproducts • Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers • Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals)
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> • Among all scenarios, this has the highest total impact on areas identified by the Wildlife Action Network, including larger impacts on areas designated Medium-High and Medium value • Reduced impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	-	Construction would affect a moderate number of residential and total parcels compared to other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	-	<ul style="list-style-type: none"> • Total 20-year cost exceeds available funds
14. Has low long-term O&M costs	Medium	-	<ul style="list-style-type: none"> • Long-term annual O&M is significantly greater than all other scenarios • Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			

Criteria	Priority	Rating	Rationale
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> • Diverges from the Metropolitan Council approved community water supply plans • Metropolitan Council is concerned with the sustainability of groundwater in the region • Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	-	<ul style="list-style-type: none"> • Requires a switch from groundwater to surface water for a majority of the communities • Requires a reliance on a regional water supplier rather than local or non-municipal water supply • Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1
2
3
4
5

G.4.4 Regional Scenario 2B.2 – Mississippi and St Croix SWTPs

Table G.25 summarizes the ratings against the applicable evaluation criteria, including the rationale for each rating.

1 **Table G.25. Evaluation of the Regional Scenario 2B.2.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Mississippi River can sustain anticipated withdrawals; the maximum daily demand would represent less than 5% of daily river flow in the driest month on record since 1892 St. Croix River can sustain anticipated withdrawals; the maximum daily demand would represent less than 5% of daily river flow in the driest month on record since 1902 Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	+	<ul style="list-style-type: none"> Surface water systems have the benefit of redundancy of supply (maintain groundwater for backup) Ensure long-term safe water through centralized systems
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	+	<ul style="list-style-type: none"> With surface water as the primary source of drinking water for most communities, future issues with PFAS in groundwater or changes in HBVs/HRLs are largely avoided Communities without a municipal water system would get POET systems; people in those homes that do not get a POET system now could be vulnerable to changing PFAS or HBVs/HRLs in the future; the Consent Order would cover homes with HI>=1 Maintaining groundwater as back-up supply protects against future risks to surface water sources, including climate change. Proposed SWTP sites are well outside current 100-year and 500-year floodplains, so flood risk under future conditions is very small.
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> Surface water sources and associated infrastructure are unlikely to be significantly impacted or harmed by remedial actions

Criteria	Priority	Rating	Rationale
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	-	<ul style="list-style-type: none"> • Conversion to surface water will almost certainly lead to an increase in disinfection byproducts; while the WTPs will likely meet regulatory requirements, there is still a health impact associated with those levels of disinfection byproducts • Despite inclusion of corrosion control measures, conversion to surface water brings risk of increasing corrosion of water mains and service lines, which may contain lead; this may result in lead contamination for some customers • Surface water sources may be more likely to contain additional contaminants that may raise health concerns in the future (e.g., pharmaceuticals)
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	+	<ul style="list-style-type: none"> • Less impact on Medium-High and Medium value areas identified by the Wildlife Action Network • Moderate amount of impact on Low-Medium value areas identified by the Wildlife Action Network • Reduced impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	0	Construction would affect a moderate number of residential and total parcels compared to other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	-	<ul style="list-style-type: none"> • Total 20-year cost exceeds available funds
14. Has low long-term O&M costs	Medium	0	<ul style="list-style-type: none"> • Long-term annual O&M is above the median for scenarios when outliers are removed from the analysis • Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			

Criteria	Priority	Rating	Rationale
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> • Diverges from the Metropolitan Council approved community water supply plans • Metropolitan Council is concerned with the sustainability of groundwater in the region • Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	-	<ul style="list-style-type: none"> • Requires a switch from groundwater to surface water for a majority of the communities • Requires a reliance on a regional water supplier rather than local or non-municipal water supply • Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1

2 G.4.5 Regional Scenario 2E – sub-regional groundwater (GAC)

3 Table G.26 summarizes the ratings against the applicable evaluation criteria, including the rationale for
4 each rating.

5 **Table G.26. Evaluation of the Regional Scenario 2E – GAC.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> • All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> • Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions • Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	O	<ul style="list-style-type: none"> • Ensure long-term safe water through centralized systems
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> • Meets 2040 maximum daily demand

Criteria	Priority	Rating	Rationale
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing HBVs, climate change impacts)	High	O	<ul style="list-style-type: none"> With regional, treated groundwater as the primary source of drinking water for most communities, future issues with PFAS in groundwater or changes in HBVs/HRLs are largely avoided Communities without a municipal water system would get POET systems; people in those homes that do not get a POET system now could be vulnerable to changing PFAS or HBVs/HRLs in the future; the Consent Order would cover homes with HI>=1 Modeling shows the sub-regional well fields are resilient to drought conditions.
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	O	<ul style="list-style-type: none"> Some increase in disinfection byproducts due to length of time that water travels in the large distribution system Some chance of loss of chlorine residual due to size of the distribution system, which can increase chances of bacterial contamination (e.g., legionella)
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> More impact on high value areas identified by the Wildlife Action Network More impact on high value areas for Biodiversity Significant Reduced impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	-	Construction would affect significantly more residential and total parcels compared to other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	O	<ul style="list-style-type: none"> Cost per mgd is above the median for scenarios where the total 20 year cost does not exceed available funds Total 20-year cost does not exceed available funds

Criteria	Priority	Rating	Rationale
14. Has low long-term O&M costs	Medium	O	<ul style="list-style-type: none"> Long-term annual O&M is above the median for scenarios when outliers are removed from the analysis Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> Diverges from the Metropolitan Council approved community water supply plans Metropolitan Council is concerned with the sustainability of groundwater in the region Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Requires a reliance on a regional water supplier rather than local or non-municipal water supply Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1 **G.4.6 Regional Scenario 2E – sub-regional groundwater (IX)**

2 Table G.27 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.27. Evaluation of the Regional Scenario 2E – IX.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years

Criteria	Priority	Rating	Rationale
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	O	<ul style="list-style-type: none"> Ensure long-term safe water through centralized systems
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing health-based values, climate change impacts)	High	O	<ul style="list-style-type: none"> With regional, treated groundwater as the primary source of drinking water for most communities, future issues with PFAS in groundwater or changes in HBVs/HRLs are largely avoided Communities without a municipal water system would get POET systems; people in those homes that do not get a POET system now could be vulnerable to changing PFAS or HBVs/HRLs in the future; the Consent Order would cover homes with HI>=1 Modeling shows the sub-regional well fields are resilient to drought conditions.
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	O	<ul style="list-style-type: none"> Some increase in disinfection byproducts due to length of time that water travels in the large distribution system Some chance of loss of chlorine residual due to size of the distribution system, which can increase chances of bacterial contamination (e.g., legionella)
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> More impact on high value areas identified by the Wildlife Action Network More impact on high value areas for Biodiversity Significant Reduced impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	-	Construction would affect significantly more residential and total parcels compared to other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	O	<ul style="list-style-type: none"> Cost per mgd is above the median for scenarios where the total 20 year cost does not exceed available funds Total 20-year cost does not exceed available funds

Criteria	Priority	Rating	Rationale
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is below the median for scenarios when outliers are removed from the analysis Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	0	<ul style="list-style-type: none"> Diverges from the Metropolitan Council approved community water supply plans Metropolitan Council is concerned with the sustainability of groundwater in the region Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	0	<ul style="list-style-type: none"> Requires a reliance on a regional water supplier rather than local or non-municipal water supply Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/0/+	

1 G.5 Previous treatment scenarios

2 The sections below provide the detailed evaluations of the regional scenarios, separated by the
3 treatment level and treatment technology (i.e., GAC or IX). Only the scenarios for year 2040
4 were evaluated.

5 G.5.1 Treatment Scenario 3A – HI(PFAS) > 1 (GAC)

6 Table G.28 summarizes the ratings against the applicable evaluation criteria, including the rationale for
7 each rating.

8 **Table G.28. Evaluation of the Treatment Scenario 3A.2 – GAC.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems

Criteria	Priority	Rating	Rationale
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Relatively little disruption to existing drinking water systems and infrastructure Negligible additional benefits
7a. Addresses future water needs (e.g., population growth)	Medium	O	<ul style="list-style-type: none"> This scenario would provide 35 mgd of treated water, which is less than the project 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing health-based values, climate change impacts)	High	-	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs/HRLs This scenario leaves many well, especially private wells, without treatment, so they would be vulnerable to future changes in HBVs/HRLs or PFAS plume movement
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	Existing well locations are unlikely to be affected by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> Since these scenarios do not involve changing a drinking water source, there is low risk of creating new unintended health impacts There is some risk of bacterial growth in GAC systems but public water systems will be required to chlorinate and private systems will need to be carefully monitored and maintained; the odds of health impacts are very low
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	O	<ul style="list-style-type: none"> Minimal impact on areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Minimal construction impact on communities and residents
Cost criteria			

Criteria	Priority	Rating	Rationale
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	O	<ul style="list-style-type: none"> • Cost per mgd is above the median for scenarios where the total 20 year cost does not exceed available funds • Total 20-year cost does not exceed available funds
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> • Long-term annual O&M is below the median for scenarios when outliers are removed from the analysis • Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> • Provides treatment to most communities consistent with Metropolitan Council's regional plan for safe drinking water • Does not reflect the local planning efforts of some communities to expand their municipal water systems • Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> • Provides treatment to most communities • Does not reflect the local planning efforts of some communities to expand their municipal water systems • Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1 **G.5.2 Treatment Scenario 3A – HI(PFAS) > 1 (IX)**

2 Table G.29 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.
4

1 **Table G.29. Evaluation of the Treatment Scenario 3A.2 – IX.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Relatively little disruption to existing drinking water systems and infrastructure Negligible additional benefits
7a. Addresses future water needs (e.g., population growth)	Medium	0	<ul style="list-style-type: none"> This scenario would provide 35 mgd of treated water, which is less than the project 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing health-based values, climate change impacts)	High	-	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs/HRLs This scenario leaves many well, especially private wells, without treatment, so they would be vulnerable to future changes in HBVs/HRLs or PFAS plume movement
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	Existing well locations are unlikely to be affected by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> Since these scenarios do not involve changing a drinking water source, there is low risk of creating new unintended health impacts
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	0	<ul style="list-style-type: none"> Minimal impact on areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Minimal construction impact on communities and residents

Criteria	Priority	Rating	Rationale
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Cost per mgd is below the median for scenarios where the total 20 year cost does not exceed available funds Total 20-year cost under 50% of the available funds
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is below the median for scenarios when outliers are removed from the analysis Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> Provides treatment to most communities consistent with Metropolitan Council's regional plan for safe drinking water Does not reflect the local planning efforts of some communities to expand their municipal water systems Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Provides treatment to most communities Does not reflect the local planning efforts of some communities to expand their municipal water systems Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1 **G.5.3 Treatment Scenario 3B – HI(PFAS) > 0.5 (GAC)**

2 Table G.30 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.30. Evaluation of the Treatment Scenario 3B.2 – GAC.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems

Criteria	Priority	Rating	Rationale
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Relatively little disruption to existing drinking water systems and infrastructure Negligible additional benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing health-based values, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs/HRLs This scenario leaves some wells without treatment, so they would be vulnerable to future changes in HBVs/HRLs or PFAS plume movement; there are fewer wells without treatment than under 3A
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)		+	Existing well locations are unlikely to be affected by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> Since these scenarios do not involve changing a drinking water source, there is low risk of creating new unintended health impacts There is some risk of bacterial growth in GAC systems but public water systems will be required to chlorinate and private systems will need to be carefully monitored and maintained; the odds of health impacts are very low
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	O	<ul style="list-style-type: none"> Minimal impact on areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Minimal construction impact on communities and residents
Cost criteria			

Criteria	Priority	Rating	Rationale
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> • Cost per MGD is below the median for scenarios where the total 20 year cost does not exceed available funds • Total 20-year cost does not exceed available funds
14. Has low long-term O&M costs	Medium	O	<ul style="list-style-type: none"> • Long-term annual O&M is above the median for scenarios when outliers are removed from the analysis • Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> • Provides treatment to most communities consistent with Metropolitan Council's regional plan for safe drinking water • Does not reflect the local planning efforts of some communities to expand their municipal water systems • Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> • Provides treatment to most communities • Does not reflect the local planning efforts of some communities to expand their municipal water systems • Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1 **G.5.4 Treatment Scenario 3B – HI(PFAS) > 0.5 (IX)**

2 Table G.31 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.31. Evaluation of the Treatment Scenario 3B.2 – IX.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> • IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country • All other technologies and approaches are standard and well-established as being reliable for drinking water systems

Criteria	Priority	Rating	Rationale
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Relatively little disruption to existing drinking water systems and infrastructure Negligible additional benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing health-based values, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs/HRLs This scenario leaves some wells without treatment, so they would be vulnerable to future changes in HBVs/HRLs or PFAS plume movement; there are fewer wells without treatment than under 3A
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)		+	Existing well locations are unlikely to be affected by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> Since these scenarios do not involve changing a drinking water source, there is low risk of creating new unintended health impacts
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	O	<ul style="list-style-type: none"> Minimal impact on areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Minimal construction impact on communities and residents
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Cost per MGD is below the median for scenarios where the total 20 year cost does not exceed available funds Total 20-year cost does not exceed available funds

Criteria	Priority	Rating	Rationale
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is below the median for scenarios when outliers are removed from the analysis Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	0	<ul style="list-style-type: none"> Provides treatment to most communities consistent with Metropolitan Council's regional plan for safe drinking water Does not reflect the local planning efforts of some communities to expand their municipal water systems Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	0	<ul style="list-style-type: none"> Provides treatment to most communities Does not reflect the local planning efforts of some communities to expand their municipal water systems Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/0/ +	

1 **G.5.6 Treatment Scenario 3C – HI(PFOS, PFOA, PFHxS) > 0 (GAC)**

2 Table G.32 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.32. Evaluation of the Treatment Scenario 3C.2 – GAC.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years

Criteria	Priority	Rating	Rationale
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Relatively little disruption to existing drinking water systems and infrastructure Negligible additional benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing health-based values, climate change impacts)	High	+	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs/HRLs This scenario leaves relatively few wells without treatment, so very few homes would be vulnerable to future changes in HBVs/HRLs or PFAS plume movement
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	Existing well locations are unlikely to be affected by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> Since these scenarios do not involve changing a drinking water source, there is low risk of creating new unintended health impacts There is some risk of bacterial growth in GAC systems but public water systems will be required to chlorinate and private systems will need to be carefully monitored and maintained; the odds of health impacts are very low
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	0	<ul style="list-style-type: none"> Minimal impact on areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Minimal construction impact on communities and residents
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Cost per MGD is equal to the median for scenarios where the total 20 year cost does not exceed available funds Total 20-year cost does not exceed available funds

Criteria	Priority	Rating	Rationale
14. Has low long-term O&M costs	Medium	O	<ul style="list-style-type: none"> Long-term annual O&M is above the median for scenarios when outliers are removed from the analysis Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> Provides treatment to most communities consistent with Metropolitan Council's regional plan for safe drinking water Does not reflect the local planning efforts of some communities to expand their municipal water systems Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Provides treatment to all communities Does not reflect the local planning efforts of some communities to expand their municipal water systems Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1 **G.5.7 Treatment Scenario 3C – HI(PFOS, PFOA, PFHxS) > 0 (IX)**

2 Table G.33 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.33. Evaluation of the Treatment Scenario 3C.2 – IX.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems

Criteria	Priority	Rating	Rationale
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Relatively little disruption to existing drinking water systems and infrastructure Negligible additional benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 max daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing health-based values, climate change impacts)	High	+	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs/HRLs This scenario leaves relatively few wells without treatment, so very few homes would be vulnerable to future changes in HBVs/HRLs or PFAS plume movement
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	Existing well locations are unlikely to be affected by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> Since these scenarios do not involve changing a drinking water source, there is low risk of creating new unintended health impacts
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	O	<ul style="list-style-type: none"> Minimal impact on areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	<ul style="list-style-type: none"> Minimal construction impact on communities and residents
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Cost per MGD is below the median for scenarios where the total 20 year cost does not exceed available funds Total 20-year cost does not exceed available funds

Criteria	Priority	Rating	Rationale
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is below the median for scenarios when outliers are removed from the analysis Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> Provides treatment to most communities consistent with Metropolitan Council's regional plan for safe drinking water Does not reflect the local planning efforts of some communities to expand their municipal water systems Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Provides treatment to all communities Does not reflect the local planning efforts of some communities to expand their municipal water systems Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1 **G.5.8 Treatment Scenario 3D – HI(PFAS) > 0 (GAC)**

2 Table G.34 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.34. Evaluation of the Treatment Scenario 3D.2 – GAC.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years

Criteria	Priority	Rating	Rationale
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Relatively little disruption to existing drinking water systems and infrastructure Negligible additional benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing health-based values, climate change impacts)	High	+	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs/HRLs This scenario leaves very few wells without treatment, so very few homes would be vulnerable to future changes in HBVs/HRLs or PFAS plume movement
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	Existing well locations are unlikely to be affected by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> Since these scenarios do not involve changing a drinking water source, there is low risk of creating new unintended health impacts There is some risk of bacterial growth in GAC systems but public water systems will be required to chlorinate and private systems will need to be carefully monitored and maintained; the odds of health impacts are very low
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	0	<ul style="list-style-type: none"> Minimal impact on areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	<ul style="list-style-type: none"> Minimal construction impact on communities and residents
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	-	<ul style="list-style-type: none"> Total 20-year cost exceeds available funds

Criteria	Priority	Rating	Rationale
14. Has low long-term O&M costs	Medium	-	<ul style="list-style-type: none"> Long-term annual O&M is significantly greater than nearly all other scenarios Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	0	<ul style="list-style-type: none"> Provides treatment to most communities consistent with Metropolitan Council's regional plan for safe drinking water Does not reflect the local planning efforts of some communities to expand their municipal water systems Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	0	<ul style="list-style-type: none"> Provides treatment to all communities Does not reflect the local planning efforts of some communities to expand their municipal water systems Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/0/ +	

1 **G.5.9 Treatment Scenario 3D – HI(PFAS) > 0 (IX)**

2 Table G.35 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.

4 **Table G.35. Evaluation of the Treatment Scenario 3D.2 – IX.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems

Criteria	Priority	Rating	Rationale
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Relatively little disruption to existing drinking water systems and infrastructure Negligible additional benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing health-based values, climate change impacts)	High	+	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs/HRLs This scenario leaves very few wells without treatment, so very few homes would be vulnerable to future changes in HBVs/HRLs or PFAS plume movement
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	Existing well locations are unlikely to be affected by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> Since these scenarios do not involve changing a drinking water source, there is low risk of creating new unintended health impacts
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	0	<ul style="list-style-type: none"> Minimal impact on areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Minimal construction impact on communities and residents
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	+	<ul style="list-style-type: none"> Cost per mgd is below the median for scenarios where the total 20 year cost does not exceed available funds Total 20-year cost does not exceed available funds

Criteria	Priority	Rating	Rationale
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> Long-term annual O&M is below the median for scenarios when outliers are removed from the analysis Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	O	<ul style="list-style-type: none"> Provides treatment to most communities consistent with Metropolitan Council's regional plan for safe drinking water Does not reflect the local planning efforts of some communities to expand their municipal water systems Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Provides treatment to all communities Does not reflect the local planning efforts of some communities to expand their municipal water systems Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1 G.6 Integrated scenarios

2 The sections below provide the detailed evaluations of the integrated scenario, separated by treatment
3 technology. GAC is presented in Section G.4.1. IX is presented in Section G.4.2.

4 G.6.1 Integrated Scenario 4A – GAC

5 Table G.36 summarizes the ratings against the applicable evaluation criteria, including the rationale for
6 each rating.

7 **Table G.36. Evaluation of the Integrated Scenario 4A – GAC.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> All technologies and approaches are standard and well-established as being reliable for drinking water systems

Criteria	Priority	Rating	Rationale
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Relatively little disruption to existing drinking water systems and infrastructure Negligible additional benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing health-based values, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs/HRLs Many homes on private wells are hooked up to PWSs with treated groundwater Targeting HI>0.5, this scenario leaves relatively few wells without treatment and vulnerable to future changes in HBVs/HRLs or PFAS plume movement
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> Low likelihood of bacterial contamination of GAC treatment systems; chlorination would be required. Low likelihood of increase in disinfection byproducts and loss of chlorine residual due to modest expansion of distribution systems
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration or reactivation of the carbon Continued impact on White Bear Lake
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			

Criteria	Priority	Rating	Rationale
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	-	<ul style="list-style-type: none"> Total 20-year cost exceeds available funds
14. Has low long-term O&M costs	Medium	O	<ul style="list-style-type: none"> Long-term annual O&M is above the median for scenarios when outliers are removed from the analysis Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Metropolitan Council The Metropolitan Council's Master Water Supply Plan indicates that a goal of the regional plan is to help realize economies of scale Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	O	<ul style="list-style-type: none"> Consists of variations on the community proposed conceptual projects and the conceptual projects are generally consistent with local planning However, variations will require collaboration between communities that is not currently consistent with comprehensive plans, water supply plans, or the proposed conceptual projects
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/O/ +	

1 **G.6.2 Integrated Scenario 4A – IX**

2 Table G.37 summarizes the ratings against the applicable evaluation criteria, including the rationale for
3 each rating.
4

1 **Table G.37. Evaluation of the Integrated Scenario 4A – IX.**

Criteria	Priority	Rating	Rationale
Implementation criteria			
3. Has a high probability of success (i.e., project outcomes are achieved)	High	+	<ul style="list-style-type: none"> IX is not yet approved by MDH but is in pilot-testing; IX is a well-established technology used throughout the country All other technologies and approaches are standard and well-established as being reliable for drinking water systems
5. Provides long-term benefits (e.g., sustainability of water supply, longevity of infrastructure, etc.; assuming all necessary O&M activities are conducted)	High	+	<ul style="list-style-type: none"> Groundwater modeling shows that anticipated 2040 pumping can be sustained by the aquifers in drought conditions Infrastructure in this scenario is expected to have a standard lifespan of roughly 50 years
6. Provides multiple benefits (e.g., benefits to the aquifer, benefits to multiple communities)	Low	-	<ul style="list-style-type: none"> Relatively little disruption to existing drinking water systems and infrastructure Negligible additional benefits
7a. Addresses future water needs (e.g., population growth)	Medium	+	<ul style="list-style-type: none"> Meets 2040 maximum daily demand
7b. Addresses future unknown/uncertain conditions (e.g., new contaminants, movement of contaminants, changing health-based values, climate change impacts)	High	O	<ul style="list-style-type: none"> Treatment removes PFAS to detection limits, so wells that receive treatment would very likely remain below any future HBVs/HRLs Many homes on private wells are hooked up to PWSs with treated groundwater Targeting HI>0.5, this scenario leaves relatively few wells without treatment and vulnerable to future changes in HBVs/HRLs or PFAS plume movement
8. Has low risk of adverse impacts from remedial actions (e.g., those conducted under the Consent Order or other known remedies)	Medium	+	<ul style="list-style-type: none"> The groundwater model was used to locate wells such that they are unlikely to be significantly impacted or harmed by remedial actions
9. Has low risk of unintended adverse health impacts (e.g., change in water corrosiveness, generation of disinfection byproducts)	Medium	+	<ul style="list-style-type: none"> Low likelihood of increase in disinfection byproducts and loss of chlorine residual due to modest expansion of distribution systems
10. Minimizes adverse environmental impacts (e.g., movement of contaminants, additional contamination, physical harm to the environment, generation of waste)	Medium	-	<ul style="list-style-type: none"> Significantly more impact on Medium-High and Medium value areas identified by the Wildlife Action Network Small generation of waste that can be handled by incineration Continued impact on White Bear Lake

Criteria	Priority	Rating	Rationale
11. Minimizes adverse social impacts (e.g., construction impacts such as noise and poor air quality, disproportionate impact to disadvantaged communities)	Medium	+	Construction would affect fewer residential and total parcels than other scenarios
Cost criteria			
13. Is cost-effective (Metrics may include: \$ per household, \$ per gallon treated; cost to include capital and O&M)	Medium	0	<ul style="list-style-type: none"> • Cost per mgd is above the median for scenarios where the total 20 year cost does not exceed available funds • Total 20-year cost does not exceed available funds
14. Has low long-term O&M costs	Medium	+	<ul style="list-style-type: none"> • Long-term annual O&M is below the median for scenarios when outliers are removed from the analysis • Rating does not currently take into account cost-sharing or any other contributions from communities to long-term O&M
Other criteria			
18. Is consistent with regional planning (e.g., Metropolitan Council planning, Washington County planning, regional aquifer planning)	Medium	+	<ul style="list-style-type: none"> • In general, consists of projects developed in collaboration with the communities and are consistent with the community planning, which is approved by Metropolitan Council • The Metropolitan Council's Master Water Supply Plan indicates that a goal of the regional plan is to help realize economies of scale • Additional input has been sought from the working groups, Metropolitan Council, and other regional government and planning bodies
19. Is consistent with local planning (e.g., city comprehensive plans)	Medium	0	<ul style="list-style-type: none"> • Consists of variations on the community proposed conceptual projects and the conceptual projects are generally consistent with local planning • However, variations will require collaboration between communities that is not currently consistent with comprehensive plans, water supply plans, or the proposed conceptual projects • Additional input has been sought from the working groups and communities
20. Is generally acceptable to the public (as reflected by public feedback on the preliminary results summary and input by the work groups)	High	-/0/ +	